

ASHUGANJ POWER STATION COMPANY LTD. (An Enterprise of Bangladesh Power Development Board) ISO 9001:2015, ISO: 14001:2015 & ISO 45001: 2018 Certified Management System.



## **TENDER DOCUMENT**

FOR

Supply, Installation, Testing & Commissioning of Circulating Water Pump Motor for 450MW CCPP-South of APSCL.

(Open Tendering Method: ICT)

## IFT NO.: 27. 25. 1233. 301. 07. 01. 18. 694

DATE: July 04, 2022

MANAGER (PROCUREMENT) ASHUGANJ POWER STATION COMPANY LTD. (APSCL) ASHUGANJ, BRAHMANBARIA-3402, BANGLADES

# **Table of Contents**

Tender Notice: 27. 25. 1233. 301. 07. 01. 18. 694 ;	DATE: July 04, 2022
Rejection Clause	
Section 1Ins	structions to Tenderers
	1
A. General	
1. Scope of Tender	1
2. Interpretation	
3. Source of Funds	
4. Corrupt, Fraudulent, Collusive or Coe	rcive Practices 2
5. Eligible Tenderers	
6. Eligible Goods and Related Services	
7. Site Visit	4
B. Tender Document	4
8. Tender Document: General	
9. Clarification of Tender Documents	5
10. Pre-Tender Meeting	5
11. Addendum to Tender Documents	6
C. Qualification Criteria	6
12. General Criteria 🧖	6
13. Litigation History	7
14. Experience Criteria	7
15. Financial Criteria	7
16. Appointment of Subcontractor	7
D. Tender Preparation	7
17. Only One Tender	7
18. Cost of Tendering	
19. Issuance and Sale of Tender Docume	ent8
20. Language of Tender	8
21. Contents of Tender	
22. Alternatives	
23. Tender Prices, Discounts	
24. Tender Currency	
25. Documents Establishing the Conform	•
Related services	

26. Documents Establishing Qualifications of the Tenderer	12
27. Validity Period of Tender	13
28. Extension of Tender Validity and Tender Security	13
29. Tender Security	
30. Form of Tender security	14
31. Authenticity of Tender Security	14
32. Return of Tender Security	14
33. Forfeiture of Tender Security	. 14
34. Format and Signing of Tender	.15
E.Tender Submission	. 15
35. Sealing, Marking and Submission of Tender	15
36. Deadline for Submission of tenders	16
37. Late tender	16
38. Modification, Substitution or Withdrawal of Tenders	
39. Tender Modification	17
39. Tender Modification	17
41. Withdrawal of Tender	17
F. Tender Opening and Evaluation	. 17
42. Tender Opening	17
43. Evaluation of Tenders	
44. Evaluation process	
45. Preliminary Examination	
46. Technical Examinations & Responsiveness	
47. Clarification on Tender	
48. Restrictions on the Disclosure of Information Relating to t	he
Procurement Process	21
49. Correction of Arithmetical Errors	22
50. Conversion to Single Currency	22
51. Domestic Preference	22
52. Financial Evaluation	23
53. Assessing the Price of Unpriced Items	24
54. Evaluation of Domestic Preference	24
55. Price Comparison	25
56. Negotiation	25
57. Post-qualification	25
58. Rejection of All Tenders	26
59. Informing Reasons for Rejection	26

G.	Contract Award	26
60.	Award Criteria	26
	Purchaser's Right to Vary Quantities	
	Notification of Award	
	Performance Security	
	Form and Time Limit for furnishing of Performance secu	-
	Validity of Performance Security	-
66. 07	Authenticity of performance Security	
67. 69	Contract Signing Publication of Notification of Award of Contract	28
60. 60	Debriefing of Tenderers	20 20
09. 70	Right to Complain	20 20
Section	2Tender Data S	
_		
Α.	General	30
В.	Tender Document	30
С.	Qualification Criteria	31
D.	Preparation of Tender	32
E.Su	bmission of Tender	34
F.Op	ening and Evaluation of Tenders	35
G.	Award of Contract	35
Section	3General Conditions of Con	tract
	Y	
1. [	Definitions	
2.0	Contract Documents	37
3. (	Corrupt, Fraudulent, Collusive or Coercive Practices	37
	nterpretation	
	Documents Forming the Contract in order of precedence	
	Eligibility	
	Governing Language	
	Governing Law	
	No fees/Gratuities	
	Use of Contract Documents & Information	
11.	Communications & Notices	39

12.	Trademark, Patent and Intellectual Property Rights	40
	Copyright	
	Assignment	
15.	Sub- contracting	40
16.S	Supplier's Responsibilities	40
17.	Purchaser's Responsibilities	40
18.	Scope of Supply	40
19.	Amendment to Order	41
20.	Instances When Amendment to Order May be Issued	41
21.	Adjustments in Contract Price and/or Delivery Schedule in	
	Amendment to Order	
22.	Packing and Documents	42
23.	Delivery and Documents	42
24.	Delivery and Documents	42
25		42
26.	Transportation	43
27.	Terms of Payment	43
28.	Transportation Terms of Payment Insurance	43
29.	Taxes and Duties	44
30.	Performance Security	44
	Specifications and Standards	
	Inspections and Tests	
	Warranty	
	Delays in Delivery and Extensions of Time	
	Liquidated Damages	
	Limitation of Liability	
37.	Change in Laws and Regulations	47
	Definition of Force Majeure	
39.	Notice of Force Majeure	47
40.	Duty to Minimize Delay	48
41.	Consequences of Force Majeure	48
	Termination for Default	
43.	Termination for insolvency	49
	Termination for Convenience	
45.	Procedures for Termination of Contracts	50
46.	Contract Amendment	50
	Settlement of Disputes	

Section 4 Particular Conditions of Contract 52
Section 5 Tender and Contract Forms
Tender Submission Letter (Form PG4 – 1) 61
Tenderer Information Sheet (Form PG4-2)64
Price Schedule for Goods (Form PG4-3A) – Not Applicable, 66
Price Schedule for Goods (Form PG4-3B)
Price Schedule for Goods (Form PG4-3C) - Not Applicable. 68
Price and Completion Schedule - Related Services (Form PG4-3D)
Specifications Submission and Compliance Sheet (Form PG4-4)
Manufacturer's Authorisation & Warranty/Guarantee Letter (Form PG4 - 5)
Bank Guarantee for Tender Security (Form PG4 – 6)
Notification of Award (Form PG4 - 7)
Contract Agreement (Form PG4 - 8)79
Bank Guarantee for Performance Security (Form PG4 – 9) 80
Bank Guarantee for Advance Payment (Form PG4 – 10) 81
Deviation List (Form PG4-11)82
Section 6. Schedule of Requirements
Section 7. Technical Specifications
Section 8

sor -

#### Section 1. Instructions to Tenderers

#### A. General

- Scope of Tender
   1.1 The Purchaser named in the Tender Data Sheet (TDS) (hereinafter referred to as the "Purchaser") wishes to issues these Tender Documents for the supply of Goods, and Related Services incidental thereto, as specified in the TDS and as detailed in Section 6: Schedule of Requirements.
  - 1.2 The name of the Tender and the number and identification of its constituent lot(s) are stated in the TDS.
  - 1.3 The successful Tenderer will be required to complete the delivery of the goods and related services (when applicable) as specified in the GCC Clause **18**.
- **2. Interpretation** 2.1 Throughout this Tender Document
  - (a) the term "in writing" means communication written by hand or machine duly signed and includes properly authenticated messages by facsimile or electronic mail;
  - (b) if the context so requires, singular means plural and vice versa; and
  - (c) "day" means calendar days unless otherwise specified as working days;
  - (d) "Tender Document/", means the Document provided by a Purchaser to a Tenderer as a basis for preparation of its Tender;
  - (e) "Tender ", depending on the context, means a Tender submitted by a Tenderer for delivery of Goods and Related Services to a Purchaser in response to an Invitation for Tender ;
- **3.** Source of Funds 3.1 The Purchaser has been allocated public funds from the source as indicated in the TDS and intends to apply a portion of the funds to eligible payments under the contract for which this Tender Document is issued.
  - 3.2 For the purpose of this provision, "public funds" means any funds allocated to a Purchaser under Government budget, or loan, grants and credits placed at the disposal of a Purchaser through the Government by the development partners or foreign states or organizations.
  - 3.3 Payments by the development partner, if so indicated in the TDS, will be made only at the request of the Government and upon approval by the development partner in accordance with the applicable Loan/Credit/Grant Agreement, and will be subject in all respects to the terms and conditions of that Agreement.

- 4. Corrupt, Fraudulent, Collusive or Coercive Practices
- 4.1 The Government requires that Procuring Entities, as well as Tenderers shall observe the highest standard of ethics during implementation of procurement proceedings and the execution of Contracts under public funds.
- 4.2 The Government requires that Procuring Entities, as well as Tenderers and Suppliers shall, during the Procurement proceedings and the execution of Contracts under public funds, ensure-
  - (a) strict compliance with the provisions of Section 64 of the Public Procurement Act 2006 (Act 24 of 2006);
  - (b) abiding by the code of ethics as mentioned in the Rule127 of the Public Procurement Rules, 2008;
  - (c) that neither it's any officer nor any staff or any other agents or intermediaries working on its behalf engages in any practice as detailed in ITT Sub Clause 4.3.
- 4.3 For the purposes of ITT Sub-clause 4.2 the terms set forth as bellows:
  - (a) corrupt practice means offering, giving or promising to give, receiving, or soliciting, either directly or indirectly, to any officer or employee of a Purchaser or other public or private authority or individual, a gratuity in any form; employment or any other thing or service of value as an inducement with respect to an act or decision or method followed by a Purchaser in connection with a Procurement proceeding or contract execution;
  - (b) fraudulent practice means the misrepresentation or omission of facts in order to influence a decision to be taken in a Procurement proceeding or Contract execution;
  - (c) collusive practice means a scheme or arrangement between two (2) or more Persons, with or without the knowledge of the Purchaser, that is designed to arbitrarily reduce the number of Tenders submitted or fix Tender prices at artificial, noncompetitive levels, thereby denying a Purchaser the benefits of competitive price arising from genuine and open competition; or
  - (d) coercive practice means harming or threatening to harm, directly or indirectly, Persons or their property to influence a decision to be taken in a Procurement proceeding or the execution of a Contract, and this will include creating obstructions in the normal submission process used for Tenders.
  - 4 Should any corrupt, fraudulent, collusive or coercive practice of any kind come to the knowledge of the Purchaser, it will, in the first place, allow the Tenderer to provide an explanation and shall, take actions only when a satisfactory explanation is not received. Such exclusion and the reasons thereof, shall be recorded in the record of the procurement proceedings and promptly communicated to the Tenderer concerned. Any communications between the Tenderer and the Purchaser related to matters of alleged fraud or corruption shall be in writing.

- 4.5 If corrupt, fraudulent, collusive or coercive practices of any kind determined by the Purchaser against any Tenderer alleged to have carried out such practices, the Purchaser shall -
  - (a) exclude the concerned Tenderer from further participation in the particular Procurement proceeding; or
  - reject any recommendation for award that had been proposed for (b) that concerned Tenderer or:
  - (c) declare, at its discretion, the concerned Tenderer to be ineligible to participate in further Procurement proceedings, either indefinitely or for a specific period of time.
- 4.6 The Tenderer shall be aware of the provisions on corruption, fraudulence, collusion and coercion in Section 64 of the Public Procurement Act, 2006 and Rule 127 of the Public Procurement Rules, 2008 and others as stated in GCC Clause 3.
- 5. Eligible 5.1 This Invitation for Tenders is open to eligible Tenderers from all countries, except for any specified in the TDS. A Tenderer will be Tenderers eligible if it is a citizen, or is constituted, registered and operates in conformity with the provisions of the laws of that country.
  - 5.2 A Tenderer may be a physical or juridical individual or body of individuals, or company, association invited to take part in public procurement or seeking to be so invited or submitting a Tender in response to an Invitation for Tenders.
  - 5.3 Government-owned enterprises in Bangladesh shall be eligible only if they can establish that they (i) are legally and financially autonomous, (ii) operate under commercial law, and (iii) are not a dependent agency of the Purchaser.
  - Tenderers shall have the legal capacity to enter into the Contract. A 5.4 Tenderer that is under a declaration of ineligibility by the Government of Bangladesh in accordance with applicable laws at the date of the deadline for Tender submission or thereafter shall be disqualified.
  - 5.5 Tenderers and all parties constituting the Tenderer shall not have a conflict of interest pursuant to Rule 55 of the Public Procurement Rules, 2008.
  - Tenderers in its own name or its other names or also in the case of its 5.6 Persons in different names, shall not be under a declaration of ineligibility for corrupt, fraudulent, collusive or coercive practices as stated under ITT Sub Clause 4.3.
  - 5.7 Tenderers are not restrained or barred from participating in public Procurement on grounds of execution of defective supply in the past under any Contract.
  - 5.8 Tenderers are not under a declaration of ineligibility by an international financing agency such as World Bank, Asian Development Bank or any other international agency.
  - Tenderers shall not be insolvent, be in receivership, be bankrupt, be in 5.9 the process of bankruptcy, be not temporarily barred from undertaking

3

business and it shall not be the subject of legal proceedings for any of the foregoing.

- 5.10 Tenderers shall have fulfilled its obligations to pay taxes and social security contributions under the provisions of laws and regulations of the country of its origin. In the case of foreign Tenderers, a certificate of competent authority in that country of which the Tenderer is citizen shall be provided.
- 5.11 Tenderers shall provide such evidence of their continued eligibility satisfactory to the Purchaser, as the Purchaser will reasonably request.
- 5.12 These requirements for eligibility will extend, as applicable, to Subcontractor proposed by the Tenderer.
- 6. Eligible Goods and Related Services
- 6.1 All goods and related services to be supplied under the contract are eligible, unless their origin is from a country specified in the TDS.
- 6.2 For purposes of this Clause, the term "goods" includes commodities, raw material, machinery, equipment, and industrial plants; and "related services" includes services such as insurance, transportation, installation, and commissioning, training, and initial maintenance.
- 6.3 For purposes of this clause, "origin" means the country where the goods have been mined, grown, cultivated, produced, manufactured or processed; or through manufacture, processing, or assembly, another commercially recognized article results that differs substantially in its basic characteristics from its components.
- 6.4 The origin of goods and services is distinct from the nationality of the Tenderer. The nationality of the firm that produces, assembles, distributes, or sells the goods shall not determine their origin.
- 7.1 For goods contracts requiring installation/ commissioning/ networking or similar services at site, the Tenderer, at the Tenderer's own responsibility and risk, is encouraged to visit and examine the Site and obtain all information that may be necessary for preparing the Tender and entering into a contract for the supply of goods and related services.
  - 7.2 The Tenderer should ensure that the Purchaser is informed of the visit in adequate time to allow it to make appropriate arrangements.
  - 7.3 The costs of visiting the Site shall be at the Tenderer's own expense.

#### **B.** Tender Document

- 8.1 The Sections comprising the Tender Document are listed below and should be read in conjunction with any addendum issued under ITT Clause 11.
  - Section 1 Instructions to Tenderers (ITT)
  - Section 2 Tender Data Sheet (TDS)
  - Section 3 General Conditions of Contract (GCC)

7. Site Visit



8. Tender Document: General

- Section 4 Particular Conditions of Contract (PCC)
- Section 5 Tender and Contract Forms
- Section 6 Schedule of Requirements
- Section 7 Technical Specifications
- Section 8 Drawings
- 8.2 The Purchaser shall reject any Tender if the Tender Document was not purchased directly from the Purchaser, or through its agent as stated in the TDS.
- 8.3 The Tenderer is expected to examine all instructions, forms, terms, and specifications in the Tender Document as well as addendum to Tender Documents.
- 9. Clarification of Tender
   9.1 A prospective Tenderer requiring any clarification of the Tender
   Documents
   9.1 A prospective Tenderer requiring any clarification of the Tender
   Documents
   9.1 A prospective Tenderer requiring any clarification of the Tender
   Documents
   9.1 A prospective Tenderer requiring any clarification of the Tender
   Document shall contact the Purchaser in writing at the Purchasers
   address indicated in the TDS before two-third of time allowed for
   preparation and submission of Tender elapses.
  - 9.2 A Purchaser is not obliged to answer any clarification received after that date requested under ITT Sub-Clause 9.1.
  - 9.3 The Purchaser shall respond in writing within five (5) working days of receipt of any such request for clarification received under ITT Sub-Clause 9.1
  - 9.4 The Purchaser shall forward copies of its response to all those who have purchased the Tender Document, including a description of the enquiry but without identifying its source.
  - 9.5 Should the Purchaser deem it necessary to amend the Tender Document as a result of a clarification, it shall do so following the procedure under ITT Clause 11.
  - 10.1 To clarify issues and to answer questions on any matter arising in the Tender Document, the Purchaser may, if stated in the TDS, hold a Pre-Tender Meeting at the place, date and time as specified in the TDS. All Potential Tenderers are encouraged to attend the meeting, if it is held.
  - 10.2 Minutes of the pre-Tender meeting, including the text of the questions raised and the responses given, together with any responses prepared after the meeting, will be transmitted within one week (7 days) after holding the meeting to all those who purchased the Tender Document and even those who did not attend the meeting.
  - 10.3 Any amendment to the Tender Document listed in ITT Sub-Clause 8.1 that may become necessary as a result of the pre-Tender meeting shall be made by the Purchaser exclusively through the issue of an Addendum as stated under ITT Sub-Clause 11 and not through the minutes of the pre-Tender meeting.
  - 10.4 Non-attendance at the pre-Tender meeting will not be a cause for disqualification of a Tenderer.

#### 10. Pre-Tender Meeting

- 11. Addendum to Tender Documents
- 11.1 At any time prior to the deadline for submission of Tenders, the Purchaser on its own initiative or in response to a clarification request in writing from a Tenderer, having purchased the Tender Document or as a result of a Pre-Tender meeting, may revise the Tender Document by issuing an addendum pursuant to Rule 95 of the Public Procurement Rules, 2008.
- 11.2 The addendum issued under ITT Sub-Clause 11.1 shall become an integral part of the Tender Document and shall have a date and an issue number and shall be circulated by fax, mail or e-mail, to Tenderers who have purchased the Tender Documents within five (5) working days of issuance of such addendum, to enable Tenderers to take appropriate action.
- 11.3 The Tenderer shall acknowledge receipt of an addendum.
- 11.4 Tenderers who have purchased the Tender Documents but have not received any addendum issued under ITT Sub-clause 11.1 shall inform the Purchaser of the fact by fax, mail or e-mail before **two-third** of the time allowed for the submission of Tenders has elapsed.
- 11.5 Procuring Entities shall also ensure posting of relevant addenda with the reference number and date on their website.
- 11.6 To give a prospective Tenderer reasonable time in which to take an amendment into account in preparing its Tender, the Purchaser may, at its discretion, extend the deadline for the submission of Tenders, pursuant to Rule 95(6) of the Public Procurement Rule, 2008 and under ITT Clause 36.
- 11.7 If an addendum is issued when time remaining is less than one-third of the time allowed for the preparation of Tenders, a Purchaser shall extend the deadline by an appropriate number of days for the submission of Tenders, depending upon the nature of the Procurement requirement and the addendum. The minimum time for such extension shall not be less than seven (07) days.

### C. Qualification Criteria

- **12. General Criteria** 12.1 The Purchaser requires the Tenderer to be qualified by meeting predefined, precise minimum requirements, which entails setting pass/fail criteria, which if not met by the Tenderer, will result in rejection of its Tender.
  - 12.2 In addition to meeting the eligibility criteria, as stated in ITT Clause 5, the Tenderer must satisfy the other criteria stated in ITT Clauses 13 to 15 inclusive.
  - 12.3 To qualify for a multiple number of lots in a package for which tenders are invited in the Invitation for Tenders, The Tenderer shall demonstrate having resources and experience sufficient to meet the aggregate of the qualifying criteria for the individual lot. The requirement of overall experience and specific experience under ITT Sub-Clause 14.1 (a) and 14.1 (b) shall not be separately applicable for individual lot.

Supply, installation, commissioning and testing of circulating water pump Motor for 450 MW South (Elect.) plant of APSCL

- **13. Litigation**<br/>History13.1 The maximum number of arbitration awards against the Tenderer over<br/>a period shall be as specified in the TDS.
- 14. Experience<br/>Criteria(a)Tenderers shall have the following minimum level of supply experience<br/>to qualify for supplying the Goods and Related Services under the<br/>contract:
  - (a) A minimum number of years of overall experience in the supply of goods and related services as specified in the TDS; and
  - (b) Specific experience of satisfactory completion of supply of similar goods of minimum value stated in the TDS under maximum number of contracts stated in TDS within the period stated in TDS; and
  - (c) A minimum supply and/or production capacity of Goods as specified in the TDS.

**15. Financial Criteria** 15.1 Tenderers shall have the following minimum level of financial capacity of qualify for the supply of goods under the contract:

- (a) Availability of minimum liquid assets or working capital or credit facilities from a Bank, as specified in the TDS.
- **16. Appointment of Subcontractor** 16.1 Tenderer, pursuant to Rule **53** of the PPR2008, is allowed to subcontract a portion of the Supply.
  - 16.2 The Tenderer shall specify in its Tender all portion of the Goods that will be Subcontracted, if any, including the entity(ies) to whom each portion will be subcontracted to, subject to the maximum allowable limit for subcontracting of Goods specified in the TDS.
  - 16.3 All subcontracting arrangement must be disclosed at the time of Tendering, and subcontractors must be identified in the Tender submitted by Tenderer.
  - 16.4 A Subcontractor may participate in more than one Tender, but only in that capacity.
  - 16.5 Subcontractors must comply with the provision of ITT Clause 5. For this purpose contractor shall complete the Subcontractor's information in Form PG4-1 for submission with tender.

16.6 If the Purchaser determines that a subcontractor is ineligible, the subcontracting of such portion of the Goods assigned to the ineligible subcontractor shall be disallowed.

### **D. Tender Preparation**

- **17. Only One Tender** 17.1 If a Tender for Goods is invited on 'lot-by-lot' basis, each lot shall constitute a Tender. A Tenderer shall submit only one (1) Tender for each lot, A Tenderer who submits or participates in more than one (1) Tender for each lot will cause all the Tenders with that Tenderer's participation to be rejected.
- **18. Cost of**<br/>Tendering18.1 Tenderers shall bear all costs associated with the preparation and<br/>submission of its Tender, and the Purchaser shall not be responsible or

7

liable for those costs, regardless of the conduct or outcome of the Tendering process.

- 19. Issuance and Sale of Tender Document
   19.1 A Purchaser, pursuant to Rule 94 of the Public Procurement Rules, 2008 shall make Tender Documents available immediately to the potential Tenderers, requesting and willing to purchase at the corresponding price if the advertisement has been published in the newspaper pursuant to Rule 90 of the Public Procurement Rules, 2008.
  - 19.2 Full contact details with mailing address, telephone and facsimile numbers and electronic mail address, as applicable, of those to whom Tender Documents have been issued shall be recorded with a reference number by the Purchaser or its agent.
  - 19.3 There shall not be any pre-conditions whatsoever, for sale of Tender Document and the sale of such Document shall be permitted up to the day prior to the day of deadline for the submission of Tender.
- 20. Language of Tender20.1 Tenders shall be written in English language. Supporting documents and printed literature furnished by the Tenderer may be in another language provided they are accompanied by an accurate translation of the relevant passages into the English language, in which case, for purposes of interpretation of the Tender, such translation shall govern.
  - 20.2 Tenderers shall bear all costs of translation to the governing language and all risks of the accuracy of such translation.

#### 21. Contents of Tender

- 21.1 The Tender prepared by the Tenderer shall comprise the following:
  - (a) Tender Submission Letter (Form PG4-1) as furnished in Section
     5: Tender and Contract Forms;
  - (b) Tenderer information sheet (Form PG4-2) as furnished in Section 5 Tender and Contract Forms;
  - (c) The completed Price Schedule for Goods and Related Services (Form PG4-3A, 3B, 3C and PG4-3D) as furnished in Section 5: Tender and Contract Forms as stated under ITT Clauses 23 and 24;
  - (d) Tender Security as stated under ITT Clause 29,30 and 31;
  - (e) The completed Specifications Submission and Compliance Sheet (Form PG4-4) as furnished in Section 5: Tender and Contract Forms as stated under ITT clause 25.2;
  - (f) Alternatives, if permitted, as stated under with ITT Clause 22;
  - (g) Written confirmation authorising the signatory of the Tender to commit the Tenderer, as stated under ITT Sub-Clause 34.3;
  - (h) The completed eligibility declarations, to establish its eligibility as stated under ITT Clause 5, in the Tender Submission Sheet (Form PG4-1), as furnished in section 5: Tender and Contract Forms;
  - An affidavit confirming the legal capacity stating that there are no existing orders of any judicial court that prevents either the Tenderer or employees of a Tenderer entering into or signing a Contract with the Purchaser as stated under ITT clause 5;

- An affidavit confirming that the Tenderer is not insolvent, in receivership or not bankrupt or not in the process of bankruptcy, not temporarily barred from undertaking their business for financial reasons and shall not be the subject of legal proceedings for any of the foregoing as stated under ITT Clause 5;
- (k) A certificate issued by the competent authority stating that the Tenderer is a Tax payer having valid Tax identification Number (TIN) and VAT registration number or in lieu any other document acceptable to the Purchaser demonstrating that the Tenderer is a genuine Tax payer and has a VAT registration number as a proof of fulfillment of taxation obligations as stated under ITT Clause 5. In the case of foreign Tenderers, a certificate of competent authority in that country of which the Tenderer is citizen shall be provided ;
- (I) Documentary evidence demonstrating that they are enrolled in the relevant professional or trade organizations registered in Bangladesh or in case of foreign tenderer in their country of origin or a certificate concerning their competency issued by a professional institution in accordance with the law of the country of their origin, as stated under ITT Clause 5;
- (m) The country of origin declarations, to establish the eligibility of the Goods and Related Services as stated under ITT Clause 6, in the Price Schedule for Goods and Related Services (Form PG4-3B, 3C and PG4-3D) as, applicable, furnished in Section 5: Tender and Contract Forms;
- (n) Documentary evidence as stated under ITT Clauses 25, that the Goods and Related Services conform to the Tender Documents;
- (o) Documentary evidence as stated under ITT Clause 26 that the Tenderer's qualifications conform to the Tender Documents;

Documents establishing legal and financial autonomy and compliance with commercial law, as stated under ITT Sub-clause 5.3 in case of government owned entity; and

- (q) Any other document as specified in the TDS.
- 21.2 The Tenderer shall submit the Tender Submission Letter (Form PG4-1) as furnished in Section 5: Tender and Contract Forms. This form must be completed without any alterations to its format, and no substitutes shall be accepted. All blank spaces shall be filled in with the information requested.
- 21.3 The Tenderer shall submit the completed Price Schedule for Goods and Related Services (Form PG4-3A, 3B, 3C and PG4-3D), according to their origin as appropriate as furnished in section 5: Tender and Contract Forms.
- **22. Alternatives** 22.1 Unless otherwise stated in the TDS, alternatives shall not be considered.
- 23. Tender Prices,<br/>Discounts23.1 The prices and discounts quoted by the Tenderer in the Tender<br/>Submission Letter (Form PG4-1) and in the Price Schedule (Form



9

PG4-3A, 3B, 3C and PG4-3D) shall conform to the requirements specified below.

- 23.2 All lots or items as listed in Section 6: Schedule of Requirements must be listed and priced separately on the Price Schedule following the Form PG4-3A, 3B, 3C and PG4-3D as applicable.
- 23.3 Tenders are being invited either for a single lot or for a number of lots on 'lot-by-lot' basis, as specified in the TDS.
- 23.4 Each lot shall constitute a Tender, If Tenders for Goods are invited on 'lot-by-lot' basis.
- 23.5 Tenders being invited for a single lot or for a number of lots on 'lot-bylot' basis, price quoted shall correspond to 100% of the items specified for each lot and to 100% of the quantities specified for each item of that particular lot and shall correspond to 100% of the total offered lot value, unless otherwise stated in the TDS
- 23.6 A Lot Tender not offering minimum number of items of those being priced based on percentage of the total number of items, and, the corresponding minimum value based on percentage of the total lot value, as specified in the ITT Sub-Clause 23.5 shall also be considered non-responsive.
- 23.7 Subject to ITT Sub-Clause 23.5, a Lot tender not offering a particular item which represents more than fifty percent (50%) of the estimated lot value identified by the Purchaser and specified in the TDS, even if it complies with the requirement of minimum number of items based on percentage of the total number of items as stated under ITT Sub Clause 23.5, shall be considered non-responsive.
- 23.8 The price to be quoted in Tender Submission Letter (Form PG4-1) shall be the total price of the Tender, excluding any discounts offered, only **in case of being awarded more than one lot**, by the Tenderer
- 23.9 The Tenderer wishing to offer any discount shall indicate the methodology for their application in the Tender Submission Letter (Form PG4-1) for being awarded of more than one lot.
- 23.10 Prices shall be quoted as specified in each Price Schedule (Form PG4-3A, 3B, 3C and PG4-3D) as applicable. The dis-aggregation of price components is required solely for the purpose of facilitating the comparison of tenders by the Purchaser. This shall not in any way limit the Purchaser's right to contract on any of the terms offered. In quoting prices, the Tenderer shall be free to use transportation through carriers registered in any eligible Countries. Similarly, the Tenderer may obtain insurance services from any eligible country. Prices shall be entered in the following manner:
- 23.11 For Goods, manufactured within Bangladesh, the prices in the Price schedule (Form PG4-3A) shall be entered separately in the following manner:
  - the price of the Goods quoted EXW (ex works, ex factory, ex warehouse, ex showroom, or off-the-shelf, as applicable), including all customs duties and import vat and other taxes



already paid or payable on the components and raw material used in the manufacture or assembly of the Goods;

- (b) VAT payable on account of supplier, if the contract is awarded ; and
- (c) the price for inland transportation, insurance, and other local costs for the delivery of the Goods to their final destination (Project Site) specified in the TDS.
- 23.12 For Goods, manufactured outside Bangladesh, to be imported, the prices in the Price schedule (Form PG4-3B) shall be entered separately in the following manner:
  - the price of the Goods, quoted CIP (named place of destination, in the Bangladesh ) or CIF (named port of destination, in Bangladesh) as specified in the TDS;
  - (b) VAT payable on account of supplier, if the contract is awarded; and
  - (c) the price for inland transportation, insurance, and other local costs for the delivery of the Goods to their final destination (Project Site) specified in the TDS;
  - (d) in addition to the CIP/CIF prices specified in 23.12(a) above, the price of the Goods to be imported may be quoted in other *INCOTERM* and shall be governed by the rules prescribed in the current edition of *INCOTERM* published by the International Chamber of Commerce, Paris, if so specified in the TDS;
- 23.13 For Goods, manufactured outside Bangladesh, already imported, the prices in the Price schedule (Form PG4-3C) shall be entered separately in the following manner:

the price of the Goods, including the original import value of the Goods; plus any mark-up; plus any other related local cost, and custom duties, import VAT and other import taxes already paid on the Goods already imported.

- (b) the custom duties, import VAT and other import taxes already paid (need to be supported with documentary evidence) on the Goods already imported;
- (c) the price of the Goods, obtained as the difference between (a) and (b) above;
- (d) VAT payable on account of supplier, if the contract is awarded; and
- (e) the price for inland transportation, insurance, and other local costs for the delivery of the Goods to their final destination (Project Site) specified in the TDS.

[For previously imported Goods, the quoted price shall be distinguishable from the original import value of these Goods declared to customs and shall include any rebate or mark-up of the local agent or representative and all local costs except import duties and taxes, which have been paid. For clarity the tenderers are asked

(a)

to quote the price including import duties, and additionally to provide the import duties and the price net of import duties which is the difference of those values.]

- 23.14 for Related Services, other than inland transportation and other services required to convey the Goods to their final destination, whenever such Related Services are specified in the Schedule of Requirements, the prices in the price schedule (Form PG4-3D) shall be entered in the following manner :
  - (a) the price of each item comprising the Related Services (inclusive of any applicable taxes).
- **24. Tender Currency** 24.1 For expenditures that will be incurred in Bangladesh, the Tenderer shall quote the prices in Bangladesh Taka.
  - 24.2 Suppliers offering Goods manufactured or assembled in Bangladesh, are permitted to submit their Tender in a combination of local and foreign currencies.
  - 24.3 For expenditures that will be incurred outside Bangladesh, the Tenderer may quote the prices in USD or GBP or EUR or JPY as specified in TDS.
  - 25.1 To establish the conformity of the Goods and Related Services to the Tender Documents, the Tenderer shall furnish as part of its Tender the documentary evidence that the Goods and Related services conform to the technical specifications and standards in Section 7, Technical Specifications.
    - 25.2 Documentary evidence of conformity of the Goods and services to the Tender Documents may be in the form of literature, drawings, and data, and shall consist of:
      - (a) a detailed description of the essential technical and performance characteristics of the Goods;

if so required in TDS, tenderer shall also furnish a list giving full particulars, including available sources and current prices of spare parts, special tools, etc., necessary for the proper and continuing functioning of the Goods during the period specified in the TDS, following commencement of the use of the Goods by the Purchaser ; and

- (c) an item-by-item commentary on the Purchaser's Technical Specifications demonstrating substantial responsiveness of the Goods and Related services to those specifications, or a statement of deviations and exceptions to the provisions of Section 7. Technical Specifications.
- 26.1 The documentary evidence of the Tenderer's qualifications to perform the contract if its Tender is accepted shall establish to the Purchaser's satisfaction:
  - (a) that the Tenderer meets each of the qualification criterion specified in Sub-Section C, Qualification Criteria of the ITT;
  - (b) that, if required in the TDS, a Tenderer that does not manufacture or produce the Goods it offers to supply shall submit the Manufacturer's Authorization Letter (Form PG4-5) furnished in Section 5: Tender and Contract Forms, to

25. Documents Establishing the Conformity of the Goods and Related services



(b)

26. Documents Establishing Qualifications of the Tenderer demonstrate that it has been duly authorized by the manufacturer or producer of the Goods to supply the Goods to Bangladesh.; and

- that, if required in the TDS, in case of a Tenderer not doing (c) business within Bangladesh, the Tenderer is or will be (if awarded the contract) represented by an Agent in the country equipped and able to carry out the Supplier's maintenance.
- 27. Validity Period of 27.1 Tender validities shall be determined on the basis of the complexity of Tender the Tender and the time needed for its examination, evaluation, approval of the Tender and issuance of the Notification of Award pursuant to Rule 19 and 20 of the Public Procurement Rules 2008.
  - 27.2 Tenders shall remain valid for the period specified in the TDS after the date of Tender submission deadline prescribed by the Purchaser, as stated under ITT Clause 36. A Tender valid for a period shorter than that specified will be rejected by the Purchaser as non-responsive.
- 28.1 In justified exceptional circumstances, prior to the expiration of the 28. Extension of **Tender Validity** Tender validity period, the Purchaser following Rule 21 of the Public Procurerment Rules,2008 may solicit, not later than ten (10) days before the expiry date of the Tender validity, compulsorily all the Tenderers' consent to an extension of the period of validity of their Tenders.
  - 28.2 The request for extension of Tender validity period shall state the new date of the validity of the Tender.
  - 28.3 The request from the Purchaser and the responses from the Tenderers will be made in writing.
  - 28.4 Tenderers consenting in writing to the request made by the Purchaser under ITT Sub-Clause 28.1 shall also correspondingly extend the validity of its Tender Security for twenty-eight (28) days beyond the new date for the expiry of Tender validity.
  - 28.5 Tenderers consenting in writing to the request under ITT Sub-Clause 28.1 shall not be required or permitted to modify its Tender in any circumstances.
  - 28.6 If the Tenderers are not consenting in writing to the request made by the Purchaser under ITT Sub-Clause 28.1, its Tender will not be considered for subsequent evaluation.
  - 29.1 The Tender Security and its amount shall be determined sufficient to discourage the submission of frivolous and irresponsible tenders pursuant to Rule 22 of the Public Procurement Rule, 2008 and shall be expressed as a rounded fixed amount and, shall not be stated as a precise percentage of the estimated total Contract value.
  - 29.2 The Tenderer shall furnish as part of its Tender, in favour of the Purchaser or as otherwise directed on account of the Tenderer as specified in TDS.

and Tender Security

29. Tender Security

- 29.3 Amount of the Tender security may be determined on the basis of different percentages for each lot, but the amount in fixed and currency as specified in TDS, if so indicated that the Tenders are invited on lotby-lot basis under ITT Sub Clause 23.3
- **30.** Form of Tender 30.1 The Tender Security shall be in the form of an irrevocable bank security guarantee issued by an internationally reputable bank and shall require to be endorsed by its any correspondent bank located in Bangladesh, to make it enforceable, in the format (Form PG4-6) furnished in Section 5: Tender and Contract Forms;
  - 30.2 be payable promptly upon written demand by the Purchaser in the case of the conditions listed in ITT Clause 33 being invoked; and
  - 30.3 remain valid for at least twenty eight (28) days beyond the expiry date of the Tender Validity in order to make a claim in due course against a Tenderer in the circumstances detailed under ITT Clause 33 and pursuant to Rule 25 of the Public Procurement Rules, 2008.
- 31.1 The authenticity of the Tender security submitted by a Tenderer shall 31. Authenticity of **Tender Security** be examined and verified by the Purchaser in writing from the Bank issuing the security, prior to finalization of the Evaluation Report pursuant to Rule 24 of the Public Procurement Rule, 2008.
  - 31.2 If a Tender Security is found to be not authentic, the Tender which it covers shall not be considered for subsequent evaluation and in such case the Purchaser shall proceed to take punitive measures against that Tenderer as stated under ITT Sub-Clause 4.6, pursuant to Rule 127 of the Public Procurement Rules. 2008 and in accordance with Section 64(5) of the Public Procurement Act, 2006.
  - 31.3 Tender not accompanied by a valid Tender Security as stated under Sub-Clause 29, 30 and 31, shall be considered as non-responsive.
- 32. Return of Tender 32.1 No Tender security shall be returned by the Tender Opening Committee (TOC) during and after the opening of the Tenders pursuant to Rule 26 of the Public Procurement Rules 2008.
  - 32.2 No Tender security shall be returned to the Tenderers before contract signing, except to those who are found non-responsive.
  - 32.3 Tender securities of the non-responsive Tenders shall be returned immediately after the Evaluation Report has been approved by the Purchaser.
  - 32.4 Tender securities of the responsive Tenderers shall be returned only after the lowest evaluated responsive Tenderer has submitted the performance security and signed the contract, that being even before the expiration of the validity period specified in Clause 27.
  - 32.5 Tender Securities of the Tenderers not consenting within the specified date in writing to the request made by the Purchaser under ITT Sub-Clause 28.1 in regard to extension of its Tender validity shall be discharged or returned forthwith.
- 33. Forfeiture of 33.1 The Tender security pursuant to Rule 25 of the Public Procurement **Tender Security** Rules,2008 may be forfeited if a Tenderer:

14

Security

- (a) withdraws its Tender after opening of Tenders but within the validity of the Tender as stated under ITT Clauses 27 and 28, pursuant to Rule 19 of the Public Procurement Rules 2008: or (b) refuses to accept a Notification of Award as stated under ITT Sub-Clause 62.3, pursuant to Rule 102 of the Public Procurement Rules 2008: or (c) fails to furnish performance security as stated under ITT Sub-Clause 63.2, pursuant to Rule 102 of the Public Procurement Rules 2008: or refuses to sign the Contract as stated under ITT Sub-Clause 67.2 (d) pursuant to Rue 102 of the Public Procurement Rules 2008; or does not accept the correction of the Tender price following the (e) correction of arithmetic errors as stated under ITT Clause 49, pursuant to Rule 98(11) of the Public Procurement Rules 2008 34. Format and 34.1 The Tenderer shall prepare one (1) original of the documents comprising the Tender as described in ITT Clause 21 and clearly mark it "ORIGINAL". **Signing of Tender** In addition, the Tenderer shall prepare the number of copies of the Tender. as specified in the TDS and clearly mark each of them "COPY". In the event of any discrepancy between the original and the copies, the original shall prevail. 34.2 Alternatives, if permitted under TT Clause 22, shall be clearly marked "Alternative". 34.3 The original and each copy of the Tender shall be typed or written in indelible ink and shall be signed by a person duly authorised to sign on behalf of the Tenderer. This authorisation shall consist of a written authorisation and shall be attached to the Tender Submission Letter (Form PG4-1).
  - 34.4 The name and position held by each person signing the authorisation must be typed or printed below the signature.
  - 4.5 All pages of the original and of each copy of the Tender, except for unamended printed literature, shall be numbered sequentially and signed or initialled by the person signing the Tender.
  - **34.6** Any interlineations, erasures, or overwriting shall be valid only if they are signed or initialled by the person(s) signing the Tender.
  - 34.7 Person(s) signing the Tender shall describe his or her name, address, position.

### E. Tender Submission

35.1 The Tenderer shall enclose the original in one (1) envelope and all the copies of the Tender, including the alternative, if permitted under ITT Clause 22 in another envelope, duly marking the envelopes as "ORIGINAL" "ALTERNATIVE" (if permitted) and "COPY." These sealed envelopes will then be enclosed and sealed in one (1) single outer envelope.

35. Sealing, Marking and Submission of Tender

- 35.2 Tenders shall be properly marked by Tenderers in order not be confused with other types of correspondence which may also be hand-delivered or posted by mail or courier service. The inner and outer envelopes shall:
  - (a) bear the name and address of the Tenderer ;
  - (b) be addressed to the Purchaser as stated under ITT Sub-Clause 36.1;
  - (c) bear the specific identification of this tendering process indicated in ITT Sub-Clause1.2 and any additional identification marks as specified in the TDS; and
  - (d) bear a statement "DO NOT OPEN BEFORE..." the time and date for Tender opening, as stated under ITT Sub- Clause 42.2
- 35.3 The Tenderer is solely and entirely responsible for pre-disclosure of Tender information if the envelope(s) are not properly sealed and marked.
- 35.4 Tenders shall be delivered by hand or by mail, including courier services to location as designated in the ITT Sub-Clause 36.1.
- 35.5 Tenders shall be submitted on the basis of this Tender Document issued by the Purchaser.
- 35.6 The Purchaser will, on request, provide the Tenderer with a receipt showing the date and time when it's Tender was received.
- 35.7 When so specified in the TDS, tenderers shall have the option of submitting their tenders electronically.
- 35.8 Tenderers submitting tenders electronically shall follow the electronic tender submission procedures specified in the TDS.
- 36.1 Tenders shall be delivered to the Purchaser at the address specified in the TDS and no later than the date and time specified in the TDS.
- 36.2 The Purchaser may, at its discretion on justifiably acceptable grounds duly recorded, extend the deadline for submission of Tender as stated under ITT Sub Clause 36.1, in which case all rights and obligations of the Purchaser and Tenderers previously subject to the deadline will thereafter be subject to the new deadline as extended.
- 37.1 Any Tender received by the Purchaser after the deadline for submission of Tenders as stated under ITT Sub-Clause 36.1, shall be declared LATE, rejected, returned unopened to the Tenderer.
- 38.1 A Tenderer may modify, substitute or withdraw its Tender after it has been submitted by sending a written notice duly signed by the authorised signatory properly sealed, and shall include a copy of the authorisation (the power of attorney), confirmed by an affidavit duly authenticated as stated under ITT Clause 34.3, provided that such written notice including the affidavit is received by the Purchaser prior to the deadline for submission of Tenders as stated under ITT Sub-Clause 36.1.

36. Deadline for Submission of tenders

37. Late tender

38. Modification, Substitution or Withdrawal of Tenders

- 39. Tender
   39.1 The Tenderer shall not be allowed to retrieve its original Tender, but shall be allowed to submit corresponding modification to its original Tender marked as "MODIFICATION".
- 40. Tender40.1The Tenderer shall not be allowed to retrieve its original Tender, but shall<br/>be allowed to submit another Tender marked as "SUBSTITUTION".
- 41. Withdrawal of<br/>Tender41.1 The Tenderer shall be allowed to withdraw its Tender by a Letter of<br/>Withdrawal marked as "WITHDRAWAL".

#### F. Tender Opening and Evaluation

- **42. Tender Opening** 42.1 Tenders shall be opened pursuant to Rule 97 following steps in Part D of Schedule IV of The Public Procurement Rule, 2008.
  - 42.2 Tenders shall be opened in public immediately after the deadline for submission of Tenders at the place, date and time as specified in the TDS but no later than **ONE HOUR** after expiry of the submission deadline. Tender opening shall not be delayed on the plea of absence of Tenderers or his or her representatives.
  - 42.3 Any specific electronic Tender opening procedures required if electronic tendering is permitted under ITT Sub-Clause 35.7, shall be as specified in the TDS.
  - 42.4 Persons not associated with the Tender may not be allowed to attend the public opening of Tenders.
  - 42.5 The Tenderers' representatives shall be duly authorized by the Tenderer. Tenderers or their authorised representatives will be allowed to attend and witness the opening of Tenders, and will sign a register evidencing their attendance.
  - 42.6 The authenticity of withdrawal or substitution of, or modifications to original Tender, if any made by a Tenderer in specified manner, shall be examined and verified by the Tender Opening Committee based on documents submitted under ITT Sub Clause 38.1.
  - 42.7 Tenders will be opened in the following manner:
    - (a) Firstly, envelopes marked "Withdrawal" shall be opened and "Withdrawal" notices read aloud and recorded, and the envelope with the corresponding Tender shall not be opened, but returned unopened to the Tenderer by the Purchaser at a later time immediately after preliminary examination by the Tender Evaluation Committee (TEC) as stated under ITT Sub-Clause 45.1. No Tender withdrawal shall be permitted unless the corresponding withdrawal notice contains a valid authorization to request the withdrawal and in such case the Tender shall be read aloud at the Tender opening;
    - (b) Secondly, the remaining Tenders will be sorted out and those marked "substitutes" or "modified" will be linked with their corresponding "original"(O) Tender;

- (c) Next, envelopes marked "Substitution"(S) shall be opened and read aloud and recorded, and exchanged with the corresponding Tender being substituted, and the substituted Tender shall not be opened, but returned unopened to the Tenderer by the Purchaser at a later time immediately after preliminary examination by the Tender Evaluation Committee (TEC) as stated under ITT Sub-Clause 45.1 . No Tender substitution shall be permitted unless the corresponding substitution notice contains a valid authorization to request the substitution and in such case the Tender shall be read aloud at the Tender opening.
- (d) Next envelopes marked "Modification" (M) shall be opened and read aloud with the corresponding Tender and recorded. No Tender modification shall be permitted unless the corresponding modification notice contains a valid authorization to request the modification and in such case the Tender shall be read aloud at the Tender opening.
- (e) Thirdly, if so specified in this Tender Document, the envelopes marked "Alternative "(A) shall be opened and read aloud with the corresponding Tender and recorded.
- 42.8 Ensuring that only the correct (M), (S), (A),(O) envelopes are opened, details of each Tender will be dealt with as follows:
  - (a) the Chairperson of the Tender Opening Committee will read aloud each Tender and record in the Tender Opening Sheet (TOS)
    - (i) the name and address of the Tenderer;
    - (ii) state if it is a withdrawn, modified, substituted , or original tender;
    - (iii) the Tender price;
    - (iv) the number of initialled corrections;
    - (v) any discounts;
    - (vi) any alternatives;
    - (vii) the presence or absence of any requisite Tender Security; and
    - (viii) such other details as the Purchaser, at its discretion, may consider appropriate.
  - (b) only discounts and alternative read aloud at the Tender opening will be considered in evaluation;
  - (c) all pages of the original version of the Tender, except for unamended printed literature, will be initialled by members of the Tender Opening Committee.
- 42.9 Upon completion of Tender opening, all members of the Tender Opening Committee and the Tenderers or Tenderer's duly authorised representatives attending the Tender opening shall sign by name, address, designation and their national Identification Numbers the Tender Opening Sheet, copies of which shall be issued to the Head of the Purchaser or an officer authorised by him or her and also to the members of the Tender Opening Committee and any authorised Consultants and, to the Tenderers immediately.
- 42.10 The omission of a Tenderer's signature on the record shall not invalidate the contents and effect of the record under ITT Sub-Clause 42.8.
- 42.11 No Tender will be rejected at the Tender opening stage except the LATE Tenders. .

42.12 A copy of the record shall be distributed to all Tenderers who submitted tenders in time, and posted online when electronic tendering is permitted. 43. Evaluation of 43.1 Purchaser's Tender Evaluation Committee (TEC) shall examine, evaluate and compare Tenders that are responsive to the mandatory requirements Tenders of Tender Documents in order to identify the successful Tenderer. 43.2 Tenders shall be examined and evaluated only on the basis of the criteria specified in the Tender Document. 44.1 The TEC may consider a Tender as responsive in the Evaluation, only if it 44. Evaluation is submitted in compliance with the mandatory requirements set out in the process Tender Document. The evaluation process should begin immediately after tender opening following four steps: Preliminary Examination: (a) (b) Technical Examinations and Responsiveness; Financial evaluation and price comparison, (c) Post-gualification of the lowest evaluated responsive Tenders. (d) 45.1 Compliance, adequacy and authenticity of the documentary evidences for 45. Preliminary Examination meeting the qualification criterion specified in the corresponding section of the Tender document shall have to be preliminarily examined and verified. 45.2 The TEC shall firstly examine the Tenders to confirm that all documentation requested in ITT Clause 21 has been provided. Examination of the compliance, adequacy and authenticity of the documentary evidence may follow the order below: verification of the completeness of the eligibility declaration in the (a) Tender Submission Letter (Form PG4-1), to determine the eligibility of the tenderer as stated under ITT Sub-Clause 21(h). Any alterations to its format, filling in all blank spaces with the information requested, failing which the tender may lead to rejection of the Tender: verification of that the Tenderer is enrolled in the relevant professional or trade organisations as stated under ITT Clause 21(I); verification of the eligibility in terms of legal capacity and fulfilment (c) of taxation obligation by the tenderer in accordance as stated under ITT Sub-Clause 21(i) and 21(k); verification of eligibility that the tenderer is not insolvent, in (d) receivership, bankrupt, not in the process of bankruptcy, not temporarily barred as stated under ITT Sub-Clause 21(i); verification of eligibility of Tenderer's country of origin as stated (e) under ITT Sub-Clause 21(b); (f) verification of the written authorization confirming the signatory of the Tenderer to commit the Tender has been attached with Tender Submission Letter (Form PG4-1) as stated under ITT Sub-Clause 21(g); in order to check the authenticity of Tender and Tenderer itself ;

- (g) verification of the Tender Security as stated under ITT Sub-Clause 21(d); and
- (h) Verification of that the written notice for 'WITHDRAWL' and 'SUBSTITUTION of' or MODIFICATION to, the corresponding Tender is proper and authentic, if the tender is "WITHDRAWN", "SUBSTITUTION" or "MODIFICATION", as stated under ITT Sub-Clause 38.1
- 45.3 The TEC shall confirm that the above documents and information have been provided in the Tender and the completeness of the documents and compliance of instructions given in corresponding ITT Clauses shall be verified, failing which the tender shall be considered as non-responsive.
- 46.1 Only those Tenders surviving preliminary examination need to be examined in this phase.
- 46.2 Secondly, the TEC will examine the adequacy and authenticity of the documentary evidence which may follow the order below:
  - (a) verification of the completeness of the country of origin declaration in the Price Schedule for Goods and Related Services (Form PG4-3B, 3C and PG4-3D) as furnished in Section 5: Tender and Contract Forms to determine the eligibility of the Goods and Related Services as stated under ITT Sub Clause 21(m).
  - (b) verification and examination of the documentary evidence and completed Specification Submission Sheet (Form PG4-4) as furnished in Section 5: Tender and Contract Forms to establish the conformity of the Goods and Related Services to the Tender Documents as stated under ITT Sub Clause 21(e) and 21(n).
  - (c) verification and examination of the documentary evidence that the Tenderer's qualifications conform to the Tender Documents and the Tenderer meets each of the qualification criterion specified in Sub-Section C, Qualification Criteria as stated under ITT Sub Clause 21(o).

verification and examination of the documentary evidence that Tenderer has met all the requirements in regards to scope of Supply as stated under Section 6, Schedule of Requirements, without any material deviation or reservation.

- 46.3 TEC may consider a Tender as responsive in the evaluation, only if comply with the mandatory requirements as stated under Clause 46.2.
- 46.4 The TEC's determination of a Tender's responsiveness is to be based on the documentary evidence as requested in Clause 46.2 without recourse to extrinsic evidence.
- 46.5 Information contained in a Tender, that was not requested in the Tender Document shall not be considered in evaluation of the Tender.
- 46.6 If a Tender is not responsive to the mandatory requirements set out in the Tender Document it shall be rejected by the TEC and shall not subsequently be made responsive by the Tenderer by correction of the material deviation, reservation.
- 46.7 A material deviation or reservation is one-

(d)

46. Technical Examinations & Responsiveness

- (a) which affects in any substantial way the scope, quality, or performance of the Goods and Related Services and Tenderer's qualifications mentioned in the Tender Document.
- which limits in any substantial way, inconsistent with the Tender (b) Documents, the Purchaser 's rights or the Tenderer's obligations under the Contract: or
- (c) whose rectification would anyway affect unfairly the competitive position of other Tenderers presenting responsive Tenders.
- 46.8 During the evaluation of Tender, the following definitions apply:
  - (a) "Deviation" is a departure from the requirements specified in the Tender Document:
  - (b) "Reservation" is the setting of limiting conditions or withholding from complete acceptance of the requirements specified in the Tender Document:
- 46.9 A TEC may regard a Tender as responsive, even if it contains-
  - (a) minor or insignificant deviations, which do not meaningfully alter or depart from the technical specifications, characteristics and commercial terms and conditions or other requirements set out in the Tender Document:
  - (b) errors or oversights, which if corrected, would not alter the key aspects of the Tender.
- 47.1 The TEC may ask Tenderers for clarifications of their Tenders, including 47. Clarification on breakdowns of unit rates, in order to assist the examination and evaluation Tender of the Tenders, provided that, Tender clarifications which may lead to a change in the substance of the Tender or in any of the key elements of the Tender as stated under ITT Sub-Clause 46.7, shall neither be sought nor permitted by the TEC.
  - 47.2 Change in the tender price shall not be sought or permitted, except to confirm correction of arithmetical errors discovered by the Purchaser in the evaluation of the Tender, as sated under ITT Clause 49.
    - Any request for clarifications by the TEC shall not be directed towards making an apparently non-responsive Tender responsive and reciprocally the response from the concerned Tenderer shall not be articulated towards any addition, alteration or modification to its Tender.
  - 47.4 If a Tenderer does not provide clarifications of its Tender by the date and time set in the TEC's written request for clarification, its Tender shall not be considered in the evaluation.
  - 47.5 Requests for clarification shall be in writing and shall be signed only by the Chairperson of the TEC.

48.1 Following the opening of Tenders until issuance of Notification of Award no Tenderer shall, unless requested to provide clarification to its Tender or unless necessary for submission of a complaint, communicate with the concerned Purchaser pursuant to Rule 31 of the Public Procurement Rule,2008.

48.2 Tenderers shall not seek to influence in anyway, the examination and evaluation of the Tenders.

48. Restrictions on the Disclosure of Information Relating to the Procurement Process

- 48.3 Any effort by a Tenderer to influence a Purchaser in its decision concerning the evaluation of Tenders, Contract awards may result in the rejection of its Tender as well as further action in accordance with Section 64 (5) of the Public Procurement Act 2006.
- 48.4 All clarification requests shall remind Tenderers of the need for confidentiality and that any breach of confidentiality on the part of the Tenderer may result in their Tender being disqualified.
- 48.5 Information relating to the examination, evaluation, comparison, and post qualification of the tender or contract award, shall not be disclosed to tenderers or any other persons not officially concerned with such process.
- 49.1 The TEC shall correct any arithmetic errors that are discovered during the examination of Tenders, and shall promptly notify the concerned Tenderer(s) of any such correction(s) pursuant to Rule 98(11) of the Public Procurement Rule, 2008.
- 49.2 Provided that the Tender is responsive, TEC shall correct arithmetical errors on the following basis:
  - (a) If there is a discrepancy between the unit price and the line item total that is obtained by multiplying the unit price by the quantity, the unit price shall prevail and the line item total shall be corrected, unless in the opinion of the TEC there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted will govern and the unit price will be corrected;
  - (b) If there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected.
- 49.3 Any Tenderer that does not accept the correction of the Tender amount following correction of arithmetic errors as determined by the application of ITT Sub-Clause 49.2 shall be considered as non-responsive.
- 50.1 For evaluation and comparison purpose, TEC shall convert all Tender prices expressed in the amounts in various currencies into an amount in Bangladeshi Taka currency, using the **selling exchange rates** established by the Bangladesh Bank, on the date of **Tender opening**.
- 51.1 **Domestic preference** shall be a factor in tender evaluation, unless otherwise specified in the **TDS**
- 51.2 If **domestic preference shall be a tender-evaluation factor**, the Purchaser will grant a margin of fifteen percent (15%) domestic preference to Goods manufactured in Bangladesh during the evaluation of its Tender while comparing the same with those of other Tenderers under the classification set out in ITT Sub-Clause 51.3. The evaluation will be carried out in accordance with the provisions set out in ITT Clause 54.
- 51.3 Tenders will be classified in one of two groups, as follows:
  - (a) **Group A:** Tender offering goods manufactured in Bangladesh, for which:
    - (i) labour, raw materials, and components from within the Bangladesh account for more than thirty (30) percent of the EXW price; and

49. Correction of

Errors

Arithmetical

50. Conversion to Single Currency

51. Domestic

Preference

EXW price; and

- the production facility in which they will be manufactured or assembled has been engaged in manufacturing or assembling such goods at least since the date of tender submission.
- (b) **Group B:** Tenders offering Goods manufactured outside Bangladesh that have been already imported or that will be imported.
- 51.4 To facilitate this classification by the Tenderer, the Tenderer shall complete whichever Form of the Price Schedule furnished in the Tender Document is appropriate.
- 51.5 Completion of an inappropriate Form of the Price Schedule by the Tenderer shall not result in rejection of its tender, but merely in the Purchaser's reclassification of the tenderer into its appropriate tender group.
- 52.1 Thirdly the TEC, pursuant to Rule 98 of the Public Procurement Rules, 2008 shall evaluate each Tender that has been determined, up to this stage of the evaluation, to be responsive to the mandatory requirements in the Tender Document.
  - 52.2 To evaluate a Tender in this stage , the Purchaser shall consider the following:
    - (a) Verification and examination of the Price Schedule for Goods and Related Services (Form PG4-3A, 3B, 3C and PG4-3D) as furnished by the Tenderer and checking the compliance with the instructions provided under ITT Clause 23;
    - (b) Evaluation will be done for Items or lot by lot as stated under ITT Clause 23 and the Total Tender Price as quoted in accordance with Clause 23;
    - (c) Adjustment for correction of arithmetical errors as stated under ITT Sub-Clause 49.2;
    - d) Adjustment for price modification offered as stated under ITT Clause 38;
    - Adjustment due to discount as stated under ITT Sub-Clauses 23.8, 23.9 and 52.3;
    - (f) Adjustment due to the application of economic factors of evaluation as stated under ITT Sub-Clause 52.5 if any;
    - (g) Adjustment due to the assessment of the price of unpriced items as stated under ITT Clause 53 if any;
    - (h) Adjustment due to the application of a margin of preference (domestic preference), in accordance with ITT Clause 54 if applicable
  - 52.3 If Tenders are invited for a single lot or for a number of lots as stated under ITT Sub-clauses 23.3, TEC shall evaluate only lots that that have included at least the percentage of items per lot as stated under ITT Sub-Clause 23.5 and 23.6. The TEC shall evaluate and compare the Tenders taking into account:
    - (a) Lowest evaluated tender for each lot ;
    - (b) The price discount/reduction per lot;

52. Financial Evaluation

- (c) Least cost combination for the Purchaser, considering discounts and the methodology for its application as stated under ITT Subclauses 23.8 and 23.9 offered by the Tenderer in its Tender.
- 52.4 Only those spare parts and tools which are specified as a item in the List of Goods and Related Services in Section 6, Schedule of Requirement or adjustment as stated under ITT Sub-clause 52.5, shall be taken into account in the Tender evaluation. Supplier-recommended spare parts for a specified operating requirement as stated under ITT Sub-clause 25.2(b) shall not be considered in Tender evaluation.
- 52.5 The Purchaser's evaluation of a tender may require the consideration of other factors, in addition to the Tender Price quoted as stated under ITT Clause 23. The effect of the factors selected, if any, shall be expressed in monetary terms to facilitate comparison of tenders. The factors, methodologies and criteria to be used shall be as specified in TDS. The applicable economic factors, for the purposes of evaluation of Tenders shall be:
  - (a) Adjustment for Deviations in the Delivery and Completion Schedule
  - (b) Cost of major replacement components, mandatory spare parts, and service
- 52.6 Variations, deviations, and alternatives and other factors which are in excess of the requirements of the Tender Document or otherwise result in unsolicited benefits for the Purchaser will not be taken into account in Tender evaluation.
- 53. Assessing the Price of Unpriced Items

54. Evaluation of

Domestic

Preference

- 53.1 If it is so permitted under ITT Clause 23, any Tenderer offered only eighty percent (80%) or minimum percent of the items of a lot as stated under ITT Sub-Clause 23.5, the TEC shall calculate the total lot value by adding up the average prices offered by other responsive Tenderers for the missing items to the lot value to establish the winning lot Tender. If the Tenderer offered less than the specified, the Tender shall be evaluated as sated under ITT Clause 23.
- 53.2 If the winning lot is missing some items as stated under ITT Sub Clause 53.1, comprising less than twenty percent (20%), the Purchaser may procure the missing items from the Tenderer offering the least cost for those remaining items.
- 54.1 If the Tender document so specifies, the Tenderer will grant a margin preference to goods manufactured in Bangladesh as stated in ITT Clause
   51 for the purpose of Tender comparison, in accordance with the procedure outlined below:
- 54.2 The Purchaser will first review the tenders to confirm the appropriateness of, and to modify as necessary, the tenderer group classification to which Tenderers assigned their tenders in preparing their Tender Forms and Price Schedules.
- 54.3 All evaluated tenders in each group will then be compared to determine the lowest evaluated tender of each group. Such lowest evaluated tenders shall be compared with each other and if as a result of this comparison a tenderer from Group A and the Tenders offering Goods manufactured in Bangladesh is the lowest, it shall be selected for the award.
- 54.4 If, as a result of the preceding comparison, the lowest evaluated tender is from Group B,

- (a) all Group B tenders will then be further compared with the lowest evaluated tender from Group A, after adding to the evaluated tender price of goods offered in the tender for Group B, for the purpose of further comparison only an amount equal to fifteen (15) percent of the CIF/CIP (named place of destination or named port of destination) tender price.
- (b) The lowest-evaluated tender determined from this last comparison shall be selected for the award.
- **55. Price Comparison** 55.1 The TEC shall compare all responsive Tenders to determine the lowestevaluated Tender, as stated under ITT Clause 54.
  - 55.2 In the extremely unlikely event that there is a tie for the lowest evaluated price, the Tenderer with the superior past performance with the Purchaser shall be selected, whereby factors such as delivery period, quality of Goods delivered, complaints history and performance indicators could be taken into consideration.
  - 55.3 In the event that there is a tie for the lowest price and none of the Tenderers has the record of past performance with the Purchaser, then the the Tenderer shall be selected, subject to firm confirmation through the Post-qualification process described in ITT Clause 57, after consideration as to whether the quality of Goods that is considered more advantageous by the end-users.
  - 55.4 The successful Tenderer as stated under ITT Sub Clauses 55.1, 55.2 and 55.3 shall not be selected through lottery under any circumstances.
  - 56.1 No negotiations shall be held during the Tender evaluation or award with the lowest or any other Tenderer pursuant to Rule 99 of the Public Procurement Rules, 2008.
    - 57.1 After determining the lowest-evaluated responsive tender as sated under ITT Sub-Clause 55.1, the Purchaser's TEC pursuant to Rule 100 of the Public Procurement Rules, 2008, shall carry out the Post-Qualification of the Tenderer, using only the requirements specified in Sub-Section C, Qualification Criteria.
      - 57.2 The TEC shall contact the references given by Tenderers about their previous Supply experiences to verify, if necessary, statements made by them in their Tender and to obtain the most up-to-date information concerning the Tenderers.
    - 57.3 The TEC may visit the premises of the Tenderer as a part of the postqualification process, if practical and appropriate, to verify information contained in its Tender.
    - 57.4 The TEC shall determine to its satisfaction whether the Tenderer that is selected as having submitted the lowest evaluated responsive Tender is qualified to perform the Contract satisfactorily.
    - 57.5 The objective of any visit under ITT Sub-Clause 57.3 shall be limited to a general and visual inspection of the Tenderer's facilities and its plant and equipment, and there shall be no discussion concerning the Tender or its evaluation with the Tenderer during such visit(s).

57. Postqualification

56. Negotiation

- 57.6 In the event that the Tenderer with lowest evaluated cost fails the postqualification, the TEC shall make a similar determination for the Tenderer offering the next lowest evaluated cost and so on from the remaining responsive Tenders, provided that,
  - (a) such action shall only be taken if the evaluated costs of the Tenders under consideration are acceptable to the Purchaser;
  - (b) when the point is reached whereby the evaluated costs of the remaining responsive Tenders are significantly higher than that of the official estimate, or the market price, the Purchaser may take action pursuant to Rule 33 and may proceed for re-Tendering, using a revised Tender Document designed to achieve a more successful result.
- 58. Rejection of All The Purchaser may, in the circumstances as stated under ITT Sub-Clause 58.2 and pursuant to Rule 33 of the Public Procurement Rules 2008, reject all Tenders following recommendations from the Evaluation Committee only after the approval of such recommendations by the Head of the Purchaser.
  - 58.2 All Tenders can be rejected, if -
    - (a) the price of the lowest evaluated Tender exceeds the official estimate, provided the estimate is realistic; or
    - (b) there is evidence of lack of effective competition; such as nonparticipation by a number of potential Tenderers; or
    - (c) the Tenderers are unable to propose completion of the delivery within the stipulated time in its offer, though the stipulated time is reasonable and realistic; or
    - (d) all Tenders are non-responsive; or
    - (e) evidence of professional misconduct, affecting seriously the Procurement process, is established pursuant to Rule 127 of the Public Procurement Rules, 2008.
  - 58.3 Notwithstanding anything contained in ITT Sub-Clause 58.2 Tenders may not be rejected if the lowest evaluated price is in conformity with the market price.
  - 58.4 A Purchaser may pursuant to Rule 35 of the Public Procurement Rules, 2008, on justifiable grounds, annul the Procurement proceedings prior to the deadline for the submission of Tenders.

58.5 All Tenders received by the Purchaser shall be returned unopened to the Tenderers in the event Procurement proceedings are annulled under ITT Sub-Clause 58.4.

59.1 Notice of the rejection, pursuant to Rule 35 of the Public Procurement Rules, 2008, will be given promptly within seven (7) days of decision taken by the Purchaser to all Tenderers and, the Purchaser will, upon receipt of a written request, communicate to any Tenderer the reason(s) for its rejection but is not required to justify those reason(s).

#### G. Contract Award

**60. Award Criteria** 60.1 The Purchaser shall award the Contract to the Tenderer whose offer is responsive to the Tender Document and that has been determined to be the lowest evaluated Tender, provided further that the Tenderer is determined to be Post-Qualified as stated under ITT Clause 57.

59. Informing Reasons for

Rejection

- 60.2 A Tenderer shall no be required, as a condition for award of contract, to undertake obligations not stipulated in the Tender Document, to change its price, or otherwise to modify its Tender.
- 61. Purchaser's Right to Vary Quantities61.1 The Purchaser reserves the right at the time of Contract Award to increase or decrease the quantity, per item, of Goods and Related Services originally specified in Section 6: Schedule of Requirements, provided this does not exceed the percentages indicated in the TDS, and without any change in the unit prices or other terms and conditions of the Tender and the Tender Document.
- 62. Notification of Award62.1 Prior to the expiry of the Tender validity period and within seven (7) working days of receipt of the approval of the award by the Approving Authority, the Purchaser pursuant to Rule 102 of the Public procurement Rules, 2008, shall issue the Notification of Award (NOA) to the successful Tenderer
  - 62.2 The Notification of Award, attaching the contract as per the sample (Form PG4-7) to be signed, shall state:
    - (a) the acceptance of the Tender by the Purchaser;
    - (b) the price at which the contract is awarded;
    - (c) the amount of the Performance Security and its format;
    - (d) the date and time within which the Performance Security shall be submitted; and
    - (e) the date and time within which the contract shall be signed.
  - 62.3 The Notification of Award shall be accepted in writing by the successful Tenderer within seven (7) working days from the date of issuance of NOA.
  - 62.4 Until a formal contract is signed, the Notification of Award shall constitute a Contract, which shall become binding upon the furnishing of a Performance Security and the signing of the Contract by both parties.
  - 62.5 The Notification of Award establishes a Contract between the Purchaser and the successful Tenderer and the existence of a Contract is confirmed through the signature of the Contract Document that includes all agreements between the Purchaser and the successful Tenderer.
  - 63.1 The Performance Security shall be determined sufficient to protect the performance of the Contract pursuant to Rule 27 of the Public Procurement Rules, 2008.
  - 63.2 Performance Security shall be furnished by the successful Tenderer in the amount specified in the TDS and **denominated in the currencies** in which the Contract Price is payable pursuant to Rule 102 (8) of the Public Procurement Rules, 2008.
  - 63.3 The proceeds of the Performance Security shall be payable to the Purchaser unconditionally upon first written demand as compensation for any loss resulting from the Supplier's failure to complete its obligations under the Contract.
- 64. Form and Time Limit for furnishing of
   64.1 The Performance Security shall be in the form of irrevocable Bank Guarantee in the format (Form PG4-9) as stated under ITT Clause 63, shall be issued by an internationally reputable bank and it shall have correspondent bank located in Bangladesh, to make it enforceable

- 63. Performance Security
- $\sim$

	Performance security		pursuant to Rule 27(4) of the Public Procurement Rules, 2008.
		64.2	Within twenty-eight (28) days from issue of the Notification of Award, the successful Tenderer shall furnish the Performance Security for the due performance of the Contract in the amount specified under ITT Sub Clause 63.2.
65.	Validity of Performance Security	65.1	The Performance Security shall be required to be valid until a date twenty- eight (28) days beyond the date of completion of the Supplier's performance obligations under the Contract, including any warranty obligations.
		65.2	If under any circumstances date of completion of the Supplier's performance obligations under the Contract, including any warranty obligations is to be extended, the Performance Security shall correspondingly be extended for the extended period.
66.	Authenticity of performance Security	66.1	The Purchaser shall verify the authenticity of the Performance Security submitted by the successful Tenderer by sending a written request to the branch of the bank issuing irrevocable Bank Guarantee in specified format.
		66.2	If the Performance Security submitted under ITT Sub Clause 63.2 is not found to be authentic, the Purchaser shall proceed to take measures against the Tenderer in accordance with Section 64 of the Act and pursuant to Rule 127 of the Public Procurement Rules, 2008.
67.	Contract Signing	67.1	At the same time as the Purchaser issues the Notification of Award, the Purchaser shall send the draft Contract Agreement and all documents forming the Contract pursuant to Rule 102 of the Public Procurement Rule, 2008, to the successful Tenderer.
		67.2	Within twenty-eight (28) days of the receipt of Notification of Award, the successful Tenderer and the Purchaser shall sign the contract provided that the Performance Security submitted by the Tenderer is found to be genuine.
	X	67.3	If the successful Tenderer fails to provide the required Performance Security, as stated under ITT Clause 63 or to sign the Contract, as stated under ITT Sub-Clause 67.2, Purchaser shall proceed to award the Contract to the next lowest evaluated Tenderer, and so on, by order of ranking pursuant to Rule 102 of the Public Procurement Rules,2008.
68.	Publication of Notification of Award of Contract	68.1	Notification of Awards for Contracts of Taka 10(ten) million and above shall be notified by the Purchaser to the Central Procurement Technical Unit within 7(seven) days of issuance of the NOA for publication in their website, and that notice shall be kept posted for not less than a month pursuant to Rule 37 of the Public Procurement Rules, 2008.
		68.2	Notification of Award for Contracts below Taka 10(ten) million, shall be published by the Purchaser on its Notice Board and where applicable on the website of the Purchaser and that notice shall be kept posted for not less than a month pursuant to Rule 37 of the Public Procurement Rules, 2008
69.	Debriefing of Tenderers	69.1	Debriefing of Tenderers by Purchaser shall outline the relative status and weakness only of his or her tender requesting to be informed of the grounds for not accepting the Tender submitted by him or her

pursuant to Rule 37 of the Public Procurement Rule, 2008, without disclosing information about any other Tenderer.

- 69.2 In the case of debriefing confidentiality of the evaluation process shall be maintained.
- 70.1 Any Tenderer has the right to complain if it has suffered or likely to suffer loss or damage due to a failure of a duty imposed on the Purchaser to fulfil its obligations in accordance with Section 29 of the Public Procurement Act 2006 and pursuant to Part 12 of Chapter Three of the Public Procurement Rules, 2008.
- 70.2 Circumstances in which a formal complaint may be lodged in sequence by a potential Tenderer against a Purchaser pursuant to Rule 56 of the Public Procurement Rules, 2008, and the complaints, if any, be also processed pursuant to Rule 57 of the Public Procurement Rules 2008.
- 70.3 The potential Tenderer shall submit his or her complaint in writing within seven (7) calendar days of becoming aware of the circumstances giving rise to the complaint.
- 70.4 In the first instance, the potential Tenderer shall submit his or her complaint to the Purchaser who issued the Tender Document.
- 70.5 The place and address for the first stage in the submission of complaints to the Administrative Authority is provided in the TDS.
- 70.6 The Tenderer may appeal to a Review Panel only if the Tenderer has exhausted all his or her options of complaints to the administrative authority as stated under ITT Sub-Clause 70.2.

70. Right to Complain

SC.

ITT Clause	Amendments of, and Supplements to, Clauses in the Instruction to Tenderers			
	A. General			
ITT 1.1	The Purchaser is: Ashuganj Power Station Company Ltd. (APSCL)			
	Representative:			
	Manager (Procurement) Ashuganj Power Station Company Ltd. (APSCL) Ashuganj, Brahmanbaria-3402, Bangladesh			
	Consignee:			
	Ashuganj Power Station Company Ltd. (APSCL) Ashuganj, Brahmanbaria-3402, Bangladesh			
ITT 1.2	The Name of the Tender is: Supply, Installation, Testing & Commissioning of Circulating Water Pump Motor for 450MW CCPP-South of APSCL.			
ITT 3.1	The source of fund is: APSCL's own fund			
ITT 3.3	The name of the Development Partner is: Not Applicable			
ITT 5.1	Tenderers from the following countries are not eligible: Israel			
ITT 6.1	Goods and Related Services from the following counties are not eligible: Israel			
	B. Tender Document			
ITT 8.2	The following are authorised agents of the Purchaser for the purpose of providing the Tender Document: Agents Name: Manager (Procurement) Address:			
	Ashuganj Power Station Company Ltd. (APSCL)			
	Ashuganj, Brahmanbaria-3402, Bangladesh.			
	Telephone: +88 08528 74033			
	Fax number: +88 08528 74044			
Y	e-mail : procurement@apscl.org.bd			
ITT 9.1	For <u>clarification of Tender purposes</u> only, the Purchaser's address is: Attention: Executive Engineer (Electrical), 450MW CCPP (South) Plant and Manager (Procurement), APSCL, Ashuganj, Brahmanbaria. <u>Address</u> :			
	Ashuganj Power Station Company Ltd. (APSCL)			
	Ashuganj, Brahmanbaria-3402, Bangladesh.			
	Telephone: +88 08528 74038			

# Section 2. Tender Data Sheet

	Fax number: +88 08528 74014		
	e-mail : <u>xenelect450south@apscl.org.bd</u> & <u>procurement@apscl.org.bd</u>		
ITT 10.1	A Pre-Tender meeting shall be held on dated: Will not be held		
	C. Qualification Criteria		
ITT 13.1	The maximum <i>three (3)</i> numbers of arbitration against the Tenderer over a period of <i>last five (5) years</i>		
ITT 14.1(a)	The Tenderer shall have minimum 05 (five) years of overall experience of supplying goods and related services to any Government/ Semi-government/ Government Owned, National Grid connected or internationally reputed Organization.		
ITT 14.1(b)	The Tenderer shall have satisfactory experience on supply, installation, commissioning & testing of at least one (01) Circulating water pump Motor of offered capacity within the last five (05) years to any Government / Semi- government / Government Owned Organization or Company / National Grid Connected Electricity Generation Company / Internationally reputed Organization which contract value is not less than equivalent to BDT 30,000,000.00 (BDT Thirty million) or not less than equivalent to USD 345,000.00 (USD Three hundred Forty Five thousand) or equivalent to any transferrable currency under a single contract in supported with end user certificate.		
	Or The tenderer shall have experience of supplying electrical/mechanical/similar goods within the last five (05) years to any Government / Semi-government / Government Owned Organization or Company / National Grid Connected Electricity Generation Company / Internationally reputed Organization which contract value is not less than equivalent to BDT 30,000,000.00 (BDT Thirty million) under a single contract in supported with end user certificate. In that case the tenderer must submit an "Assurance letter" duly issued by the Manufacturer taking full responsibility of installation, testing and commissioning within the supply contract.		
	On the basis of above-mentioned cases, Manufacturer's Authorization & Warranty / Guarantee Letter (Form PG4-5) must have to submit with the tender if the Tenderer is not Manufacturer.		
$\overline{}$	In above-mentioned both cases, Manufacturer's Authorization & Warranty / Guarantee Letter (Form PG4-5) must have to submit with the tender if the Tenderer is not Manufacturer.		
	The <b>Manufacturer</b> must have experience in manufacturing of at least Two (2) sets of offered Circulating water pump Motor in supported with end user certificate. The Circulating water pump motors should have minimum three (3) years satisfactory performance within last twelve (12) years.		
	It is noteworthy that above "End User Certificates" of both of the tenderer & the Manufacturer - must contain name, address, fax, phone, e-mail, website, etc. in Letter Head Pad for necessary correspondences. Moreover, years of experience		

	of the tendence Q the Menufectures will be exact beckward from the date of		
	of the tenderer & the Manufacturer will be count backward from the date of publication of IFT in the newspaper.		
	It is worth mentioning that the Circulating Water Pump Motor manufacturer / tenderer must have the installation, testing & commissioning expertise "service team" available in Bangladesh for the offered model. In this regards, necessary document must have to submit by the tenderer with the tender.		
ITT 14.1(c)	The Minimum supply and/or production capacity of goods is/are:		
	At least one quarter (1/3) of the total tender quantity per month.		
ITT 15.1(a)	For minimum amount of liquid assets or working capital or credit facility is supported with: A recently issued Bank solvency certificate amounting not less than quoted price, which needs to be submitted with tender. Credit limit must be mentioned in the		
	certificate.		
	D. Preparation of Tender		
ITT 21.1(q)	The Tenderer shall submit with its Tender the following additional documents:		
	<ul> <li>behalf of the Tenderer.</li> <li>ii. Detail specification, data sheet of equipment, instruction manual, necessary technical literatures, description of system and products, drawings and leaflets/ complete catalogue from manufacturer of the offered equipment/ items.</li> <li>iii. Technical Data Sheet, P&amp;ID Diagram</li> <li>iv. Dimensional drawing, clear cross-sectional drawing.</li> <li>v. Manufacturer must hold valid ISO 9001, ISO 14001 and OHSAS 18001 certificates for last 4 years.</li> <li>vi. Name of the manufacturer and country of origin of the offered equipment/ items.</li> <li>vii. Bank Solvency Document as per ITT 15.1 (a).</li> <li>viii. Guarantee / warranty certificate from the Tenderer on genuineness of the equipment/ items and its satisfactory performance during the warranty period as per GCC 33.3.</li> <li>ix. If Tenderer has any reservations, he has to mention it in deviation list (PG4-11).</li> <li>x. Tenderer shall have to submit Certificate from End User with details (Contract Agreement number with date, description of supplied items &amp; services and completion date) that the Tenderer had supplied the equipment and services as specified in the ITT 14.1 (b) within last 05 years.</li> <li>xi. If Tenderer does not manufacturer or produce the Goods it offers to supply shall submit the Manufacturer's Authorization &amp; Warranty/Guarantee Letter (Form PG4-5) furnished in Section 5: Tender and Contract Forms, to demonstrate that it has been duly authorized by the manufacturer or producer of the Goods to supply the Goods to Bangladesh (ITT 26.1b).</li> <li>xii. Certificate from the manufacturer confirming that his offered items are new, unused, in good condition and will fit properly without any modification.</li> <li>xiii. Supply record of the offered equipment / items of the respective manufacturers or last five (05) years with mentioning the name of supplies, client address contact number (e-mail telephone/mobile) etc.</li> </ul>		


	<ul> <li>xv. Tenderer shall have to submit Certificate confirming compliance to the terms and conditions of the Tender Document.</li> <li>xvi. Tenderer shall have to submit Certificate from end user and Manufacturer (if applicable) with details (Contract Agreement number with date, description of supplied items &amp; services and completion date) that the Tenderer and manufacturer had supplied the equipment and services as specified in the ITT 14.1 (b).</li> <li>All the Certificates should be duly signed and sealed by the tenderer.</li> </ul>
ITT 22.1	Alternatives shall not be permitted.
ITT 23.3	Tenders are being invited for single (01) lot.
ITT 23.5	Not Applicable
ITT 23.7	Not Applicable
ITT 23.11(c) ITT 23.12 (c) ITT 23.13 (e)	Insurance will be paid by APSCL. "Final destination is":450MW CCPP-South store of Ashuganj Power Station Company Ltd. (APSCL), Ashuganj, Brahmanbaria- 3402, and Bangladesh. C&F Agency cost, Inland transportation (local), loading & unloading in all respects
	are supplier's account within the quoted price and should mentioned in the price schedule.
ITT 23.12 (a)	Unit price of the Goods to be quoted on CFR (Cost and Freight) basis, as per Incoterms 2020, including C&F Agency cost, inland transportation and other local costs for the delivery of the goods to the final destination. <b>Port of Destination</b> : Chattogram Seaport and then 450 MW- South plant of APSCL, Ashuganj, Brahmanbaria-3402, Bangladesh as per direction of work-in- charge.
ITT 23.12 (d)	<ul> <li>Unit price of the Goods to be quoted on CFR (Cost and Freight) basis, as per Incoterms 2020, including C&amp;F Agency cost, inland transportation and other local costs for the delivery of the goods to the final destination.</li> <li>Port of Destination: Chattogram Seaport and then 450 MW- South plant store of APSCL &amp; thereafter designated location of 450 MW CCPP (South) plant of APSCL, Ashuganj, Brahmanbaria-3402, Bangladesh.</li> </ul>
ITT 24.3	Name of the foreign currency: US Dollar/Euro/GBP/JPY.
ITT 25.2(b)	Not Applicable.
ITT 26:1(b)	Manufacturer's authorization is: Required. Manufacturer's Authorisation Letter is required for the following <i>items listed in</i> <i>Section 6: Schedule of Requirements:</i>
ITT 26.1(C)	After sales service is: Required
ITT 27.2	The Tender validity period shall be: 120 days from the date of tender opening.

ITT 29.2	In favour of Ashuganj Power Station Company Limited (APSCL), Ashuganj, Brahmanbaria-3402, Bangladesh.	
ITT 29.3	The amount of the Tender Security shall be : as per tender notice	
ITT 30.1	Replace the text ITT 30.1	
	The Tender security in the form of a Bank Guarantee ( <b>irrevocable and unconditional</b> ) as specified in the Tender Document shall be and issued by an internationally reputable bank and shall require to be endorsed by any correspondent schedule bank located in Bangladesh, at the same format of Bank Guarantee stipulated in tender document on Taka 300/- worth non-judicial Stamp to make it enforceable.	
	Tender security issued in the form of Pay-order/Bank Draft by any schedule bank of Bangladesh is also acceptable.	
ITT 34.1	In addition to the original of the Tender, two (2) copies shall be submitted within the date and time as mentioned in the tender notice.	
	E. Submission of Tender	
ITT 35.1	Tenders shall have to be submitted in a single sealed envelope in accordance with the requirements of the Tender document including addenda (if any).	
	The <u>original and two (2) copies of the tender shall be submitted within the date and time as mentioned in the tender notice.</u>	
ITT 35.2(c)	The inner and outer envelopes shall bear the following additional identification marks: Tender Enquiry No. & Date: Brief Description of the materials: Name & Address of the Purchaser: Name & Address of the Tenderer.	
ITT 35.7	Tenderer shall <b>not</b> have the option of submitting their tender electronically.	
ITT 35.8	If Tenderers shall have the option of submitting their bids electronically, the electronic Tender submission procedures shall be: <b>Not Applicable.</b>	
ITT 36.1	For <u>Tender submission purposes</u> , the Purchaser's address is: Attention: Company Secretary of APSCL Address: Office of the Company Secretary APSCL Corporate Office Navana Rahim Ardent (Level# 8), 185, Shahid Sayed Nazrul Islam Soroni, Palton, Dhaka, Bangladesh. The deadline for submission of Tenders is: As mentioned in Tender Notice	

F. Opening and Evaluation of Tenders		
ITT 42.2	The Tender opening shall take place at: Address: <b>Office of the Company Secretary</b> APSCL Corporate Office Navana Rahim Ardent (Level# 8), 185, Shahid Sayed Nazrul Islam Soroni, Palton, Dhaka, Bangladesh. The deadline for submission of Tenders is: <b>As mentioned in Tender Notice</b>	
ITT 42.3	If electronic tender submission is permitted as sated under ITT sub-clause 34.8, the specific tender opening procedures shall be: <b>Not Applicable.</b>	
ITT 51.1	Domestic preference <i>shall</i> be a tender evaluation factor: <b>Not Applicable</b> .	
ITT 52.5	<ul> <li>The Tenderer shall have to comply with the payment terms stipulated in PCC Clause 27.1. Otherwise Tender shall be rejected</li> <li>The applicable economic factors, for the purposes of evaluation of Tenders shall be:</li> <li>(a) Adjustment for Deviations in the Delivery and Completion Schedule Not applicable.</li> <li>(<i>The Goods covered by this Tendering process are required to be delivered in accordance with, and completed within, the Delivery and Completion Schedule specified in Section 6, Schedule of Requirements. No credit will be given for earlier completion. Tenders offering late contract performance and delivery schedule beyond the date specified in Section 6, Schedule of Requirement, shall be rejected.)</i></li> <li>(b) Cost of major replacement components, mandatory spare parts, and service Not applicable.</li> </ul>	
	G. Award of Contract	
ITT 61.1	The maximum percentage by which quantities per item may be increased is 15% The maximum percentage by which quantities per item may be decreased is 15%	
ITT 63.2	The amount of Performance Security shall be Ten percent (10%) of the Contract Price.	
ITT 64.1	Replace the text: The Performance security shall be in the form of an irrevocable and unconditional Bank Guarantee as specified in the Tender Document issued by an internationally reputable bank and shall require to be endorsed by any correspondent schedule bank located in Bangladesh, at the same format of Bank Guarantee stipulated in tender document on non-judicial Stamp to make it enforceable. Performance security in the form of Pay-order/Bank Draft issued by any schedule bank of Bangladesh is also acceptable.	
ITT 70.5	The name and address of the office where complaints to the Purchaser are to be submitted is: Manager (Procurement)	
	Ashuganj Power Station Company Ltd. (APSCL) Ashuganj, Brahmanbaria-3402, Bangladesh.	
	e-mail: procurement@apscl.org.bd	

## Section 3. General Conditions of Contract

- 1. Definitions
- 1.1 The following words and expressions shall have the meaning hereby assigned to them. Boldface type is used to identify the defined term:
  - (a) **Completion Schedule** means the fulfilment of the Related Services by the Supplier in accordance with the terms and conditions set forth in the Contract;
  - (b) Contract Agreement means the Agreement entered into between the Purchaser and the Supplier, together with the Contract Documents referred to therein, including all attachments, appendices, and all documents incorporated by reference therein;
  - (c) **Contract Documents** means the documents listed in the Contract Agreement, including any amendments thereto;
  - (d) **Contract Price** means the price stated in the Notification of Award and thereafter as adjusted in accordance with the provisions of the Contract; ;
  - (e) **Day** means calendar days **Unless** otherwise specified as working days;
  - (f) Delivery means the transfer of ownership of the Goods from the Supplier to the Purchaser in accordance with the terms and conditions set forth in the Contract;
  - (g) GCC mean the General Conditions of Contract;
  - (h) Goods means raw materials, products and equipment and objects in solid, liquid or gaseous form, electricity, and related Services if the value of such Services does not exceed that of the Goods themselves ;
  - (i) **Government** means the Government of the People's Republic of Bangladesh;
  - (j) **Procuring Entity/Purchaser** means a Entity having administrative and financial powers to undertake Procurement of Goods, Works or Services using public funds, as specified in the PCC;
    - Related Services means Services linked to the supply of Goods contracts.;
  - (I) **PCC** means the Particular Conditions of Contract;
  - (m) Subcontractor means any natural person, private or government entity, or a combination of the above, to whom any part of the Goods to be supplied or execution of any part of the Related Services is subcontracted by the Supplier;
  - (n) **Supplier** means a Person under contract with a Purchaser for the supply of Goods and related Services under the Act;
  - (o) **Site** means the point(s) of delivery named in the PCC
  - (p) **Writing** means communication written by hand or machine duly signed and includes properly authenticated messages by facsimile or electronic mail.
  - (q) **Verified Report** means the report submitted by the Purchaser to the Head of the Purchaser setting forth its findings as to the existence of grounds or causes for termination and explicitly stating its recommendation for the issuance of a Notice to Terminate.



- 2. Contract Documents
- 3. Corrupt, Fraudulent, Collusive or Coercive Practices
- 2.1 Subject to the order of precedence set forth in the GCC Sub-Clause 5.1, all documents forming the Contract (and all parts thereof) are intended to be correlative, complementary, and mutually explanatory. The Contract Agreement shall be read as a whole.
- 3.1 The Government requires that Purchaser, as well as Suppliers, shall observe the highest standard of ethics during the implementation of procurement proceedings and the execution of contracts under public funds.
- 3.2 The Government requires that Procuring Entities, as well as Suppliers shall, during the execution of Contracts under public funds, ensure-
  - (a) strict compliance with the provisions of Section 64 of the Public Procurement Act 2006 (Act 24 of 2006);
  - (b) abiding by the code of ethics as mentioned in the Rule127 of the Public Procurement Rules, 2008;
  - (c) that neither it nor any other member of its staff or any other agents or intermediaries working on its behalf engages in any practice as detailed in GCC Sub -Clause 3.3
- 3.3 For the purpose of GCC Sub-clause 3.2 the terms -

(C)

- (a) corrupt practice means offering, giving or promising to give, receiving, or soliciting, either directly or indirectly, to any officer or employee of a Purchaser or other public or private authority or individual, a gratuity in any form; employment or any other thing or service of value as an inducement with respect to an act or decision or method followed by a Purchaser in connection with a Procurement proceeding or contract execution;
- (b) fraudulent practice means the misrepresentation or omission of facts in order to influence a decision to be taken in a Procurement proceeding or Contract execution;
  - **collusive practice** means a scheme or arrangement between two (2) or more Persons, with or without the knowledge of the Purchaser, that is designed to arbitrarily reduce the number of Tenders submitted or fix Tender prices at artificial, noncompetitive levels, thereby denying a Purchaser the benefits of competitive price arising from genuine and open competition; or
- (d) coercive practice means harming or threatening to harm, directly or indirectly, Persons or their property to influence a decision to be taken in a Procurement proceeding or the execution of a Contract, and this will include creating obstructions in the normal submission process used for Tenders.
- 3.4 Should any corrupt, fraudulent, collusive or coercive practice of any kind come to the knowledge of the Purchaser, it will, in the first place, allow the Supplier to provide an explanation and shall, take actions only when a satisfactory explanation is not received. Such exclusion and the reasons thereof, shall be recorded in the record of the procurement proceedings and promptly communicated to the Supplier concerned. Any communications between the Supplier and the Purchaser related to matters of alleged fraud or corruption shall be in writing.

Supply, installation, commissioning and testing of circulating water pump Motor for 450 MW South (Elect.) plant of APSCL

- 3.5 If corrupt, fraudulent, collusive or coercive practices of any kind determined by the Purchaser against the Supplier alleged to have carried out such practices, the Purchaser shall proceed under GCC Clause 42.4
- 3.6 The Supplier shall permit the Purchaser to inspect the Supplier's accounts and records and other documents relating to the submission of the Tender and Contract performance.
- **4. Interpretation 4.1** In interpreting the GCC, singular also means plural, male also means female or neuter, and the other way around. Headings in the GCC shall not be deemed part thereof or be taken into consideration in the interpretation or construction thereof or of the Contract. Words have their normal meaning under the English language unless specifically defined.
  - (a) The Contract constitutes the entire agreement between the Purchaser and the Supplier and supersedes all communications, negotiations and agreements (whether written or oral) of parties with respect thereto made prior to the date of Contract Agreement; except those stated under GCC Sub Clause 5.1(i).

#### 4.3 Amendment

(a) No amendment or other variation of the Contract shall be valid unless it is in writing, is dated, expressly refers to the Contract, and is signed by a duly authorised representative of each party thereto.

#### 4.4 Non-waiver

(a) Subject to GCC Sub-Clause 4.4(b), no relaxation, forbearance, delay, or indulgence by either party in enforcing any of the terms and conditions of the Contract or the granting of time by either party to the other shall prejudice, affect, or restrict the rights of that party under the Contract, neither shall any waiver by either party of any breach of Contract operate as waiver of any subsequent or continuing breach of Contract.

Any waiver of a party's rights, powers, or remedies under the Contract must be in writing, dated, and signed by an authorised representative of the party granting such waiver, and must specify the right and the extent to which it is being waived.

#### Severability

4.5

- (a) If any provision or condition of the Contract is prohibited or rendered invalid or unenforceable, such prohibition, invalidity or unenforceability shall not affect the validity or enforceability of any other provisions and conditions of the Contract.
- 5.1 The following documents forming the Contract shall be in the following order of precedence, namely :
  - (a) the signed Contract Agreement;
  - (b) the Notification of Award;
  - (c) The Tender and the appendices to the Tender;
  - (d) Particular Conditions of Contract;
  - (e) General Conditions of Contract;

4.2 Entire Agreement(a) The Contract constitutes the entire a and the Supplier and supersedes

5. Documents Forming the Contract in order of precedence

- (f) Technical Specifications;
- (g) Drawings;
- (h) Priced Schedule and schedule of requirements and ;
- (i) Other Documents including correspondences listed in the PCC forming part of the Contract.
- 6. Eligibility 6.1 The Supplier and its Subcontractors shall have the nationality of an eligible country. A Supplier or Subcontractor shall be deemed to have the nationality of a country if it is a citizen or constituted, incorporated, or registered, and operates in conformity with the provisions of the laws of that country.
  - 6.2 All Goods and Related Services to be supplied under the Contract shall have their origin in Eligible Countries.
  - 6.3 For the purpose of the GCC Clause 6.2, origin means the country where the goods have been grown, mined, cultivated, produced, manufactured, or processed; or through manufacture, processing, or assembly, another commercially recognized article results that differs substantially in its basic characteristics from its components.
- 7. Governing Language
  7.1 The Contract shall be written in English language. Correspondence and documents relating to the Contract exchanged by the Supplier and the Purchaser shall be written in English Supporting documents and printed literature that are part of the Contract may be in another language provided they are accompanied by an accurate translation of the relevant passages in English language, in which case, for purposes of interpretation of the Contract, this translation shall govern.
  - 7.2 The Supplier shall bear all costs of translation to the governing language and all risks of the accuracy of such translation.
- **8. Governing Law** 8.1 The Contract shall be governed by and interpreted in accordance with the laws of the People's Republic of Bangladesh.
  - 9.1 No fees, gratuities, rebates, gifts, commissions or other payments, other than those shown in the Tender or the contract, shall be given or received in connection with the procurement process or in the contract execution.
  - 10.1 The Supplier shall not, except for purposes of performing the obligations in this Contract, without the Purchaser's prior written consent, disclose this Contract, or any provision thereof, or any specification, plan, drawing, pattern, sample, or information furnished by or on behalf of the Purchaser. Any such disclosure shall be made in confidence and shall extend only as far as may be necessary for purposes of such performance.
  - 10.2 Any document, other than this Contract itself, enumerated in GCC Clause 10.1 shall remain the property of the Purchaser and shall be returned (all copies) to the Purchaser on completion of the Supplier's performance under this Contract if so required by the Purchaser.
- 11. Communications
   & Notices
   11.1 Communications between Parties (notice, request or consent required or permitted to be given or made by one party to the other) pursuant to the Contract shall be in writing to the addresses specified in the PCC.

10. Use of Contract Documents & Information

9. No fees/

Gratuities

- 11.2 A notice shall be effective when delivered or on the notice's effective date, whichever is later.
- 11.3 A Party may change its address for notice hereunder by giving the other Party notice of such change to the address.
- 12. Trademark, Patent and Intellectual Property Rights
   12.1 The Purchaser should not be liable for any infringement of intellectual property rights arising from use of the goods procured. In case there are thirdparty claims of such infringement of patent, trademark, or industrial design rights, the supplier must indemnify and hold the Purchaser free and harmless against such claims and shall not be in contravention of The Trademark Act, 2009 and The Patents and Designs Act, 1911.
- 13. Copyright
  13.1 The copyright in all drawings, documents, and other materials containing data and information furnished to the Purchaser by the Supplier herein shall remain vested in the Supplier, or, if they are furnished to the Purchaser directly or through the Supplier by any third party, including suppliers of materials, the copyright in such materials shall remain vested in such third party.
- **14. Assignment** 14.1 The Supplier shall not assign his rights or obligations under the Contract, in whole or in part, except with the Purchaser's prior written consent.
- **15. Sub-**<br/>contracting15.1Any subcontracting arrangements made during contract implementation and<br/>not disclosed at the time of the Tendering shall not be allowed.
  - 15.2 Subcontracting of any portion of the Goods shall not relieve the Tenderer from any liability or obligations that may arise from its performance.
  - 15.3 Supplier shall retain full responsibility for the contract and cannot pass any contractual obligations to the subcontractor and under no circumstances assignment of the contract to the subcontractor be allowed.
  - 15.4 Subcontractors shall comply with the provisions of GCC Clause 3 and 6.
- 16. Supplier's Responsibilities

Responsibilities

17. Purchaser's

18. Scope of

Supply

- 16.1 The Supplier shall supply all the Goods and Related Services specified in the Scope of Supply as stated under GCC Clause 18 and the Delivery and Completion schedule, as stated under GCC Clauses 23 and 24 in conformity with the provisions of the Contract Agreement.
- 17.1 Whenever the performance of the obligations in this Contract requires that the Supplier obtain permits, approvals and other license from local public authorities, the Purchaser may, if so needed by the Supplier, make its best effort to assist the Supplier in complying with such requirements in a timely and expeditious manner. However, the supplier shall bear the costs of such permits and/or licenses. On the other hand, the Purchaser shall pay all costs involved in the performance of its responsibilities, in accordance with the contract.
- 17.2 The Purchaser shall pay the Supplier, in consideration of the provision of Goods and Related Services, the Contract Price under the provisions of the Contract at the times and manner prescribed in the Contract Agreement.
- 18.1 Subject to the PCC, the Goods and Related Services to be supplied shall be as specified in Section 6: Schedule of Requirements.
  - 18.2 Unless otherwise stipulated in the Contract, the Scope of Supply shall include all such items not specifically mentioned in the Contract but that can be reasonably inferred from the Contract as being required for attaining Delivery

and Completion of the Goods and Related Services as if such items were expressly mentioned in the Contract.

- 19. Amendment to 19.1 The Purchaser may make an amendment to Order for necessary adjustment within the general scope of the contract in any one or more of the following aspects in order to fully meet the requirement of the Contract:
  - Drawing, design or specifications of the goods, provided that: (a)
    - The goods to be furnished are to be specifically manufactured for i the government in accordance therewith:
    - The change is an improvement of the goods and advantageous ii. to the Government;
    - iii. It is done at no extra cost: and
    - It is not prejudicial to the losing Tenderers in the sense that such iv. change/s could not have been foreseen during the conduct of the tendering and would have significantly affected the other tenderer's tender:
  - (b) The place of delivery;
  - The place of performance of the services (c)
  - (d) Additional items needed and necessary for the protection of the goods procured, which were not included in the original contract.
  - 19.2 Such amendment may or may not result to an increase or a decrease of the contract price, and/or an extension or reduction of the delivery period. However, the amendment should not have the result of changing the subject matter of the contract or the specifications of the goods or services, in any material aspect and to such an extent that, if introduced during the Tendering stage, may have had a significant effect on other Tenderer's tender, because this situation would actually require another tendering activity.
- 20. Instances When 20.1 Amendment to Order May be Issued

(a)

Order

- The Purchaser may issue amendments order at any time during contract implementation, through a notice as stated under GCC Clause 11, provided that such adjustment is required to fully meet the requirements of the contract. Any of the following circumstances may serve as basis for such amendment/s:
  - Emergency cases, fortuitous events or unforeseen contingencies arising during contract implementation, and such contingencies have an impact on the procurement at hand, such as:
    - i. Changes in the conditions affecting the contract, e.g., a change in the place of delivery;
    - Time is of the essence in the implementation of the contract, ii. and any changes require immediate implementation; and
    - Additional requirements have been identified as necessary for iii. the protection of the goods procured, such as changes in the packaging of the goods, or

additional items have become necessary to ensure that the goods are sufficiently protected from the elements;

- (b) When the contract does not reflect the real intention of the parties due to mistake or accident, and the amendment is necessary to reflect the party's intention; and
- (c) Other analogous circumstances that could affect the conditions of the procurement at hand
- 21. Adjustments in 21.1 **Contract Price**

If an amendment to order increases or decreases the cost of ,or the time required for executing any part of the delivery under the original contract, an

and/or Delivery Schedule in Amendment to		equitable adjustment in contract price and/or delivery schedule should be mutually agreed upon between parties concerned, and the contract should be modified as stated under GCC Clause 46
Order	21.2	If the amendment to order consists of additional items, the price adjustment shall be based on the unit price in the original contract for items of goods similar to those in the original contract. If the contract does not contain any rate applicable to the additional items, then suitable prices shall be mutually agreed upon between the parties, based on prevailing market prices.
	21.3	It is required, however, that any increase in contract price must not exceed ten percent (10%) of the original contract price.
22. Packing and Documents	22.1	The Supplier shall provide such packing of the goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the Contract and in accordance with existing industry standards. The packing shall be sufficient to withstand, without limitation, rough handling and exposure to extreme temperatures, salt and precipitation, and open storage. Packing case size and weights shall take into consideration, where appropriate, the remoteness of the goods' final destination and the absence of heavy handling facilities at all points in transit.
	22.2	The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract as stated under GCC Clause 22.1, including additional requirements, if any, specified in the PCC, and in any subsequent instructions ordered by the Purchaser.
	22.3	The outer packaging must contain a "Packing List" which must reflect the actual contents of the package.
23. Delivery and Documents	23.1	Subject to GCC Sub-Clause 19, the Delivery of the Goods and completion of the Related Services shall be in accordance with the Delivery and Completion Schedule specified in the Section 6: Schedule of Requirements.
	23.2	The details of shipping and other documents to be furnished by the Supplier shall be specified in the PCC, and shall be received by the Purchaser at least one week before arrival of the Goods and, if not received the Supplier shall be responsible for consequent expenses.
24. Acceptance	24.1	Acceptance by the Purchaser shall be completed not later than fourteen (14) days from receipt of the goods at final destination in the form of an <b>Acceptance Certificate</b> , unless any defects in the supply, any damage during transportation or any failure to meet the required performance criteria of the supply are identified and reported to the Supplier as stated under GCC Clause 31 and GCC Clause 32. In such cases the Acceptance Certificate will be issued only for those parts of the contract supplies which are accepted. The Acceptance Certificate for the remaining supplies will only be issued after the Supplier has remedied the defects and/or any non-conformity under GCC Clause 31 and GCC Clause 32.
	24.2	The appropriate Technical Inspection and Acceptance Committee of the Purchaser must commence the inspection and acceptance process within two (2) days from delivery of the goods, and shall complete the same as soon as practicable.

**25. Contract Price** 25.1 The Contract Price shall be specified in the PCC.

	25.2	During evaluation, tender has excluded and not taken into account:	
		(a) In the case of Goods manufactured in Bangladesh, VAT payable on account of Supplier, which will be payable on the goods if a contract is awarded to the Tenderer;	
		in the case of Goods manufactured outside the Bangladesh, already imported or to be imported, customs duties, import VAT and other import taxes levied on the imported Goods, VAT, which will be payable on the Goods if the contract is awarded to the Tenderer.	
	25.3	The Contract price will include all the costs paid or payable as stated under GCC Clause 25.2.	
	25.4	Prices charged by the Supplier for the Goods delivered and the Related Services performed under the Contract shall not vary from the price as stated under GCC Sub-Clause 25.1, with the exception of any change in price resulting from a Change Order issued under GCC Clause 19.	
26. Transportation	26.1	The Supplier is required under the Contract to transport the Goods to a specified place of destination as specified in Section 6: Schedule of Requirements, defined as the Site, transport to such place of destination, including insurance, other incidental costs, and temporary storage, if any. These costs shall be included in the Contract Price.	
	26.2	If not in accordance GCC Clause 26.1, responsibility for transportation of the Goods shall be as specified in the <i>INCOTERM</i> indicated in the Price Schedule or any other trade terms specify the responsibilities of the Purchaser and Supplier as specified in PCC.	
27. Terms of Payment	27.1	The Contract Price, including any Advance Payments, if applicable, shall be paid in the manner as specified in the PCC.	
	27.2	The Supplier's request for payment shall be made to the Purchaser in writing, accompanied by an invoice describing, as appropriate, the Goods delivered and Related Services performed, and accompanied by the documents as stated under GCC Clause 23 and 24 and upon fulfilment of any other obligations stipulated in the Contract.	
K	27.3	Payments shall be made promptly by the Purchaser, but in no case later than the days indicated in the PCC after submission of an invoice or request for payment by the Supplier, and after the Purchaser has accepted it.	
	27.4	The currencies in which payments shall be made to the Supplier under this Contract shall be those in which the tender price is expressed.	
	27.5	In the event that the Purchaser fails to pay the Supplier any payment by its respective due date or within the period set forth in the PCC, the Purchaser shall pay to the Supplier interest on the amount of such delayed payment at the rate shown in the PCC, for the period of delay until payment has been made in full, whether before or after judgment or arbitrage award.	
28. Insurance	28.1	The Goods supplied under this Contract shall be fully insured by the Supplier in a freely convertible currency against loss or damage incidental to manufacture or acquisition, transportation, storage, and delivery. The Goods remain at the risk and title of the Supplier until their acceptance by the Purchaser.	
	28.2	If not in accordance GCC Clause 28.1, the insurance coverage shall be as specified in the <i>INCOTERM</i> indicated in the Price Schedule or any other insurance provisions as specified in PCC.	

**29. Taxes and Duties** 29.1 For Goods Manufactured within Bangladesh, the Supplier shall be entirely responsible for all taxes, duties, VAT, license fees, and other such levies imposed or incurred until delivery of the contracted goods to the Purchaser.

30. Performance

Security

- 29.2 For Goods manufactured outside Bangladesh, the Supplier shall be entirely responsible for all taxes, duties and other such levies imposed outside Bangladesh.
- 29.3 If any tax exemptions, reductions, allowances or privileges may be available to the Supplier in Bangladesh, the Purchaser shall use its best efforts to enable the Supplier to benefit from any such tax savings to the maximum allowable extent.

30.1 The proceeds of the Performance Security shall be payable to the Purchaser as compensation for any loss resulting from the Supplier's failure to complete its obligations under the Contract.

- 30.2 The Performance Security shall be discharged by the Purchaser and returned to the Supplier not later than Thirty (30) days following the date of Completion of the Supplier's performance obligations under the Contract and the issuance of certification to that effect by the Purchaser, including any warranty obligations as stated under GCC Clause 33, provided that there are no claims field against the supplier.
- 31. Specifications and Standards
   31.1 The Goods and Related Services supplied under this Contract shall conform to the technical specifications and standards mentioned in Section 7, Technical Specification and in Section 8, Drawings, if any.
  - 31.2 If there is no applicable standard, the goods must conform to the authoritative standards appropriate to the good's country of origin. Such standards must be the latest issued by the concerned institution.
  - 31.3 Subject to the GCC Clause 19, the Supplier shall be entitled to disclaim responsibility for any design, data, drawing, specification or other document, or any modification thereof provided or designed by or on behalf of the Purchaser, by giving a notice of such disclaimer to the Purchaser.
  - 31.4 Wherever references are made in the Contract to codes and standards in accordance with which it shall be executed, the edition or the revised version of such codes and standards shall be those specified in the Technical Specification. During Contract execution, any changes in any such codes and standards shall be applied only after approval by the Purchaser and shall be treated under GCC Clause 19.
- **32. Inspections and 32.1** The Purchaser shall have the right to test the Goods to confirm their conformity to the Contract specifications. The PCC and Technical specifications shall specify what tests the Purchaser requires and where they are to be conducted. The supplier shall at its own expense and at no cost to the Purchaser, carry out all such tests of the Goods and related services as are specified in the Contract.
  - 32.2 The Supplier shall provide the Purchaser with a report of the results of any such test.
  - 32.3 The Purchaser may engage external agents for the purpose of conducting inspection or pre-shipment inspection of Goods, provided that the Purchaser shall bear all of its costs and expenses.
  - 32.4 The Purchaser or its designated representative as specified shall be entitled to attend the tests and/or inspections under GCC Clause 32.1, provided that

the Purchaser shall bear all of its own costs and expenses incurred in connection with such attendance.

- 32.5 Whenever the Supplier is ready to carry out any such test and inspection, it shall give a reasonable advance notice, including the place and time, to the Purchaser. The Supplier shall obtain from any relevant third party or manufacturer any necessary permission or consent to enable the Purchaser or its designated representative to attend the test and/or inspection.
- 32.6 The Purchaser may require the Supplier to carry out any test and/or inspection not required by the Contract, but deemed necessary to verify that the characteristics and performance of the Goods comply with the technical specifications, codes and standards under the Contract, provided that the Supplier's reasonable costs and expenses incurred in the carrying out of such test and/or inspection shall be added to the Contract Price. Further, if such test and/or inspection impede the progress of manufacturing and/or the Supplier's performance of its other obligations under the Contract, due allowance will be made in respect of the Delivery Dates and Completion Dates and the other obligations so affected.
- 32.7 The Purchaser may reject any Goods or any part thereof that fail to pass any test and/or inspection or do not conform to the specifications. The Supplier shall either rectify or replace such rejected Goods or parts thereof or make alterations necessary to meet the specifications at no cost to the Purchaser, and shall repeat the test and/or inspection, at no cost to the Purchaser, upon giving a notice under GCC Sub-Clause 32.5.
- 32.8 The Supplier agrees that neither the execution of a test and/or inspection of the Goods or any part thereof, nor the attendance by the Purchaser or its representative, nor the issue of any report as stated under GCC Sub-Clause 32.2, shall relieve the Supplier from any warranties or other obligations under the Contract.
- 33.1 The Supplier warrants that all the Goods supplied under the Contract are new, unused, and of the most recent or current models, and that they incorporate all recent improvements in design and materials, except when the design and/or material required by the Purchaser provides otherwise under GCC Clause 19.
- 33.2 The Supplier further warrants that the all Goods supplied under this Contract shall have no defect, arising from design, materials, or workmanship or from any act or omission of the Supplier that may develop under normal use of the supplied Goods in the conditions prevailing in Bangladesh.
- 33.3 In order to assure that manufacturing defects shall be corrected by the Supplier, manufacturer, or distributor, as the case may be, a warranty shall be required from the Supplier for a minimum period of three (3) months in the case of supplies, and one (1) year in the case of equipment, or other such period as may be specified in the PCC, after the Goods, or any portion thereof as the case may be, have been delivered to and accepted in the form of an **Acceptance Certificate** as indicated in the GCC Clause 24.1 at the final destination indicated in the PCC
- 33.4 The warranty periods may vary among the various items and lots. The warranty for Goods delivered ahead will lapse earlier than the succeeding deliveries.
- 33.5 The Purchaser shall promptly notify the Supplier in writing of any claims arising under this warranty.

33. Warranty

- 33.6 Upon receipt of such notice, the Supplier shall, within the period specified in the PCC, expeditiously repair or replace the defective Goods or parts thereof, at no cost to the Purchaser.
- 33.7 If the Supplier, having been notified, fails to remedy the defect(s) within the period as stated under GCC Sub Clause 33.6, the Purchaser may proceed to call upon the Performance security without prejudice to any other rights which the Purchaser may have against the Supplier under the Contract and under the applicable law.
- 33.8 Performance Security under GCC Clause no 30 shall only be released after the lapse of the warranty period, provided that the goods supplied are free from patent and latent defects and all the conditions imposed under the contract have been fully met.
  - (a) A patent defect, which is one that is apparent to the buyer on normal observation. It is an apparent or obvious defect.
    - i. For example, a ball pen that does not write is patently defective.
  - (b) A latent defect, which is one that is not apparent to the buyer by reasonable observation. A latent defect is "hidden" or one that is not immediately determinable.
    - i. For example, a ball pen that writes .75 kilometers instead of the expected 1.5 kilometers, has a latent defect.
- 34. Delays in Delivery and Extensions of Time

35. Liquidated

Damages

- 34.1 The Supplier must deliver the Goods or perform the services procured within the period prescribed by the Purchaser, as specified in the Contract.
- 34.2 If at any time during performance of the Contract, the Supplier or its subcontractors should encounter conditions impeding timely delivery of the Goods or completion of Related Services as stated under GCC Clause 23, the Supplier shall promptly notify the Purchaser in writing. It must state therein the cause/s and duration of the expected delay. The Purchaser shall decide whether and by how much to extend the time. In all cases, the request for extension should be submitted before the lapse of the original delivery date.
  - 4.3 Within twenty-one (21) days of receipt of the Supplier's notice, the Purchaser shall evaluate the situation and may grant time extensions, if based on justifiable grounds, without liquidated damages.
- 34.4 The Procuring may extend up to twenty percent (20%) of the original contract time, above 20% of the original contract time approval of Head of Purchaser (HOPE) shall be required, in which case the extension shall be ratified by the Parties by amendment of the Contract as stated under GCC Clause 46.
- 34.5 Except in the case of Force Majeure, as provided under GCC Clause 38, a delay by the Supplier in the performance of its Delivery and Completion obligations shall render the Supplier liable to the imposition of liquidated damages as stated under GCC Clause 35, unless an extension of time is agreed upon, under GCC Sub-Clause 34.3.
- 35.1 Subject to GCC Clause 34 and 38, if the , if the Supplier fails to deliver any or all of the Goods by the Date(s) of delivery and/or perform the Related Services within the period specified in the Contract as stated under GCC Clause 23, the Purchaser shall, without prejudice to all its other remedies under the Contract, deduct from the Contract Price, as liquidated damages, a sum equivalent to the percentage specified in the PCC of the Contract price of the delayed Goods or unperformed / Related Services for each week or part thereof of delay until actual delivery or performance, up to a maximum

Supply, installation, commissioning and testing of circulating water pump Motor for 450 MW South (Elect.) plant of APSCL

deduction of the percentage specified in those PCC. Once the maximum is reached, the Purchaser may terminate the Contract as stated under GCC Clause 42.

- 36. Limitation of Liability
  36.1 Except in cases of criminal negligence or wilful misconduct, and in the case of infringement of patent and intellectual property rights, if applicable, the Supplier shall not be liable to the Purchaser, whether in contract, tort, or otherwise, for any indirect or consequential loss or damage, loss of use, loss of production, or loss of profits or interest costs, the aggregate liability of the Supplier to the Purchaser shall not exceed the total Contract Price, provided that this limitation shall not apply, to the cost of repairing or replacing defective equipment or, to any obligation of the Supplier to pay liquidated damages to the Purchaser.
- 37. Change in Laws and Regulations
  37.1 Unless otherwise specified in the Contract, if after the Contract, any law, regulation, ordinance, order or bylaw having the force of law is enacted, promulgated, abrogated, or changed in Bangladesh (which shall be deemed to include any change in interpretation or application by the competent authorities) that subsequently affects the Delivery Date and/or the Contract Price, then such Delivery Date and/or Contract Price shall be correspondingly increased or decreased, to the extent that the Supplier has thereby been affected in the performance of any of its obligations under the Contract.
- **38. Definition of** 38.1 In this Clause, "Force Majeure" means an exceptional event or circumstance:
  - (a) which is beyond a Party's control;

**Force Maieure** 

- (b) which such Party could not reasonably have provided against before entering into the Contract;
- (c) which, having arisen, such Party could not reasonably have avoided or overcome; and
- (d) which is not substantially attributable to the other Party.
- 38.2 Force Majeure may include, but is not limited to, exceptional events or circumstances of the kind listed below, so long as conditions (a) to (d) above are satisfied:
  - i) war, hostilities (whether war be declared or not), invasion, act of foreign enemies;
    - rebellion, terrorism, sabotage by persons other than the Contractor's Personnel, revolution, insurrection, military or usurped power, or civil war;
  - (iii) riot, commotion, disorder, strike or lockout by persons other than the Contractor's Personnel;
  - (iv) munitions of war, explosive materials, ionising radiation or contamination by radio-activity, except as may be attributable to the Contractor's use of such munitions, explosives, radiation or radioactivity, and
  - (v) natural catastrophes such as cyclone, hurricane, typhoon, tsunami, storm surge, floods, earthquake , landslides, fires, epidemics, quarantine restrictions, or volcanic activity;
  - (vi) freight embargoes;

(ii)

- (vii) acts of the Government in its sovereign capacity.
- 39. Notice of Force Majeure
   39.1 If a Party is or will be prevented from performing its substantial obligations under the Contract by Force Majeure, then it shall give notice to the other Party of the event or circumstances constituting the Force Majeure and shall specify the obligations, the performance of which is or will be prevented. The

notice shall be given within 14 days after the Party became aware, or should have become aware, of the relevant event or circumstance constituting Force Majeure.

- 39.2 The Party shall, having given notice, be excused performance of its obligations for so long as such Force Majeure prevents it from performing them.
- 39.3 Notwithstanding any other provision of this Clause, Force Majeure shall not apply to obligations of either Party to make payments to the other Party under the Contract.
- **40. Duty to Minimize Delay 40.1** Each Party shall at all times use all reasonable endeavours to minimise any delay in the performance of the Contract as a result of Force Majeure.
  - 40.2 A Party shall give notice to the other Party when it ceases to be affected by the Force Majeure.


41. Consequences of Force Majeure

- of 41.1 The Supplier shall not be liable for forfeiture of its Performance Security, liquidated damages, or termination for default if and to the extent that it's delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.
  - 41.2 The Purchaser may suspend the delivery or contract implementation, wholly or partly, by written order for a certain period of time, as it deems necessary due to force majeure as defined in the contract.
  - 41.3 Delivery made either upon the lifting or the expiration of the suspension order. However, if the Purchaser terminates the contract as stated under GCC clause 42, resumption of delivery cannot be done.
  - 41.4 Head of Purchaser determines the existence of a force majeure that will be basis of the issuance of suspension of order.
  - 41.5 Adjustments in the delivery or contract schedule and/or contract price, including any need to modify contract under GCC Clause 46.

42.1 The Purchaser shall terminate this Contract for default when any of the following conditions attends its implementation:

- (a) Outside of force majeure, the Supplier fails to deliver or perform any or all of the GOODS within the period(s) specified in the contract, or within any extension thereof granted by the Purchaser pursuant to a request made by the Supplier prior to the delay;
- (b) As a result of force majeure, the Supplier is unable to deliver or perform any or all of the GOODS, amounting to at least ten percent (10%) of the contract price, for a period of not less than sixty (60) calendar days after receipt of the notice from the Purchaser stating that the circumstance of force majeure is deemed to have ceased; or
- (c) The Supplier fails to perform any other obligation under the Contract;
- (d) If the Supplier, in the judgment of the Purchaser has engaged in corrupt, fraudulent, collusive or coercive practices, as stated under GCC Clause 3, in competing for or in executing the Contract;
- (e) When deductible amount due to liquidated damage reaches its maximum as stated under GCC Clause 35.

42. Termination for Default



- 42.2 Termination of a contract for default is without prejudice to other remedies available to the Purchaser for breach of contract, such as payment of liquidated and other damages, if there are grounds for the latter.
- 42.3 In the event the Purchaser terminates the Contract in whole or in part, as stated under GCC Clause 42.1, the Purchaser may procure, upon such terms and in such manner as it deems appropriate, Goods or Related Services similar to those undelivered or not performed, and the Supplier shall be liable to the Purchaser for any additional costs for such similar Goods or Related Services. However, the Supplier shall continue performance of the Contract to the extent not terminated.
- 42.4 In the event as stated under GCC Clause 42.1(d), the Purchaser shall,
  - (a) terminate the Supplier's employment under the Contract and cancel the contract, after giving 14 days notice to the Supplier and the provisions of Clause 42 shall apply as if such expulsion had been made under Sub-Clause 42.1
  - (b) declare, at its discretion, the concerned Person to be ineligible to participate in further Procurement proceedings, either indefinitely or for a specific period of time.
- 43. Termination for insolvency43.1 The Purchaser shall terminate this Contract if the Supplier is declared bankrupt or insolvent as determined with finality by a court of competent jurisdiction. In this event, termination will be without compensation to the Supplier, provided that such termination will not prejudice or affect any right of action or remedy which has accrued or will accrue thereafter to the Purchaser and/or the Supplier.
- 44. Termination for Convenience44.1 The Purchaser, by written notice sent to the supplier, may terminate this Contract, in whole or in part, at any time for its convenience. The notice of termination shall specify that the termination is for the Purchaser's convenience, the extent to which performance of the supplier under the contract is terminated, and the date upon which such termination becomes effective.
  - 44.2 Any of the following circumstances may constitute sufficient grounds to terminate a contract for conveniences :
    - (a) If Physical and economic conditions have significantly changed so as to render the contract no longer economically, financially or technically feasible, as determined by the Head of Purchaser;
    - (b) The Head of Purchaser has determined the existences of conditions that make contract implementation impractical and/or unnecessary, such as, but not limited to , fortuitous event/s, change in laws and government policies;
    - (c) Funding for the contract has been withheld or reduced;
    - (d) Any circumstances analogous to the foregoing.
  - 44.3 The GOODS that have been delivered and/or performed or are ready for delivery or performance within thirty (30) calendar days after the Supplier's receipt of Notice to Terminate shall be accepted by the Purchaser at the contract terms and prices. For GOODS not yet performed and/or ready for delivery, the Purchaser may elect:
    - (a) to have any portion delivered and/or performed and paid at the contract terms and prices; and/or
    - (b) to cancel the remainder and pay to the Supplier an agreed amount for partially completed and/or performed goods and for materials and parts previously procured by the Supplier.

- 45. Procedures for Termination of Contracts
- 45.1 The following provisions shall govern the procedures for termination of this Contract as stated under GCC Clauses 42,43 and 44:
  - (a) Upon receipt of a written report of acts or causes which may constitute ground(s) for termination as aforementioned, or upon its own initiative, the Purchaser shall, within a period of seven (7) calendar days, verify the existence of such ground(s) and cause the execution of a Verified Report, with all relevant evidence attached;
  - (b) Upon recommendation by the Purchaser, the Head of the Purchaser shall terminate this Contract only by a written notice to the Supplier conveying the termination of this Contract. The notice shall state:
    - i. that this Contract is being terminated for any of the ground(s) afore-mentioned, and a statement of the acts that constitute the ground(s) constituting the same;
    - ii. the extent of termination, whether in whole or in part;
    - iii. an instruction to the Supplier to show cause as to why this Contract should not be terminated; and
    - iv. special instructions of the Purchaser, if any.
  - (c) The Notice to Terminate shall be accompanied by a copy of the Verified Report;
  - (d) Within a period of seven (7) calendar days from receipt of the Notice of Termination, the Supplier shall submit to the Head of the Purchaser a verified position paper stating why this Contract should not be terminated. If the Supplier fails to show cause after the lapse of the seven (7) day period, either by inaction or by default, the Head of the Purchaser shall issue an order terminating this Contract;
  - (e) The Purchaser may, at any time before receipt of the Supplier's verified position paper, withdraw the Notice to Terminate if it is determined that certain items or works subject of the notice had been completed, delivered, or performed before the Supplier's receipt of the notice;

Within a non-extendible period of ten (10) calendar days from receipt of the verified position paper, the Head of the Purchaser shall decide whether or not to terminate this Contract. It shall serve a written notice to the Supplier of its decision and, unless otherwise provided, this Contract is deemed terminated from receipt of the Supplier of the notice of decision. The termination shall only be based on the ground(s) stated in the Notice to Terminate; and

(g) The Head of the Purchaser may create a Contract Termination Review Committee (CTRC) to assist him in the discharge of this function. All decisions recommended by the CTRC shall be subject to the approval of the Head of the Purchaser.

- 46. Contract Amendment
- 46.1 Subject to applicable laws, no variation in or modification of the terms of this Contract shall be made except by written amendment signed by the parties.
- 46.2 The Purchaser, in accordance with their Delegation of Financial Powers, as required, may amend the Contract to reflect the changes introduced to the Original terms and Conditions of the Contract.

Supply, installation, commissioning and testing of circulating water pump Motor for 450 MW South (Elect.) plant of APSCL

47. Settlement of Disputes

#### 47.1 Amicable Settlement:

(a) The Purchaser and the Supplier shall use their best efforts to settle amicably all disputes arising out of or in connection with this Contract or its interpretation.

#### 47.2 Adjudication

- (a) If the Supplier /Purchaser believe that amicable settlement of dispute is not possible between the two parties, the dispute shall be referred to the Adjudicator within fourteen (14) days of first written correspondence on the matter of disagreement;
- (b) The Adjudicator named in the PCC is jointly appointed by the parties. In case of disagreement between the parties, the Appointing Authority designated in the PCC shall appoint the Adjudicator within fourteen (14) days of receipt of a request from either party;
- (c) The Adjudicator shall give its decision in writing to both parties within twenty-eight (28) days of a dispute being referred to it;
- (d) The supplier shall make all payments (fees and reimbursable expenses) to the Adjudicator, and the Purchaser shall reimburse half of these fees through the regular progress payments;
- (e) Should the Adjudicator resign or die, or should the Purchaser and the Supplier agree that the Adjudicator is not functioning in accordance with the provisions of the Contract; a new Adjudicator will be jointly appointed by the Purchaser and the Supplier. In case of disagreement between the Purchaser and the Supplier the Adjudicator shall be designated by the Appointing Authority designated in the PCC at the request of either party, within fourteen (14) days\_of receipt of a request from either party.

#### 47.3 Arbitration

- (a) If the Parties are unable to reach a settlement under GCC Clause
   47.1(a) within twenty-eight (28) days of the first written correspondence on the matter of disagreement, then either Party may give notice to the other party of its intention to commence arbitration in accordance with GCC Sub-Clause 47.3(b);
- (b) The arbitration shall be conducted in accordance with the rules of procedure specified in the PCC.

# Section 4. Particular Conditions of Contract

GCC Clause	Amendments of, and Supplements to, Clauses in the General Conditions of Contract	
GCC 1.1(j)	The Purchaser is: Ashuganj Power Station Company Ltd. (APSCL)	
	Manager (Procurement)	
	Ashuganj Power Station Company Ltd. (APSCL)	
	Ashuganj, Brahmanbaria-3402, Bangladesh. The Consignee:	
	Ashuganj Power Station Company Ltd. (APSCL), Ashuganj, Brahmanbaria-3402, Bangladesh.	
	Engineer:	
	Executive Engineer (Electrical Maintenance), Ashuganj 450MW CCPP (South) Plant, APSCL, Ashuganj, Brahmanbaria -3402, Bangladesh.	
GCC 1.1(o)	The site(s)/ point(s) of delivery is/are: APSCL's Store, Ashuganj, Brahmanbaria- 3402, Bangladesh	
GCC 1.1(r)	PAC: Provisional Acceptance Certificate	
GCC 5.1(i)	The following documents shall also be part of the Contract:	
	Proposal (Offer) of the Contractor.	
GCC 11.1	For notices, the Purchaser's contact details shall be:	
	Attention: Manager (Procurement)	
	Address:	
	Ashuganj Power Station Company Ltd. (APSCL),	
	Ashuganj, Brahmanbaria-3402, Bangladesh	
	Telephone: +880 8528 74033	
	Facsimile number: +880 8528 74044	
	Electronic mail : procurement@apscl.org.bd	
	For notices, the Supplier's contact details shall be:	
	Attention:	
	Address:	
	Telephone:	
	Facsimile number:	
	Electronic mail address:	
GCC 18.1	The scope of Supply shall be defined in: As specified in section 6, Schedule of Requirements.	

GCC 22.2	The packing, marking and documentation within and outside the packages shall be:			
	A complete packing list indicating the content of each package shall be enclosed in a water proof envelope and shall be secured to the outside of the packing case. In addition, each package shall be marked with indelible ink/paint in bold letters, as follows:			
	a. Contract Number			
	b. Name and address of Purchaser			
	c. Country of origin			
	d. Gross weight			
	e. Net weight			
	f. Package number of total number of packages			
	g. Brief description of the content			
	Upright markings, where appropriate, shall be placed on all four vertical sides of the package.			
	All materials used for packing shall be environmentally neutral.			
	Additional marking and documentation within and outside the packages shall be:			
	Arrow/Umbrella/Cup etc. shall be printed on the box to indicate upside of the box.			
	The Supplier must have to submit the following:			
	i.The FAT report along with the manual and necessary wiring diagram regarding the motor. The FAT must be completed in presence of three (03) engineers from APSCL at the manufacturing factory of the motor.			
	ii.Minimum 4 (Four) copies of original colour printed Manual and O&M Manual as well as softcopy has to be provided through 04 (Four) pen drives by supplier. The O&M manual must include the clear cross-sectional drawing with bill of materials, proper assembly disassembly procedure, troubleshooting procedure, interconnecting pipe line diagram, Functional diagram, set point list, equipment and instrumentation list with part number, E&IC circuit diagram, interlock-logic- control and protection diagram etc. of the Circulating Water Pump Motor set.			
	Q & M manual as stated in Technical Specification should provide with goods.			
	Complete catalogue, drawing, instruction manual & trouble shooting guide with spare parts list.			
GCC 23.1	No goods will be shipped without FAT / Third party inspection. The goods will be shipped only after prior instruction from the Purchaser.			
$\overline{}$	snipped only after prior instruction from the Purchaser.			

		1		
GCC 23.2	Details of shipping and documents to be furnished by the Supplier shall be:			
	For Goods supplied from abroad			
	Upon shipment, the supplier shall notify the purchaser and the Insurance Company by telex or e-mail the full details of the shipment including purchase Order No. / Contract Number, description of Goods, quantity, the vessel, the bill of lading number, shipment date, Port of loading, date of arrival, port of discharges, etc. The supplier shall mail the following documents to the Purchaser, with a copy to the Insurance Company.			
	<ul> <li>(i) Copies of the supplier's invoice showing goods diprice, total amount.</li> <li>(ii) Original and three (3) copies of the negotiable clear marked freight prepaid and three(3) copies of non-net (iii) Copies of packing list identifying contents of each pacity.</li> <li>(iv) Manufacturer's guarantee certificate stating quality, of goods.</li> <li>(v) Certificate of Origin issued by the Chamber manufacturing country.</li> <li>(vi) Freight memo.</li> </ul>	n, on board bill of lading egotiable bill of lading: ickage. juantity and genuineness		
	(vii) Factory Test Certificate from Manufacturer. (viii) FAT Clearance or Third-party clearance certificate.			
	The Supplier shall ensure that the documents to be discrepancy within 07 (Seven) days before arrival of good of Bangladesh. In case of any discrepancy in the docum responsible for any consequent expenses, such as a additional demurrage at port owing to delayed cleara negotiable sets of documents shall be original signed negotiable sets of documents shall be original, signed by The commercial invoice is to show material values plus for	Is at Chattogram seaport ent, the supplier shall be dditional bank charges, ince of goods etc. The by the contractor. The the Contractor/ Supplier.		
	SHIPPING DOCUMENTS:			
	The shipping documents described above shall be receive one week before arrival of cargoes at the port of destinat	-		
	The number of shipping documents shall be supplied to a	as follows:		
	1. Managing Director, APSCL (md@apscl.org.bd)	-1 set		
	2. Dy. General Manager (Finance & Accounts), APSCL (dgmfin@apscl.org.bd)	-1 set		
$\sim$	<ol> <li>Manager (Procurement), APSCL (procurement@apscl.org.bd)</li> </ol>	-1 set		
<b>Y</b>	For Goods from within the Purchaser's country: Not App	licable.		
GCC 24.2	Upon receipt of the goods constituting a lot or part of lot a of requirements, at the designated 450 MW South plant Si installation, commissioning, testing and post-landing ins Consignee will issue the Receipt & Inspection (R&I) certificate on the basis of satisfactory test result and cont	tore, and after successful pections, the Purchaser/ Report and Acceptance		
	It is noteworthy that after continuous running of the Moto certificate and R&I will be issued.	r at full load, Acceptance		

	The issuance of Acceptance Certificate shall in no way relieve the Contractor/ Supplier of his responsibility for the satisfactory operation/ utilization of the Goods in terms of the Specification and as per Warranty.	
GCC 25.1	The Contract price is:	
GCC 25.3	For Goods manufactured outside Bangladesh and to be imported, customs duties, import VAT and other import taxes levied on the imported Goods will be paid by APSCL. Hence contract price will not include these costs.	
GCC 26.2	Responsibility of the Purchaser and Supplier is: Marine insurance as well as Local Insurance cost shall be paid by APSCL. The tenderer is requested not to include this cost at their quoted price.	
GCC 27.1	(a) Payment of foreign currency (FC) shall be made through an irrevocable letter of credit opened in favour of the Supplier in a scheduled bank of Bangladesh.	
	(b) Payment of Bangladeshi taka shall be made direct through accounts office of the purchaser through Cheque.	
	1.(a) Payment for Goods & Spares manufactured outside Bangladesh and to be imported:	
	(i) Advance Payment: <b>Not permitted</b>	
	<ul> <li>(ii) Eighty (80) percent payment of the Goods shipped shall be paid through irrevocable letter of credit opened in favour of the Supplier in a bank in its country, upon submission of documents of original clean shipping document specified in GCC Clause 23.2 to the negotiating bank and issuance of payment advice by the Competent Authority.</li> </ul>	
	(iii) Twenty (20) percent payment of the goods received shall be paid after successfully completion of installation, commissioning & testing of the CWP Motor upon submission of bill supported by R&I report and Acceptance certificate duly issued by the competent authority of APSCL.	
	(iv) Hundred (100) percent for installation, commissioning & testing services shall be paid after successfully completion of the installation, testing & commissioning of the CWP Motor supported with Acceptance certificate duly issued by the competent authority of APSCL.	
Y	2. Payment for Goods manufactured outside Bangladesh & already imported and for Goods manufactured in Bangladesh: - Not Applicable	
	<ul> <li>(i) Advance Payment: <i>Not Permitted</i></li> <li>(ii) On Delivery and Acceptance: Not Applicable.</li> </ul>	
	3. Inland Transportation and other local costs for delivery for Goods manufactured outside Bangladesh and to be imported:	

	<ul> <li>a) 100% (Hundred percent) Inland Transportation and other local costs for delivery shall be paid against claim bill submitted in triplicate duly certified by Consignee, supported by R&amp;I report and Acceptance Certificate after successful commissioning and testing of the CWP Motor at 450 MW South plant of APSCL.</li> <li>The Tenderer must comply payment terms as stated above.</li> <li>BANKING CHARGES:</li> <li>a) Letter of Credit opening and other charges including amendment charges within Bangladesh shall be borne by APSCL and those outside Bangladesh shall be borne by the supplier.</li> <li>b) The supplier shall have to bear all such charges both inside and outside Bangladesh in case of extension of L/C if done at the request of the supplier.</li> </ul>
GCC 27.3	Payments shall be made promptly by the Purchaser after submission of an invoice or request for payment by the Supplier and after the Purchaser has accepted it.
GCC 27.5	Interest for payment-delay period is not allowed.
GCC 28.2	The Contractor / supplier shall secure and maintain throughout the duration of the contract insurance of such types and in such amounts as may be necessary to protect himself and the interest of APSCL/ Purchaser against hazards of risk or loss at APSCL's cost.
	Failure of the Contractor/ supplier to maintain such coverage shall not relieve him of any contractual responsibility or obligations for transportation and ocean cargo insurance from port of loading to port of unloading and from warehouse to warehouse in Bangladesh. As Marine insurance as well as Local Insurance shall be paid by APSCL/Purchaser from M/S. Sadharan Bima Corporation, 139, Motijheel Commercial Area, Dhaka, Bangladesh. The supplier shall promptly furnish 2(two) sets of shipping documents i.e. copies of Bill of Lading / Air way Bill, invoice, Packing list etc. of each and every consignment for insurance purpose directly to the Deputy General Manager (Finance & Accounts), APSCL, Ashuganj, Brahmanbaria-3402, Bangladesh indicating the Purchase order/ contract No. and date insurance cover note (open Policy) number, Bill of lading and invoice No. and date, invoice CFR value, name of Port loading and unloading, name of goods with number of cases/ packages name of vessel with present age, flag of vessel and type of cargo, well ahead or immediately after shipment to the Consignee for payment of insurance charge by APSCL.
	If the Contractor /supplier fails to comply with these instructions they shall be held fully responsible for any loss or damage arising out of the non-compliance of these contract conditions.
$\overline{\mathbf{n}}$	Shipment of goods in any chartered vessel over 15(fifteen) years of age and shipment of goods in the Deck are prohibited.
GCC 29.2	a) Bangladesh Income tax and VAT for Income Earned in Bangladesh The Supplier shall be entirely liable to pay all Income Tax, VAT and all other taxes of similar nature earned in Bangladesh arising out of this contract for both foreign currency (if any other than CFR Value) & Local currency portion [i.e except CFR value] of the Contract Price at the prevailing rule of the Government (at the date of Tender Submission) which shall be deducted at source during payment of bills for onward deposition of the same into Government Treasury. At the date of payment if there is any increase or decrease in rate of Income tax, VAT and other taxes, APSCL will pay or receive respectively the balance amount.

	But for payment through Local L/C, Supplier shall be entirely responsible to pay all Income Tax and other taxes (if any) as per existing laws/rules of Bangladesh Government and these will be deducted at source.
	<b>b) Import related duties, taxes, VAT, levies</b> APSCL will be responsible for the payment of import related duties, taxes, VAT, levies and all sort of charges etc. to be liable by the port as well as other Govt. agencies inside Bangladesh for the goods to be imported in accordance with the specification. But APSCL shall not pay the custom duty on any replacement/ additional items.
GCC 32.1	The Training and Factory Acceptance Test shall be:
	i) Training and Factory Acceptance Test:
	The Purchaser or its authorized representative (3 engineers) shall attend for training at Motor manufacturing factory and Factory Acceptance test of the Motor to confirm that the arrangements, size, position, capacity etc. of the Motor is same as the CWP Motor installed at 450 MW CCPP South plant of APSCL. The cost of performing all tests shall be borne by the Supplier.
	The payment for Training, FAT and tests at the manufacturer's premises also includes Travel cost (7 days including travelling time), airfare cost (round trip), accommodation/hotel cost (at least three-star quality), local transportation cost and food cost. for each participant and daily allowances for seven (07) days. The cost of subsequent inspection(s) due to rejection/additional re-testing of Goods at the first inspection shall also be borne by the Supplier.
	(ii) Third Party Inspection:
	For any reason, if Purchaser's/ Employer's representative (s) cannot attend above mentioned Training and Factory Acceptance Test, a Third-Party Inspection Company/Agency shall conduct/ witness Pre-shipment Inspections as well as Factory Acceptance Tests as per Contract and relevant standard at the manufacturer's Premises with the concurrence of APSCL. The Third-Party Inspector shall submit a comprehensive report to Purchaser with recommendation accompanied with photograph and video clips with date and time of the Equipment/Materials/ Goods inspected within 7 days after completion of respective inspection / Test. After approval of Third-Party Inspection report by APSCL, shipping advice shall be issued to Supplier. No Equipment / Materials / Goods shall be shipped without shipping advice.
	The inspections/Tests shall be performed on as-needed basis as per schedule provided by the respective manufacturers.
	The Supplier / Contractor/ Manufacturer shall not claim any additional cost for Third Party Inspection.
	The third-party inspection company/agency must not be involved in design, procurement, fabrication, construction and installation under this Contract.
	The Contractor/Supplier shall propose any of the following an ASME accredited/authorized inspection companies/agencies as Third-Party Inspector:
	1. BUREAU VERITAS,
	2. SGS,
	3. Black and Veatch,
	4. TUV SUD,
	5. Lloyd Inspection Agency,

	6. Mott MacDonald,
	7. Intertek group,
	8. Any other internationally ASME accredited, independent & reputed inspection
	company/Agency with global presence and must have minimum 05 years of
	experience as Third-Party Inspection Company/Agency and related activities in
	the major Engineering Industries. In addition, Inspection Company/ Agency must
	be a member of the International Federation of Inspection Agency (IFIA), must
	have valid accreditation certificate for ISO 9001 and ISO/IEC 17020 and
	experience in successful completion of the similar test activities for relevant item.
	With the approval of APSCL, the Contractor/Supplier shall engage ASME
	accredited/authorized Third Party Inspection Company/ agency. APSCL reserves
	the right to revise above mentioned list.
	Third party inspection is applicable for Equipment/Materials/Goods manufactured in outside Bangladesh.
	Post Landing Inspection:
	The Post Landing Inspection shall be intimated to the representative of contractor/ supplier. The program of such inspection shall be intimated to the representative of contractor/ supplier by APSCL upon arrival of the goods at final destination i.e. Ashuganj 450MW CCPP (South) plant of APSCL.
	(a) The Purchaser has right to inspect, test and where necessary, reject the Goods arrival in the purchaser's store shall in no way be limited or waived by reason of the Goods having previously been tested and passed by the manufacturer/supplier.
	(b) Nothing in this clause shall in any way release the supplier from any warranty or other obligation under the provisions of the contract/purchase order.
GCC 32.3	The Purchaser may engage external agents for the purpose of conducting inspection or pre-shipment inspection of Goods, provided that the Supplier shall bear all of its costs and expenses.
GCC 32.4	The Purchaser or its designated representative as specified shall be entitled to attend the tests and/or inspections under GCC Clause 32.1, provided that the Supplier shall bear all costs and expenses incurred in connection with such attendance including, but not limited to, all traveling and board and lodging expenses.
	The Supplier would not be relieved from its responsibility/ liability of making appropriate plant and material as per specification despite inspection by the Purchaser or its designated representative.
GCC 33.3	The period of validity of the Warranty shall be: 01 (one) year from the date of issuance of Acceptance Certificate. Acceptance Certificate will be issued after continuous operation of motor at 450 MW-South plant with full load for minimum three (3) days.
	In case of any mismatch of materials detected within the warranty period the supplier shall take back the mismatched items at their own cost and replace the same with appropriate spares without claim of additional cost to the purchaser within 15 days from the date of notification from the purchaser.


r	
	For purpose of the Warranty, the place of final destination(s) shall be: Ashuganj 450MW CCPP (South) Store of APSCL and thereafter designated site of 450MW CCPP (South) plant premises of APSCL, Ashuganj, Brahmanbaria-3402, and Bangladesh.
GCC 33.6	Upon receipt of such notice, the supplier shall, within the period of 15 days repair or replace the defective goods or parts thereof, without cost to the Purchaser including delivery to APSCL's store complete in all respects.
	The warranty period for the replaced equipment / parts/ goods of the supply shall be counted from the date of such replacement/ delivery to stores and shall be extended by the supplier by a period of 12 months and the performance guarantee shall be extended accordingly.
GCC 35.1	It is understood and agreed that time is of the essence in this contract. If the Contractor/Supplier fails to complete the supply and related services included in this contract within the period of time stipulated herein, the Contractor/Supplier shall pay damages for such delay. The amount of liquidated damages shall be assessed @ 0.1% (zero point one) percent per day of the contract price.
	It is noteworthy that in case of prolonged execution of related services which interrupts/affects the usage of supplied goods (though goods are supplied within stipulated time), Liquidated damage shall be applied on total contract price (price of both supply and related services) up to the date of completion of related services. APSCL shall have the right to deduct the liquidated damages from any money in its hands or otherwise due or to become due, to the contractor/supplier.
	The maximum amount of liquidated damages shall be: Ten (10%) percent of the Contract Price.
GCC 47.2(b)	The name of the Adjudicator: Will be selected as and when necessary.
	Adjudicator Appointing Authority: President of the Institution of Engineers, Bangladesh.
GCC 47.3(b)	Any dispute, controversy or claim arising out of or relating to this Contract, or breach, termination or invalidity thereof shall be settled by arbitration in accordance with the Arbitration Act (Act No 1 of 2001) of Bangladesh as at present in force.
	Arbitration shall take place in Dhaka, Bangladesh.
$\overline{\mathbf{r}}$	

## Section 5. Tender and Contract Forms

Form	Title
	Tender Forms
PG4 – 1	Tender Submission Letter
PG4 – 2	Tenderer Information Sheet
PG4 – 3A,3B & 3C	Price Schedule for Goods
PG4 – 3D	Price Schedule for Related Services
PG4 – 4	Specifications Submission and Compliance Sheet
PG4 – 5	Manufacturer's Authorisation & Warranty/Guarantee Letter
PG4 – 6	Bank Guarantee for Tender Security
PG4 – 11	Deviation list
	Contract Forms
PG4 – 7	Notification of Award
PG4 – 8	Contract Agreement
PG4 – 9	Bank Guarantee for Performance Security
PG4 – 10	Bank Guarantee for Advance Payment

Forms PG4-1 to PG4-6 and PG4-11 comprises part of the Tender and should be completed as stated in ITT Clause 21.

Forms PG4-7 to PG4-10 comprises part of the Contract as stated in GCC Clause 5.



### Tender Submission Letter (Form PG4 – 1)

[This letter shall be completed and signed by the <u>Authorized Signatory</u> preferably on the Letter-Head pad of the Tenderer].

То:	Date:
Manager (Procurement)	
Ashuganj Power Station Company Ltd.	
Ashuganj, Brahmanbaria-3402, Banglade	sh
Invitation for Tender No:	[indicate IFT No]
Tender Package No:	[indicate Package Not
Lot No:	[indicate number of Lots]
We, the undersigned, offer to supply in c Goods and related Services:	onformity with the Tender Document the following
In accordance with ITT Clauses 22 and 2 Tender:	23, the following prices and discounts apply to our
The Tender Price is:	USD/ Freely convertible international currency
(ITT Sub-Clause 23.1)	and Taka [state currency & amount in figures and words]
Mandatory Spare parts Price	N/A
(If economic Factor is applicable) (ITT Sub-Clause 52.2 (f) & 52.5 (b)	
The unconditional discount for being awarded more than one lot in this package is:	USD/ Freely convertible international currency and Taka
(ITT Sub-Clause 23.8)	[state currency & amount in figures and words]
The methodology for Application of the discount is:	[state the methodology]
(ITT Sub-Clause 23.9)	
The advance payment is: (GCC Sub-Clause 27.1)	N/A
and we shall accordingly submit an Advance Pa PG4 -10, – N/A	ayment Guarantee in the format shown in Form
In signing this letter, and in submitting ou	r Tender, we also confirm that:

- a) our Tender shall be valid for the period stated in the Tender Data Sheet (ITT Sub-Clause 27.2) and it shall remain binding upon us and may be accepted at any time before the expiration of that period;
- b) a Tender Security is attached in the form of a *bank guarantee*] in the amount stated in the Tender Data Sheet (ITT Clause 29) and valid for a period of 28 days beyond the Tender validity date;

- c) if our Tender is accepted, we commit to furnishing a Performance Security in the amount stated in the Tender Data Sheet (ITT Sub-Clause 63.2) in the form stated in Tender Data Sheet (ITT Sub-Clause 64.1) and valid for a period of 28 days beyond the date of completion of our performance obligations;
- d) we have examined and have no reservations to the Tender Document, issued by you on [insert date];

including Addendum to Tender Documents No(s) [*state numbers*] ,issued in accordance with the Instructions to Tenderers (ITT Clause 11). [*insert the number and issuing date of each addendum; or delete this sentence if no Addendum have been issued*];

- e) we, including as applicable, subcontractor for any part of the contract resulting from this Tender process, have nationalities from eligible countries, in accordance with ITT Sub-Clause 5.1;
- f) we are submitting this Tender as a sole Tenderer
- g) we are not a Government owned entity as defined in ITT Sub-Clause 5.3

or

we are a Government owned entity, and we meet the requirements of ITT Sub-Clause 5.3]; (delete one of the above as appropriate)

- h) we, declare that we are not associated, nor have been associated in the past, directly or indirectly, with a consultant or any other entity that has prepared the design, specifications and other documents, in accordance with ITT Sub-Clause 5.5;
- i) we, including as applicable subcontractor have not been declared ineligible by the Government of Bangladesh on charges of engaging in corrupt, fraudulent, collusive or coercive practices, in accordance with ITT Sub-Clause 5.6;
- j) furthermore, we are aware of ITT Sub Clause 4.3 concerning such practices and pledge not to indulge in such practices in competing for or in executing the Contract;
- k) we intend to subcontract an activity or part of the Supply, in accordance with ITT Sub-Clause 16.1 to the following Subcontractor(s);

	Nature of the Supply or related service	Name and address of Subcontractor
~		
$\sim$		

- we, confirm that we do not have a record of poor performance, such as abandoning the Supply, not properly completing contracts, inordinate delays, or financial failure as stated in ITT Sub-Clause 5.8, and that we do not have, or have had, any litigation against us, other than that stated in the Tenderer Information Sheet(Form PG4-2);
- m) we are not participating as Tenderers in more than one Tender in this Tendering process. We understand that your written Notification of Award shall become a binding Contract between us, until a formal Contract is prepared and executed;

n) we understand that you reserve the right to accept or reject any Tender, to cancel the Tender proceedings, or to reject all Tenders, without incurring any liability to Tenderers, in accordance with ITT Clause 58.1.

Signature:

Name:

[insert signature of authorized representative of the Tenderer]

[insert full name of signatory with National [D]

In the capacity of:

[insert designation of signatory]

Duly authorized to sign the Tender for and on behalf of the Tenderer

[If there is more than one (1) signatory add other boxes and sign accordingly].

~

KE

Attachment 1: Written confirmation authorizing the above signatory (ies) to commit the Tenderer, in accordance with ITT Sub-Clause 34.3;

### **Tenderer Information Sheet (Form PG4-2)**

[The Tenderer shall fill in this Form in accordance with the instructions indicated below. No alterations to its format shall be permitted and no substitutions shall be accepted]

Invitation for Tender No: [Indicate IFT No]

FT No]

[Insert date of Tender Submission]

Date

Tender Package No:

[Indicate Package No]

### A. Individual Tenderers 1. Eligibility Information of the Tenderer [ITT Clauses 5 & 21] 1.1 Tenderer's Legal Name: 1.2 Tenderer's legal address in Country of Registration 1.4 Tenderer's Year of Registration 1.5 Tenderer's Authorised **Representative Information** Name National ID number Address Telephone / Fax Numbers e-mail address 1.6 Attached are copies of original documents of : [check box (es) of the attached original documents Articles of Incorporation or Registration of firm named in 1.1, in accordance with ITT sub-Clause 5.1and 5.2] In case of government owned entity, documents establishing legal and financial autonomy and compliance with commercial law, in accordance with ITT Sub-Clause 5.3 An affidavit confirming the legal capacity stating that there are no existing orders of any judicial court that prevents either the tenderer or employees of a tenderer entering into or signing a Contract with the Purchaser in accordance with ITT clause 5 □ An affidavit confirming that the tenderer is not insolvent, in receivership or not bankrupt or not in the process of bankruptcy, not temporarily barred from undertaking their business for financial reasons and shall not be the subject of legal proceedings for any of the foregoing in accordance with ITT Clause 5.

	A certificate issued by the competent authority stating that the Tenderer is a Tax payer having valid Tax identification Number (TIN) and VAT registration number or in lieu any other document acceptable to the Purchaser demonstrating that the Tenderer is a genuine Tax payer and has a VAT registration number as a proof of fulfillment of taxation obligations as stated under ITT Clause 5. In the case of foreign Tenderers, a certificate of competent authority in that country of which the Tenderer is citizen shall be provided.
	Documentary evidence demonstrating that they are enrolled in the relevant professional or trade organizations registered in Bangladesh or in case of foreign tenderer in their country of origin or a certificate concerning their competency issued by a professional institution in accordance with the law of the country of their origin, as stated under ITT Clause 5.
	igation History: [Number of arbitration awards against the tenderer over the period cordance the ITT Clause 13.1] if no [state "None"]
3.	Qualification Information of the Tenderer:
3.1	Number of years of overall experience of the Tenderer in the supply of goods and related services as stated under ITT Sub- Clause14.1(a):
3.2	Number of completed supply contracts in the supply of similar goods and related services of required value within the period mentioned in TDS as stated under ITT Sub- Clause 14.1(b):
3.2	Number of completed supply contracts in the supply of similar goods and related services of required value within the period mentioned in TDS as stated under ITT Sub-
3.2 3.3	Number of completed supply contracts in the supply of similar goods and related services of required value within the period mentioned in TDS as stated under ITT Sub- Clause 14.1(b): Number of Contracts: Value of the Contracts:

# Price Schedule for Goods (Form PG4-3A) – Not Applicable

# [Group A Tenders: Goods Manufactured in Bangladesh]

Invitation for Tender No:	Date:	
Tender Package No:	Package Description:	[enter description as specified in Section 6]
Tender Lot No:	Lot Description:	[enter description as specified in Section 6]

1	2	3	4	5	6	7	8	9	1	0
Line Item No.	Description of Item	Unit of Measurement	Quantity	Unit price EXW [FC or		Inland transportation and other local costs for the delivery of the	labour, raw	VAT Payable on account of Supplier if the		per line item . 6+7)
				Taka.]	[FC or Taka.]	Goods to their final destination <i>[Taka]</i>	components from with origin in Bangladesh	Contract is awarded <i>[Taka]</i>	FC	Taka
Not Applicable	Not Applicable	[Insert name of the Unit]	[Insert number of Unit to be supplied]	[Insert EXW unit price, also indicate Currency]	[Insert total EXW price per line item]	[Insert corresponding price per line item]	[Insert cost of local labour, raw material and components as a % of the Col 5]	[Insert Supplier's VAT if Contract is awarded ]	[Insert total pr item]	rice per line
<sup>1</sup> Note : Pric	ce offered in	foreign curren	рсу (FC) & В	angladesh	Taka		Total Price for L	ot		
Point of De	Point of Delivery as per Schedule of Requirement:									

Name:	K (	[insert full name of signatory]	Signature with Date and Seal			
In the capacity of:		[insert designation of signatory]	[ Sign]			
	Duly aut	orized to sign the Tender for and on behalf of the Tenderer				
	<b>&gt;</b>					

# Price Schedule for Goods (Form PG4-3B)

## [Group B Tenders: Goods Manufactured outside Bangladesh, to be imported]

Invitation for Tender No:	As per notice	Date:	As per notice
Tender Package No:	As per notice	Package Description:	[enter description as specified in Section 6]
Tender Lot No: Single lot		Lot Description:	[enter description as specified in Section 6]

1	2	3	4	5	6	7	8	9	1	0
Item No.	Description of Item	Country of Origin (Where materials grown)	Unit of Measurem ent	Quantity	Unit price CFR (Cost Plus Freight) [insert port of destination] [FC]		Inland transportation with loading- unloading cost, Port Handling Charges with C& Agency cost and others [Taka]		Total Price FC (Col.7)	oer line item Taka (Col.8)
1.	Supply of Circulating Water Pump (CWP) motor as per attached specification and drawings. Brand: Hyundai Heavy Industries / ABB / Siemens <i>N.B: Detail specification is attached in</i> <i>Section: 8.</i>	South Korea / Switzerland / Germany	set	01 (One)						
	oint of Delivery as per Schedule of Requireme Company Ltd. (APSCL), Ash	uganj, Brahmanb	oaria-3402,	Banglade	sh.		Total Price Period of Deliv Schedule of re	ery as per	Sig	ning
Nam			, it should be included in the unit price. [insert full name of signatory]				Sig	Signature with Date and Seal		
In the	e capacity of:	[inse	[insert designation of signatory]			[ Si	[ Sign]			
	Duly authorized to sign the Tender for and on behalf of the Tenderer									

# Price Schedule for Goods (Form PG4-3C) - Not Applicable.

## [Group B Tenders: Goods Manufactured outside Bangladesh, already imported]

Invitation for Tender No:	Date:	
Tender Package No:	Package Description:	[enter description as specified in Section 6]
Tender Lot No:	Lot Description:	[enter description as specified in Section 6]

1	2	3	3	4	5	6	7	8	9	10	11
Line Item No .	Description of Item	Country of Origin	Unit of Measurement	Quantity	Unit price Including Custom Duties, import VAT & other import taxes already paid <b>[Taka]</b>	Custom Duties, impor VAT & other import taxes already paid per unit <b>[Taka]</b>	Duties, import VAT & other import taxes	Price per line item net of Custom Duties, import VAT & other import taxes already paid [Taka] (Col. 4X Col. 7)	Inland transportation and other local costs for the delivery of the Goods to their final destination <b>[Taka]</b>	VAT Payable on account of Supplier if the Contract is awarded <b>[Taka]</b>	Total Price per line item (Col.8+ Col.9) <i>[Taka]</i>
Not Applic able.	Not Applicabl e.	[insert country of origin of the Good]	[Insert name of the Unit]	[Insert numbe r of Unit to be supplie d]	[Insert unit price including CD & all import taxes]	[Insert CD, VAT & import taxes paid per unit] to be supported by documents	[insert unit price net of CD, VAT and import taxes]	[ insert price per line item net of CD,VAT and import taxes]	[Insert correspond ing price per line item]	[Insert Supplier's VAT if Contract is awarded ]	[Insert total price per line item ]
			<u>gladesh Taka</u>		<u> </u>			Price for Lot		<u></u>	
Point	of Delivery	as per Sc	hedule of Red	uiremen		F	Period of Delivery as	per Schedule	of Requirem	ent:	
				-							
Name:	Name:         [insert full name of signatory]         Signature with Date and Seal								d Seal		
In the c	In the capacity of: [insert designation of signatory] [Sign]										
				Dul	y authorized to	sign the Ter	nder for and on behalf o	f the Tenderer			
			Y								

# Price and Completion Schedule - Related Services (Form PG4-3D).

Invitatio	on for Tender No:		Date	):					
Tender	Package No:	N/A.	Pacl	kage Des	cription:	[enter description a	as specified in Sec	tion 6]	
Tender	Lot No:		Lot	Description	on:	[enter description a	as specified in Sec	tion 6]	
1	2	3	4	5	6	7	8	ļ	•
Service No.	Description of Services	Country of Origin	Unit of Measurement	Quantity	Unit price of service [FC] or [Taka]	Price per line item of service (Col. 5 X Col. 6) [FC] or [Taka]	VAT Payable on account of Supplier if the Contract is awarded [Taka]	of se	ber line item rvice I. 7) Taka
1.	Installation, Testing and Commissioning o Circulating water (CW) pump Motor.	f Switzerland/	Job	01	0,				
Note Price	e offered in foreign currency (FC) &	& Bangladesh Taka				Total Price for Lot			
Point of I	Delivery: As per Schedule of Ro	equirement.		Pe	riod of Deliver	ry: As per Schedule of	Requirement.		

### N.**B**.:

1. The mounting arrangement, Size & Position of phases junction box, neutral junction box, junction box for heating resistors, instrument junction box etc. of the motor must be same as the CW pump motor of the 450 MW CCPP (South) plant of APSCL. All of these and related mechanical accessories should be 100% similar to the original motor. The motor supplier must take total responsibilities to the mentioned items and the supplier will be solely responsible for any kind of miss-match. No deviation will be accepted in this regard. Manufacturer must provide the manual and necessary wiring diagram of the CW pump motor along with the motor supply as required by APSCL.

2. The installation, alignment, adjustment, coupling along with the testing and commissioning of the supplied motor shall be carried out by the manufacturer expert of the motor. All cost regarding the test and commissioning of the motor and expert from manufacturer must be included in the actual cost of the supplied motor.

- 3. The delivery point would be warehouse (South plant) of Ashuganj Power Station Company Ltd. (APSCL), Ashuganj, Brahmanbaria-3402, Bangladesh. After receiving the motor by the warehouse of APSCL, the authority of APSCL will provide the schedule for Installation, Testing and Commissioning within 120 calendar days of the delivery. The Installation, Testing and Commissioning work shall be completed within 10 calendar days from the date of plant shut down. The plant shut down shall be given at a suitable duration of time within 180 calendar days from the date of receipt of Motor at APSCL Plant site. The Manufacturer's expert shall start journey only after getting notification from APSCL.
- 4. All related services must have to complete as per technical specification of tender document.
- 5. The manufacturer must submit the FAT report along with the manual and necessary wiring diagram regarding the motor. The FAT must be completed in presence of three (03) engineers from APSCL at the manufacturing factory of the motor. The motor supplier must bear all expenses related to the APSCL three (03) engineers travel i.e., airfares cost (up-down), accommodation/hotel cost, local transportation cost, food cost, the daily allowances for seven (07) days etc.

Third Party inspection as per GCC clause 32.1. In case of Third-party inspection, the supplier will arrange a video call participation with purchaser during the witness.

OR

Name:	[insert full name of signatory]	Signature with Date and Seal
In the capacity of:	[insert designation of signatory]	[ Sign]
	Duly authorized to sign the Tender for and on behalf of the	Tenderer

## **Specifications Submission and Compliance Sheet (Form PG4-4)**

Invitation for Tender No:	As per tender Notice	Date:	As per tender Notice
Tender Package No:	As per tender Notice	Package Description:	As per tender Notice
Tender Lot No:	Single	Lot Description:	As per tender Notice

### Supply, installation, commissioning and testing of Circulating Water Pump Motor at 450 MW CCPP (South) plant of APSCL

			General	
SL No	Description	Unit	character	Full Technical Specification and standards (To be filled by tenderer)
	APSCL Require	ment		NOTE 1
1	Name of the manufacturer & Country of origin HYUNDAI HEAVY INDUSTRIES, Korea. (Original) / ABB, Switzerland/ Siemens, Germany	-	To be filled by the bidder	
2	Туре	-	Three Phase Induction Motor- Squirrel Case	
3	Make and Model no.	-	To be filled by the bidder	
4	Catalogue no.	-	To be filled by the bidder	
5	General and safety requirement	-	To be filled by the bidder	
6	Quality assurance	-	ISO 9001	
Tech	nical data for supplying, insta	llation,	testing & commissioning	g of CW pump motor.
7	Equipment		Three Phase Induction motor	
8	For		Circulating water pump Approx. weight Motor pedestal: 22500 Kg	
9	Manufacturer The bidder may offer from Original manufacturer (Hyundai) or distributor of motor or any other manufacturer (as mentioned) who are manufacturing similar motor.		HYUNDAI HEAVY INDUSTRIES, Korea ABB, Switzerland Siemens, Germany	
10.	Slip		0.80 %	
11.	Stator winding connection		Star (Y)	
12.	LRC (Locked Rotor Current)	p.u	5.5	
13.	Guaranteed power rating	kW	2220	
14.	Direction of Rotation (looking at the motor from the side opposite the coupling)		CW	
15.	Duty Type		S1	
16.	Class of stator winding Insulation		F	
17.	Туре		HRQ3 807-76Y	
18. 10	Frame size		800	
19. 20.	Rated useful life Shaft type	years	25 Solid vertical	
	Type of construction and		The mounting arrangement	1
21.	mounting arrangement		and related mechanical, I&C accessories should be 100%	

			similar to the original motor.	
22.	Protection degree		IP55	
22. 23.	Power frequency withstand voltage	kV	14.2	
24.	Rated voltage	kV	6.6 ± 10%	
24. 25.	Rated frequency	Hz	50	
26.	Rated Speed	RPM	372	
27.	Phases	14.11	3	
28.	No. of pole		16	
29.	Rated current	A	267.6	
30.	No load current	A	149.0	
31.	Minimum torque at rated voltage and frequency	%	74	
32.	Breakdown torque	p.u	2.3	
33.	Guaranteed minimum startup voltage	% UN	80	
34.	Power factor with locked rotor		0.71	
35.	Moment of Inertia	Kgm <sup>2</sup>	1067.0	
36.	Efficiency			
	- at 4/4 load - at 3/4 load - at 2/4 load	% % %	95.5 95.4 94.6	
37.	Power factor - at 4/4 load - at 3/4 load at 2/4 load	p.u p.u	0.76	
38.	- at 2/4 load Insulation system of stator winding	p.u	0.62 VPI	
39.	Ambient temperature	<sup>0</sup> C	40	
40.	Temperature rise	k	80	
41.	Rotor axial clearance	mm	300	
42.	Type of bearings		Lubricant	
	- DE (Drive End) - NDE (Non-Drive End)		Amount           6052M         130g           7340BDT         1210g	
43.	Temp. detector of bearing (RTDs): - Quantity per bearing - Manufacturer - Type	)	1 Pt-100 6 (3, Dual)	
44.	- Number of terminals Lubrication of bearing - Type - Interval	months	SHELL GADUS S2 V100 3 4	
45	Stator temperature detectors (RTDs): - Quantity - Manufacturer - Type - Number of terminals		6 pt-100 6 (3, Dual)	
46.	Acceleration time (full load) a) At rated voltage b) At min specified startup voltage	S	a) Approx. 1.8s b) Approx. 4.3s	
47.	Temperature detectors (RTDs) to measure heat exchanger inlet and outlet air, in case of air/water cooling:			

	<u> </u>	ł		
	- Quantity		2	
	- Manufacturer			
	- Type		Pt-100	
	- Number of terminals		6	
48.	Current transformer for			
	differential protection:			
	- Quantity		3	
	- Manufacturer		CTE TECH	
	- Type		EPOXY MOLDED	
	- Connection		CIH-250	
	- Transformation ratio		50/5	
	- Rated output.			
	<ul> <li>Accuracy class and</li> </ul>		10P5	
	rated accuracy limit			
	factor			
49.	Motor equivalent circuit		0.0086	
	parameters in respect of stator		0.1310	
	R1 X1	p.u	0.0097	
	R2 (S=0) R2 (S=1) X2 (S=0) X2	p.u	0.0217	
	(S=1) XM		0.0728	
			0.0458	
			1.5583	
50.	Sub-transient reactance, X"	p.u	0.1653	
51.	Sound pressure level	dB(A)	80	
52.	Service factor		1.15	/
53.	Space heater		2 Piece; 230 <b>V</b> ;	
54.	Motor cooling method		IC611	
55.	Surge arresters:			
	- Quantity		3	
	- Manufacturer		OHIO BRASS PDV-65	
	- Type		Phase-earth 9	
	- Connection type	kV	7.65	
	- Rated voltage.			
	- Continuous	kV		
	operating			
	voltage			
56.	Number of terminal boxes		4	
57.	Type of terminal boxs		STEEL	
58.	Minimum IP protection degree of		IP65 (MAIN T/B IP55)	
	the terminal boxes			
59.	Size & Position of phases junction	L	1. Mentioned in the attached	
	box, junction box for heating		drawings.	
	resistors etc.		2. Size & Position of	
			phases junction box,	
			junction box for heating	
			resistors and junction box	
			for $PT100\Omega$ sensor of	
			winding & bearing temp	
	<b>7</b>		should be 100% matched	
			to the original motor.	
<u> </u>		1		

60.	Tests at manufacturer		No-load test	
	premises/factory		Locked rotor test	
			Dielectric strength test	
	The tests should be done at		at power frequency for 1	
	factory of manufacturer with the		min	
	presence of representatives/		Insulation resistance test	
	engineers (3 persons) of APSCL (in Service). And test report		before and after the	
	should be delivered with the		dielectric test	
	supply.		Winding resistance	
			measurement	
			Rotation test and phase	
			sequence test	
			Rotor vibration test and	
			balance test	
			Phase-earth capacity	
			and tan $\delta$ of the insulation	
			Dimensional check and	
			verification of finish	
			Inspection of the motor	
			auxiliary device wiring to	
			the terminal strips	
			Determination of the	<b>Y</b>
			magnetic centering 人 💙	
			Operating inspection of the	
			RTDs of windings and	
			bearings	
			-Overspeed test	
			Temperature rise test	
			Sound pressure level at 1 m	
			Establishment of	
			speed-torque, speed-	
			current and speed-	
			power factor curves	
			Determination of losses,	
			efficiency and power factor	
(1	Site tests after installation		Visual inspection (motor	
61.	She tests after installation		rating plate, ID plate,	
	The tests should be done at site of		terminal boxes, CT's,	
	APSCL and test report should be		RTD's, documentation,	
	delivered.		paint, cooling, etc)	
			No-load test as per	
			declared standard	
/			test procedure.	
			Insulation resistance test	
	<b>Y</b>		before and after the load at 100% rated load.	
			Winding resistance	
			measurement	
			Rotation test	
			Dimensional check and	
			verification of finish	
			72 hrs. Temp. rise test at	
			full load/ max. available	
			load	
			No load vibration test	
1		1	(DE, NDE) and full load	

		vibration test (DE, NDE)	
62.	Pump requirements	Fluid type: Raw water Flow: 29023 m3/h Total head: 21.9	Given for your convenience
	Given for your convenience	m NPSH available: 15.2 m Gauge pressure at pump discharge: 2.81 barg at LWL	
	Installation, Testing and Commissioning of Circulating water (CW) pump Motor.	discharge. 2.81 barg at LWL	

### Note 1 :

## [The tenderer should complete all the columns]

[The Tenderer should complete all the columns as per Manufacturer data with supporting technical documents duly sealed and signed by the respective Manufacturers]

	$\mathbf{N}'$
Signature:	[insert signature of authorized representative of the Tenderer]
Name:	[insert full name of signatory]
In the capacity of:	[insert designation of signatory]
Duly authorized to sign the Tender for and on behalf of	f the Tenderer

# Manufacturer's Authorisation & Warranty/Guarantee Letter (Form PG4 - 5)

[The Tenderer shall require the Manufacturer to fill in this Form in accordance with the instructions indicated. This letter of authorization should be on the letterhead of the Manufacturer and should be signed by a person with the proper authority to sign documents that are binding on the Manufacturer. The Tenderer shall include it in its tender, if so indicated in the **TDS as stated under ITT Sub-Clause 26.1(b)**]

Invitation for Tender No: As per Tender Notice	Date: As per Tender Notice	
Tender Package No: As per Tender Notice		
Tender Lot No:	Single.	
To: [Name and address of Purchaser]		

#### WHEREAS

We [insert complete name of Manufacturer],

who are official manufacturer of *[insert type of goods manufactured]*, having factories at *[insert full address of Manufacturer's factories]*, do hereby

authorize [insert complete name of Tenderer] to supply the following Goods, manufactured by us [insert name and or brief description of the Goods]. OR

We hereby confirm that We will supply our genuine products to the tenderer and our Engineer (s) shall execute the installation, commissioning and testing works within the supplier's contract, being present at designated site of 450 MW-South plant of APSCL, Ashuganj, Brahmanbaria, Bangladesh.

We hereby extend our full guarantee and warranty as stated under GCC Clause 33 of the General Conditions of Contract, with respect to the Goods offered by the above Tenderer.

Signed: [insert signature(s) of authorized representative(s) of the Manufacturer]

Name: [insert complete name(s) of authorized representative(s) of the Manufacturer] Address: [insert full address including Fax and e-mail] Title: [insert title]

Date: [insert date of signing]

# Bank Guarantee for Tender Security (Form PG4 – 6)

[this is the format for the Tender Security to be issued by a scheduled bank of Bangladesh as stated under ITT Clauses 29 and 30]

Invitation for Tender No:

Date:

Tender Package No:

Tender Lot No:

To: [Name and address of Purchaser]

### TENDER GUARANTEE No:

We have been informed that [insert name of Tenderer] (hereinafter called "the Tenderer") intends to submit to you its Tender dated [insert date of Tender] (hereinafter called "the Tender") for the supply of [description of goods and related services] under the above Invitation for Tenders (hereinafter called "the IFT").

Furthermore, we understand that, according to your conditions, Tenders must be supported by a Bank Guarantee for Tender Security.

At the request of the Tenderer, we *[insert name of bank]* hereby irrevocably undertake to pay you, without cavil or argument, any sum or sums not exceeding in total an amount of Tk. *[insert amount in figures and in words]* upon receipt by us of your first written demand accompanied by a written statement that the Tenderer is in breach of its obligation(s) under the Tender conditions, because the Tenderer:

- a. has withdrawn its Tender after opening of Tenders but within the validity of the Tender Security ; or
- b. refused to accept the Notification of Award (NOA) within the period as stated under Instructions to Tenderers (ITT); or
- c. failed to furnish Performance Security within the period as stipulated in the NOA; or
- d. refused to sign the Contract Agreement by the time specified in the NOA; or
- e. did not accept the correction of the Tender price following the correction of the arithmetic errors in accordance with the ITT; or

This guarantee will expire:

- (a) if the Tenderer is the successful Tenderer, upon our receipt of a copies of the contract signed by the Tenderer and the Performance Security issued to you in accordance with the ITT; or
- (b) if the Tenderer is not the successful Tenderer, twenty eight (28) days after the expiration of the Tenderer's Tender validity period, being [date of expiration of the Tender validity plus twenty eight(28) days]

Consequently, we must receive at the above-mentioned office any demand for payment under this guarantee on or before that date.

Signature

Seal

# Notification of Award (Form PG4 - 7)

Contract No: To: Date:

[Name of Contractor]

This is to notify you that your Tender dated [insert date] for the supply of Goods and related <u>Services</u> for [name of contract] for the Contract Price of Tk. [state amount in figures and in words] as corrected and modified in accordance with the Instructions to Tenderers, has been approved by [name of Purchaser].

You are thus requested to take following actions:

- i. accept in writing the Notification of Award within seven (7) working days of its issuance pursuant to ITT Sub-Clause 62.3
- ii. furnish a Performance Security in the specified format and in the amount of Tk. [state amount in figures and words], within Twenty-eight (28) days from issue of this Notification of Award but not later than <u>(specify date)</u>, in accordance with ITT Clause 64.2
- iii. sign the Contract within twenty-eight (28) days of receipt of this Notification of Award but not later than <u>(specify date)</u>, in accordance with ITT Clause 67.2

You may proceed with the execution of the supply of Goods and related Services only upon completion of the above tasks. You may also please note that this Notification of Award shall constitute the formation of this Contract, which shall become binding upon you.



Signed

Duly authorized to sign for and on behalf of [name of Purchaser]

Date:

# **Contract Agreement (Form PG4 - 8)**

THIS AGREEMENT made the [day] day of [month] [year] between [name and address of Purchaser] (hereinafter called "the Purchaser") of the one part and [name and address of Supplier] (hereinafter called "the Supplier") of the other part:

WHEREAS the Purchaser invited Tenders for certain goods and related services, viz. [brief description of goods and related services] and has accepted a Tender by the Supplier for the supply of those goods and related services in the sum of Taka [Contract Price in figures and in words] (hereinafter called "the Contract Price").

#### NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

- 1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the General Conditions of Contract hereafter referred to
- 2. The following documents forming the Contract shall be in the following order of precedence, namely :
  - (a) the signed Form of Contract Agreement;
  - (b) the Notification of Award
  - (c) The Tender and the appendices to the Tender
  - (d) Particular Conditions of Contract;
  - (e) General Conditions of Contract;
  - (f) Technical Specifications;
  - (g) Drawings;
  - (h) Price Schedules and Schedule of Requirements and;
  - (i) other document including correspondences listed in the PCC forming part of the Contract
- 3. In consideration of the payments to be made by the Purchaser to the Supplier as hereinafter mentioned, the Supplier hereby covenants with the Purchaser to provide the goods and related services and to remedy any defects therein in conformity in all respects with the provisions of the Contract.
- 4. The Purchaser hereby covenants to pay the Supplier in consideration of the provision of the goods and related services and the remedying of defects therein, the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the Contract.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with the laws of Bangladesh on the day, month and year first written above.

For the Purchaser:

For the Supplier:

Signature Print Name

Title

In the presence of Name Address

## Bank Guarantee for Performance Security (Form PG4 – 9)

[This is the format for the Performance Security to be issued by **an internationally reputable bank and it shall have correspondent bank located in Bangladesh, to make it enforceable** in accordance with ITT Sub-Clause 64.1 pursuant to Rule 27(4) of the Public Procurement Rules, 2008.]

Contract No:

Date:

To:

[Name and address of Purchaser]



### **PERFORMANCE GUARANTEE No:** [insert Performance Guarantee number]

We have been informed that [name of supplier] (hereinafter called "the Supplier") has undertaken, pursuant to Contract No [reference number of Contract] dated [date of Contract] (hereinafter called "the Contract") for the supply of [description of goods and related services] under the Contract.

Furthermore, we understand that, according to your conditions, Contracts must be supported by a performance guarantee.

At the request of the Supplier, we [name of bank] hereby irrevocably undertake to pay you, without cavil or argument, any sum or sums not exceeding in total an amount of Tk. [insert amount in figures and in words] upon receipt by us of your first written demand accompanied by a written statement that the Supplier is in breach of its obligation(s) under the Contract conditions, without you needing to prove or show grounds or reasons for your demand of the sum specified therein.

This guarantee is valid until [date of validity of guarantee], consequently, we must receive at the above-mentioned office any demand for payment under this guarantee on or before that date.

[Signatures of authorized representatives of the bank]

Signature

Seal

# Bank Guarantee for Advance Payment (Form PG4 – 10) - Not Applicable

[this is the format for the Advance Payment Security to be issued by **an internationally reputable bank and it shall have correspondent bank located in Bangladesh, to make it enforceable** in accordance with GCC Clause 27.1]

Contract No:

Date:

To:

[Name and address of Purchaser]

### ADVANCE PAYMENT GUARANTEE No:

We have been informed that [name of supplier] (hereinafter called "the Supplier") has undertaken, pursuant to Contract No [reference number of Contract] dated [date of Contract] (hereinafter called "the Contract") for the supply of [description of goods and related services] under the Contract.

Furthermore, we understand that, according to your Particular Conditions of Contract Clause 26.1, Advance Payment(s) on Contracts must be supported by a bank guarantee.

At the request of the Supplier, we [name of bank] hereby irrevocably undertake to pay you, without cavil or argument, any sum or sums not exceeding in total an amount of Tk [insert amount in figures and in words] upon receipt by us of your first written demand accompanied by a written statement that the Supplier is in breach of its obligation(s) under the Contract conditions, without you needing to prove or show grounds or reasons for your demand of the sum specified therein.

We further agree that no change, addition or other modification of the terms of the Contract to be performed, or of any of the Contract documents which may be made between the Purchaser and the Supplier, shall in any way release us from any liability under this guarantee, and we hereby waive notice of any such change, addition or modification.

This guarantee is valid until [date of validity of guarantee], consequently, we must receive at the above-mentioned office any demand for payment under this guarantee on or before that date.

[Signatures of authorized representatives of the bank]

Signature

Seal

# **Deviation List (Form PG4-11)**

[If Tenderer has any reservations on terms and conditions, Tenderer has to mention his reservations in Deviation list]

Image:	SI. No.	Reference No./ Clause No.	Proposed Deviation	Remarks
Tenderer]       Name:     [insert full name of signatory]       In the capacity of:     [insert designation of signatory]				
Signature:[insert signature of authorized representative of the Tenderer]Name:[insert full name of signatory]In the capacity of:[insert designation of signatory]				
Tenderer]       Name:     [insert full name of signatory]       In the capacity of:     [insert designation of signatory]	[Add rows if n	ecessary]		
In the capacity of: [insert designation of signatory]	Signature:		[insert signature of au Tenderer]	ithorized representative of the
	Name:		[insert full name of sig	gnatory]
Duly authorized to sign the Tender for and on behalf of the Tenderer	In the capa	city of:	[insert designation of	signatory]

## Section 6. Schedule of Requirements

Invitation for Tender No:	As per Tender Notice	Date:	As per Tender Notice
Tender Package No:	N/A		

## A. List of Goods and Delivery Schedule

When completing Form PG4-3A, 3B & 3C the Tenderer shall quote prices and contract delivery dates for each lot separately, as specified in the List of Goods and Delivery Schedule.

SI. No	Description of the item	Unit of Measurement	Quantity	Point of Delivery (Final project site)	Completion time (in days)
1.	Supply of Circulating Water Pump (CWP) motor as per attached specification and drawings. Manufacturer: Hyundai Heavy Industries (South Korea) / ABB (Switzerland)/ SIEMENS (Germany)	set	01 (One)	Ashuganj 450MW CCPP (South) Plant Store.	210 days from the date of L/C opening.

## Note:

- 1. The mounting arrangement, Size & Position of phases junction box, neutral junction box, junction box for heating resistors, instrument junction box etc. of the motor must be same as the CW pump motor of the 450 MW CCPP (South) plant of APSCL. All of these and related mechanical accessories should be 100% similar to the original motor. The motor supplier must take total responsibilities to the mentioned items and the supplier will be solely responsible for any kind of mismatch. No deviation will be accepted in this regard. Manufacturer must provide the manual and necessary wiring diagram of the CW pump motor along with the motor supply as required by APSCL.
- 2. The installation, alignment, adjustment, coupling along with the testing and commissioning of the supplied motor shall be carried out by the manufacturer expert of the motor. All cost regarding the test and commissioning of the motor and expert from manufacturer must be included in the actual cost of the supplied motor.
- 3. The manufacturer must submit the FAT report along with the manual and necessary wiring diagram regarding the motor. The FAT must be completed in presence of three (03) engineers from APSCL at the manufacturing factory of the motor. The motor supplier must bear all expenses related to the APSCL three (03) engineers travel i.e., airfares cost (up-down), accommodation/hotel cost, local transportation cost, food cost, the daily allowances for seven (07) days etc.

OR

Third Party inspection as per GCC clause 32.1. In case of Third-party inspection, the supplier will arrange a video call participation with purchaser during the witness.

4. The delivery point would be warehouse (South plant) of Ashuganj Power Station Company Ltd. (APSCL), Ashuganj, Brahmanbaria-3402, Bangladesh. After receiving the motor by the warehouse of APSCL, the authority of APSCL will provide the schedule for Installation, Testing and Commissioning within 120 calendar days of the delivery. The Installation, Testing and Commissioning work shall be completed within 10 calendar days from the date of plant shut down. The plant shut down shall be given at a suitable duration of time within 180 (One Hundred Eighty) calendar days from the date of receipt of Motor at APSCL Plant site. The Manufacturer's expert shall start journey only after getting notification from APSCL.

In the capacity of:

Duly authorized to the sign the Tender on behalf of the Tenderer. Date:

## B. List of Related Services and Completion Schedule.

When completing Form PG4-3D, the Tenderer shall quote prices and Completion date for services for each item against each lot

ltem No.	Description of Item	Unit of Measurement	Quantity	Place where Services shall be performed	Completion Date(s) of Services
1.	APSCL engineers (3 persons) Factory Acceptance Test (FAT) at Motor manufacturer's factory. The motor supplier must bear all expenses related to the APSCL three (03) engineers travel i.e. airfares cost (up- down), accommodation/hotel cost, local transportation cost, food cost, the daily allowances for seven (07) days etc. OR Third Party inspection as per GCC clause 32.1. In case of Third-party inspection, the supplier will arrange a video call participation with purchaser during the witness.	Lot	01	At Manufacturing Factory	Before Shipment
2.	Installation, Testing and Commissioning of Circulating water (CW) pump Motor.	Lot	01	Designated location at Ashuganj 450 MW CCPP (South), APSCL plant site, Ashuganj, Brahmanbaria- 3402, Bangladesh	Within 10 calendar days from the date of Plant shutdown

N.B. 🖌

1. The mounting arrangement, Size & Position of phases junction box, neutral junction box, junction box for heating resistors, instrument junction box etc. of the motor must be same as the CW pump motor of the 450 MW CCPP (South) plant of APSCL. All of these and related mechanical accessories should be 100% similar to the original motor. The motor supplier must take total responsibilities to the mentioned items and the supplier will be solely responsible for any kind of mismatch. No deviation will be accepted in this regard. Manufacturer must provide the manual and necessary wiring diagram of the CW pump motor along with the motor supply as required by APSCL.

2. The installation, alignment, adjustment, coupling along with the testing and commissioning of the supplied motor shall be carried out by the manufacturer expert of the motor. All cost

regarding the test and commissioning of the motor and expert from manufacturer must be included in the actual cost of the supplied motor.

3. The manufacturer must submit the FAT report along with the manual and necessary wiring diagram regarding the motor. The FAT must be completed in presence of three (03) engineers from APSCL at the manufacturing factory of the motor. The motor supplier must bear all expenses related to the APSCL three (03) engineers travel i.e., airfares cost (up-down), accommodation/hotel cost, local transportation cost, food cost, the daily allowances for seven (07) days etc.

Or

Third Party inspection as per GCC clause 32.1. In case of Third-party inspection, the supplier will arrange a video call participation with purchaser during the witness.

4. The delivery point would be warehouse (South plant) of Ashuganj Power Station Company Ltd. (APSCL), Ashuganj, Brahmanbaria-3402, Bangladesh. After receiving the motor by the warehouse of APSCL, the authority of APSCL will provide the schedule for Installation, Testing and Commissioning within 120 calendar days of the delivery. The Installation, Testing and Commissioning work shall be completed within 10 calendar days from the date of plant shut down. The plant shut down shall be given at a suitable duration of time within 180 (One Hundred Eighty) calendar days from the date of receipt of Motor at APSCL Plant site. The Manufacturer's expert shall start journey only after getting notification from APSCL.

5. Acceptance certificate will be issued after continuous running of the supplied Motor at full load for three (3) days at 450 MW South plant of APSCL. After then R&I will be issued.

## Section 7. Technical Specifications

### Supply, Installation, Testing & Commissioning of Circulating Water Pump Motor for 450MW CCPP-South of APSCL.

		G	General	
SL No	Description	Unit	Character	Remarks
1.	Name of the manufacturer & Country of origin	-	To be filled by the bidder	HYUNDAL HEAVY INDUSTRIES, Korea. (Origin al) / ABB, Switzerland/ Siemens, Germany
2.	Туре	-	Three Phase Induction Motor-Squirrel Case	
3.	Make and Model no.	-	To be filled by the bidder	
4.	Catalogue no.	-	To be filled by the bidder	
5.	General and safety requirement	-	To be filled by the bidder	
6.	Quality assurance	-	ISO 9001	
	Technical data for supplying, in	stallatio	n, testing & commissioning of CW put	mp motor.
7.	Equipment		Three Phase Induction motor	
8.	For		Circulating water pump Approx. weight Motor pedestal: 22500 Kg	
9.	Manufacturer		HYUNDAI HEAVY INDUSTRIES, Korea ABB, Switzerland Siemens, Germany	The bidder may offer from original manufacturer (Hyundai) or distributor of motor or any other manufacturer (as mentioned) who are manufacturing similar motor.
10. 🦯	Slip		0.80 %	
11.	Stator winding connection		Star (Y)	
12.	LRC (Locked Rotor Current)	p.u	5.5	
13.	Guaranteed power rating	kW	2220	
14.	Direction of Rotation (looking at the motor from the side opposite the coupling)		CW	
15.	Duty Type		S1	
16.	Class of stator winding Insulation		F	
17.	Туре		HRQ3 807-76Y	
18.	Frame size		800	
19.				

20.	Shaft type		Solid vertical		
21.	Type of construction and mounting	<b>I</b>	The mounting array	ngement and related	<u></u>
	arrangement			ccessories should be 100%	
	-		similar to the origin	nal motor.	
22.	Protection degree		IP55		
23.	Power frequency withstand voltage	kV	14.2		
24.	Rated voltage	kV	$6.6 \pm 10\%$		
25.	Rated frequency	Hz	50		
26.	Rated Speed	RPM	372		
26. 27.	Phases		3		
28.	No. of pole		16		
29.	Rated current	А	267.6		
30.	No load current	А	149.0		
31.	Minimum torque at rated voltage	%	74		
	and frequency				
32.	Breakdown torque	p.u	2.3		
33.	Guaranteed minimum startup	% UN	80		
	voltage				*
34.	Power factor with locked rotor		0.71		
35.	Moment of Inertia	$Kgm^2$	1067.0		
36.	Efficiency				
	- at 4/4 load	%	95.5		
	- at 3/4 load	%	95.4		
	- at 2/4 load	%	94.6		
37.	Power factor				
	- at 4/4 load	p.u	0.76	<b>7</b>	
	- at <sup>3</sup> ⁄4 load - at 2/4 load	p.u p.u	0.73 0.62		
38.	Insulation system of stator winding	p.u	VPI		
30. 39.	Ambient temperature	<sup>0</sup> C	40		
<u>40.</u>	Temperature rise	k	80		
40. 41.	Rotor axial clearance	mm	300		
42.	Type of bearings		300	Lubricant Amount	
42.	Type of bearings	P		Lubricant Amount	
	- DE (Drive End)		6052M	130g	-
	- NDE (Non-Drive End)	<b>Y</b>			_
			7340BDT	1210g	
43.	Temp. detector of bearing				
	(RTDs):				
	- Quantity per bearing		1		
	- Manufacturer		D: 100		
	- Type Number of terminals		Pt-100 6 (3, Dual)		
44.	- Number of terminals Lubrication of bearing		0 (3, Duai)		+
····	- Type		SHELL GADUS S	2 V100 3	
	- Interval	months	4		
45.	Stator temperature detectors				+
	(RTDs):				
	- Quantity		6		
	- Manufacturer				
	- Type		Pt-100		
	- Number of terminals		3		
46.	Acceleration time (full load)				
	c) At rated voltage		c) Approx. 1.8		
	d) At min specified	S	d) Approx. 4.3	S	
	startup voltage				

47				1
47.	Temperature detectors (RTDs)			
	to measure heat exchanger inlet			
	and outlet air, in case of			
	air/water cooling:			
	- Quantity		2	
	- Manufacturer		<b>B</b> t 100	
	<ul><li>Type</li><li>Number of terminals</li></ul>		Pt-100 6	
40				
48.	Current transformer for differential			
	protection:		3	
	- Quantity - Manufacturer		3 CTE TECH	_
			CTE TECH	
	- Type - Connection		EPOXY MOLDED CIH-250	
	- Connection - Transformation ratio			
			50/5	
	<ul><li>Rated output.</li><li>Accuracy class and</li></ul>		10P5	
	- Accuracy class and rated accuracy limit			
	factor			
49.	Motor equivalent circuit			
47.	parameters in respect of stator			
	R			
	к 1	p.u	0.0086	
		P.u	0.1310	
			0.0097	
	R2		0.0217	
	(S=0		0.0728	
	) R2		0.0458	
	(S=1		1.5583	
	) X2			
	(S=0			
	) X2			
	(S=1			
	XM			
50.	Sub-transient reactance, X"	p.u	0.1653	
51. 52.	Sound pressure level	dB(A)	80	
	Service factor	7	1.15	
53. 54.	Space heater		2 Piece; 230V;	
	Motor cooling method		IC611	
55.	Surge arresters:			
	- Quantity		3	
	- Manufacturer		OHIO BRASS	
	- Type		PDV-65	
	- Connection type		Phase-earth	
	- Rated voltage.	kV	9	
	- Continuous	kV	7.65	
	operating voltage			
56.	Number of terminal boxes		4	
57.	Type of terminal boxs		STEEL	
58.	Minimum IP protection degree of		IP65 (MAIN T/B IP55)	
-	the terminal boxes			
59.	Size & Position of phases		3. Mentioned in the attached drawings.	
	junction box, junction box for		4. Size & Position of phases junction box,	
	heating resistors etc.		junction box for heating resistors and	
			junction box for PT100 $\Omega$ sensor of winding	
			& bearing temp should be 100% matched to	
			the original motor.	

60.	Tests at manufacturer		- No-load test	The tests should be
	premises/factory		<ul> <li>Locked rotor test</li> </ul>	done at
			- Dielectric strength test at power	factory of
			frequency for 1 min	manufacturer with
			- Insulation resistance test before and	the
			after the dielectric test	presence of
			- Winding resistance measurement	representatives/
			<ul> <li>Rotation test and phase sequence</li> </ul>	engineers ( 3 persons)
			test	of APSCL (in
			- Rotor vibration test and balance test	Service). And test
			- Phase-earth capacity and tan $\delta$ of	report should be
			the insulation	delivered with the
			- Dimensional check and verification	supply.
			of finish	
			<ul> <li>Inspection of the motor auxiliary</li> </ul>	
			device wiring to the terminal strips	
			- Determination of the magnetic	
			centering	
			- Operating inspection of the RTDs of	
			windings and bearings	
			- Overspeed test	
			- Temperature rise test	
			- Sound pressure level at 1 m	
			- Establishment of speed-torque,	
			speed-current and speed-power	
			factor curves	
			- Determination of losses, efficiency	
			and power factor	
61.	Site tests after installation		- Visual inspection (motor rating	The tests should be
			plate, ID plate, terminal boxes,	done at site of
			<b>CT</b> 's, RTD's, documentation, paint,	APSCL and test
			cooling, etc)	report should be
			- No-load test as per declared	delivered.
			standard test procedure.	denvered.
			- Insulation resistance test before and	
			after the load at 100% rated load.	
			- Winding resistance measurement	
		7	- Rotation test	
			- Dimensional check and verification	
			of finish	
			- 72 hrs. Temp. rise test at full load/	
			max. available load	
	<b>K</b>		- No load vibration test (DE, NDE)	
			and full load vibration test (DE,	
			NDE)	
62.	Pump requirements		Fluid type: Raw water	Given for your
	- mp requirements		Flow: 29023 m3/h	convenience
			Total head: 21.9 m	
			NPSH available: 15.2 m	
			Gauge pressure at pump discharge: 2.81 barg	
			at LWL	

1. The mounting arrangement, Size & Position of phases junction box, neutral junction box, junction box for heating resistors, instrument junction box etc. of the motor must be same as the CW pump motor of the 450 MW CCPP (South) plant of APSCL. All of these and related mechanical accessories should be 100% similar to the original motor. The motor supplier must take total responsibilities to the mentioned items and the supplier will be solely responsible for any kind of miss-match. No deviation will be accepted in this regard.

Manufacturer must provide the manual and necessary wiring diagram of the CW pump motor along with the motor supply as required by APSCL.

2. The manufacturer must submit the FAT report along with the manual and necessary wiring diagram regarding the motor. The FAT must be completed in presence of three (03) engineers from APSCL at the manufacturing factory of the motor. The motor supplier must bear all expenses related to the APSCL three (03) engineers travel i.e. airfares cost (up-down), accommodation/hotel cost, local transportation cost, food cost, the daily allowances for seven (07) days etc.

OR


Third Party inspection as per GCC clause 32.1. In case of Third-party inspection, the supplier will arrange a video call participation with purchaser during the witness.

3. The installation, alignment, adjustment, coupling along with the testing and commissioning of the supplied motor shall be carried out by the manufacturer expert of the motor. All cost regarding the test and commissioning of the motor and expert from manufacturer must be included in the actual cost of the supplied motor.


4. The delivery point would be warehouse (South plant) of Ashuganj Power Station Company Ltd. (APSCL), Ashuganj, Brahmanbaria-3402, Bangladesh. After receiving the motor by the warehouse of APSCL, the authority of APSCL will provide the schedule for Installation, Testing and Commissioning within 120 calendar days of the delivery. The Installation, Testing and Commissioning work shall be completed within 10 calendar days from the date of plant shut down. The plant shut down shall be given at a suitable duration of time within six (6) months from the date of receipt of Motor at APSCL Plant site. The Manufacturer's expert shall start journey only after getting notification from APSCL.

In the capacity of: Duly authorized to the sign the Tender on behalf of the Tenderer. Date:






Doylell




Noupell

X



Napel


P



Daugel

Q.

	Р	UMP DA	TA SHEETS	
Rev.	05	Doc. Nº	112070-01-MEC-HD-0001	
Date:	10.09.2014			FLOWSERVE
Pag.	1 of 2	Client Doc. Nº	S003-112070-01-MEC-HD-0001	





Stamps:

5

Rev.	Descripción Description Description	Autor Made by Auteur	Comprobado Checked by Verifié	Aprobado Approved by Approuvé	Fecha Date Date
00	FOR APPROVAL	SC	SC	ED	24.12.2013
01	As per comments	SC	SC	ED	13.02.2014
02	FOR APPROVAL	SC	SC	ED	25.04.2014
03	FOR APPROVAL	SC	SC	ED	16.05.2014
04	FOR APPROVAL	SC	SC	ED	30.06.2014
05	FOR APPROVAL	SC	SC	ED	10.09.2014

Este documento no puede ser reproducido ni comunicado a terceros sin la autorización de CTI. This document must not be copied or disclosed to third parties without CTI consent. Ce document ne peut être reproduit ni comuniqué à des tiers sans autoritation de CTI.

## PUMP DATA SHEETS

Rev.	05	Doc. Nº	442070 04 MEC UD 0004
Date	10.09.2014		112070-01-MEC-HD-0001
Pag.	2 de 2	Client Doc. Nº	S003-112070-01-MEC-HD-0001

### CHANGE LOG

REV.	SECCION / PARRAFO AFECTADO	DOCUMENTO INICIAL RAZONES DEL CAMBIO
00 24.12.2013		FOR APPROVAL
01 13.02.2014		As per comments
02 25.04.2014		FOR APPROVAL
03 16.05.2014		FOR APPROVAL
04 30.06.2014		FOR APPROVAL
05 10.09.2014	AS PER CUSTOMER COMMENTS	FOR APPROVAL

**FLOWSERVE** 

GHES		JGANJ 450 MW C		POWER PLANT		K		RA	REV DATE: BY: CHECK:	5 10.09.2014 SC ED
	AD125		(SOUTH)	w			INELECTRA		CHECK: APROBED:	ED MD
										l
				CIRCULA	TING WATER PUMP DA	ATA SHEET				
SENERAL TEM (KKS)	00PAC10/20AP001				Supplier	FLOWSERV	E			
Service	Cooling water			1	Model	53 APM				
Quantity	2x100% NOT CUALIFIE		CATEGORY 1	CATEGORY 2	Type CATEGORY 3	Vertical wet p	iit			
TEX Category			CATEGORI 10	GATEGORTZE						
luid			Raw W		Barometric absolute pressu Ambient temperature (°C)	ire ( mbar)			1013 35	
Temperature	e (max / normal/ min) (°C)	)	39/35	5/15	Relative humidity (%)				98	
Viscosity (C	(st)		0,72 Cst (	@ 35° C	Liquid level (max/normal/m Sump depth (m) (PWD)	in) (PWD)		7,8/6	,6 / 1,16 See Note 2 & -5,9 m	3)
Density (kg/r	m3) lute pressure (bar)		994,21 kg/m 0.056 bar		Design gauge pressure (ba	ar)			4,5 / -0,5 barg	
Solid conten	nt (mg/l)		32	2	Design temperature (°C)				39	
ocation (Outdoo	or/ Indoor)	SPECIFICATION	Outd	ioor	Seismic qualification		SUPPLIE		(Z = 0.2 g) BNBC20	06
	<u> </u>	PECIFICATION				-T			Operating Point 2	Run out Poir
Operating conditi	ions				Shut-off Condition	N	Ainimum Flow	Operating Point 1 (Contractual Point)	(Run out defined with system curves)	(*Only with Hi Water Level
Flow			Q oper. = 29023 m		0 38.5		25100 23.3	29023	34780	41000
	@ minimun liquid level sure at pump discharge fla	ange	TDH oper.= 21,9 m (barg)		2.81 at LWL	<u> </u>	1.34 at LWL	1.19 at LWL	1.35 at HWL	0.44 (*) at HV
Pump efficie	ency		(%)		N/A		81.5	86.8	83.1	63
NPSH requir			(m)		N/A N/A		9.8	9.1	2.91	14.5
Submergen Pump brake	e horsepower		(m) (kW)		-		1944	1984	1360	1322
PSH avail. (at n	minimum liquid level)		(m)				15.2			
	vail. (at minimum liquid lev	el)	(m)				6.3			
Speed First critical spee	ed .		(r.p.m.)				> 460			
	able reverse speed		(r.p.m.)				558 484			
	vable reverse speed tion time at shut-off conditi	ion	(r.p.m.) (s)				30			
oump rotation		(1)	CW or CCW				CCW			
Noise level 1 m a	away from the pump		82 dBA				82 dB/	A		
Number of stage							1			
	easured from baseplate (m				L (pump ) = 14.368			L (pump + bell ) = 14.3	68	
	Distance from the back w bell centerline	all to the pump	(mm)				1875			
	Distance between the inle	et bell and floor	(mm)				732			
Pump Intake Dimensions (by							2194			
ANSI/HI 9.8)	inier beir dutside diamete		(mm)		· · · · · · · · · · · · · · · · · · ·			· · · · · · · · · · · · · · · · · · ·		
	Distance from pump inlet the through-flow traveling		n (mm)				N/A			
	Y)			Engan	Position		Size	c	lass/ Rating	Faces
Discharge	Position Above soleplate		nge class	Faces	Above soleplate		60"		207 Table 2 Class B	I FF
Nozzle	Below soleplate	🛛 AWWA		C RF	Below soleplate				Oper	
					Enclosed		Semiopen			
impeller							Dactual= 1214 mm		jumin≓ i	1188 mm
	Mechanical seal	Pumped fluid			Dmax= 1306 mm		Dactual= 1214 mm Make: Flowserve	D Pumper	d fluid Externa	al 🗋
Impeller					Dmax= 1306 mm Mechanical seal	<u>.</u>			d fluid Externa nin	1188 mm al PS = μm
Impeller	<ul> <li>Mechanical seal</li> <li>Packing</li> </ul>	Pumped fluid			Dmax= 1306 mm Mechanical seal Packing		Make: Flowserve Flushing Nº : API Plan 1	3 Q= 1/n	d fluid Externa nin g. T= ℃ Q.= 1/min PS	al [] PS = μm = μm
Impeller Shaft sealing					Dmax= 1306 mm  Mechanical seal  Packing  Line shaft	Grease	Make: Flowserve Flushing N° : API Plan 1 [2] Pumped fluid [2] External fluid	3 Q= 1/n	d fluid Externa nin g. T= ℃ Q= 1/min PS p= barg.T=	al [] PS = μm = μm •C
Impeller Shaft sealing					Dmax= 1306 mm Mechanical seal Packing		Make: Flowserve Flushing N° : API Plan 1 2 Pumped fluid External fluid 2 Pumped fluid	3 Q= 1/n	d fluid Externa nin r.g. T= ℃ Q = 1/min PS p = barg. T= Q = 1/min PS p = barg. T=	$\frac{\mu}{PS = \mu m}$ $\frac{\mu}{PS = \mu m}$ $\frac{\mu}{PS = \mu m}$ $\frac{\mu}{PS = \mu m}$
Impeller Shaft sealing Bearings	Packing Pull out				Dmax= 1306 mm  Mechanical seal  Packing  Line shaft  Oil  Thrust  Pull out	Grease	Make: Flowserve Flushing N° : API Plan 1 2 Pumped fluid External fluid 2 Pumped fluid	3 Q= Vn p = bar	d fluid Externa nin $G_{\mu} = 0$ $G_{\mu} =$	$\frac{1}{PS} = \mu m$ $\frac{0}{C}$ $\frac{1}{PC} = \mu m$ $\frac{0}{PC}$ Yes
Impeller Shaft sealing Bearings	Packing Pull out Non pull out	Fluid from externation Fluid from externatio	ternal source	Size	Dmax= 1306 mm  Mechanical seal  Packing  Line shaft Oil  Thrust Oil  Oil	Grease	Make: Flowserve Flushing N° : API Plan 1 2 Pumped fluid External fluid 2 Pumped fluid	3 Q≣ //n p = bar	d fluid Externa nin Q = 1/min PS p = barg. T= Q = 1/min PS p = barg. T= Inner colum ☐ ype	$PS = \mu m$ $PS = \mu m$ $C$ $= \mu m$ $C$ $C$ $Yes$ No $Size$
Impeller Shaft sealing Bearings Arrangement Auxiliary	Pull out Non pull out Denomination U Vent	Fluid from exte	Type	Size	Dmax= 1306 mm       Packing       Line shaft       OThrust       Pull out       Non pull out       Denominatic	Grease	Make: Flowserve Flushing N° : API Plan 1 2 Pumped fluid 2 External fluid 2 Pumped fluid 2 External fluid	3 Q= Vn p = bar	d fluid Externa nin g. T= °C Q = 1/min PS p = bar g. T= Q = 1/min PS p = bar g. T= linner colum □ ype Connectio	al PS = μm °C °C Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections	Pull out Pull out Non pull out Denomination Vent Manometer	Fluid from exte	Type C Connection	Size	Omax=1306 mm       Ø Mechanical seal       Packing       Une shaft       Ø Thrust       Pull out       Non pull out       Denominatio       Uvent       Manometer	Grease	Make: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid External fluid Quantity Cuantity	3 Q= Vr p = bar Plugg Plugg Plugg	d fluid Extema nin g. T= °C Q = 1/m in PS p = bar g. T= Q = 1/m in PS p = bar g. T= Inner colum ype Connectio Connectio	al PS = μm °C °C Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxiliary connections Anchor bolts	Pull out Pull out Non pull out Denomination Vent Manometer Information	Fluid from external     Plugg     Plugg	Type Connection Connection Duply	Size	Dmax= 1306 mm       Packing       Line shaft       OThrust       Pull out       Non pull out       Denominatic	Grease	Make: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator	3 Q= Vn p = bar	d fluid Externa nin (2007) Externa p = 1/min PS p = barg. T= 0 = 1/min PS p = barg. T= inner colum 2 ype Connectio	al PS = μm °C °C Yes No Size in
Impeller Shaft sealing Bearings Arrangement Auxiliary connections Anchor bolts Speed regulation	Pull out  Pull out  Non pull out  Vent  Manometer  Information Variable speed Constant speed	Fluid from exte     Fluid from exte     Plugg     Plugg     Plugg     Hydraulic sç     Frecuency v	Type Connection Connection Connection Supply peed variator variator		Omax= 1306 mm       Ø Mechanical seal       Packing       Uhe shaft       Ø Hill       Ø Thrust       Ø Non pull out       Denominatic       Went       Manometer       Information       Variable speed       Ø Constant speed	Grease Grease	Nake: Flowserve Flushing N° : API Plan 1 2 Pumped fluid 2 Pumped fluid 2 External fluid 2 Quantity	3 Q= Vr p = bar Plugg D Plugg D Supply	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al □ PS = µm °C i = µm °C Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling	Pull out Pull out Non pull out Denomination Vent Manometer Information Variable speed Constant speed Zeflexble [2Rigd]	Fluid from exter     Plugg     Plugg     Plugg     Plugg     Frecuency v     Spacer	Type       	Size	Dmax= 1306 mm       Packing       Line shaft       Oil       Thrust       Pull out       Non pull out       Denomination       Vent       Information       Variable speed	Grease Grease	Make: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator	3 Q= Vr p = bar Plugg Plugg Plugg	d fluid Externa nin (2007) Externa p = 1/min PS p = barg. T= 0 = 1/min PS p = barg. T= inner colum 2 ype Connectio	al □ PS = µm °C i = µm °C Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxiliary connections Anchor bolts Speed regulation Coupling Baseplate	Pull out  Pull out  Non pull out  Vent  Manometer  Information Variable speed Constant speed	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type Connection Connection Connection Supply peed variator variator		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Nake: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator	3 Q= Un p = bar p = bar Plugg () Plugg () Supply Spacer	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling Baseplate	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Nake: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator	3 Q= Un p = bar p = bar Plugg () Plugg () Supply Spacer	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxiliary connections Anchor bolts Speed regulation Coupling Baseplate	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Nake: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator	3 Q= Un p = bar p = bar Plugg Q Plugg Q Supply Supply Soleplate	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling Baseplate	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Make: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator	3 Q= Un p = bar p = bar Plugg Q Plugg Q Supply Supply Soleplate	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling Baseplate INSTRUMENT	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Make: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator	3 Q= Un p = bar p = bar Plugg Q Plugg Q Supply Supply Soleplate	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxiliary connections Anchor bolts Speed regulation Coupling Baseplate	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Make: Flowserve Flushing Nº : API Plan 1  Pumped fluid  External fluid  Quantity  Hydraulic variator  Hydraulic variator  Rafer to Pump In	3 Q= Un p = bas p = bas Plugg D Supply Supply Soleplate strument List	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling Baseplate INSTRUMENT INSTRUMENT MOTOR Manufacturer Power	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Nake: Flowserve Flushing N° : API Plan 1 Pumped fluid External fluid Cuantity Quantity Hydraulic variator Frecuency variator Rafer to Pump In TBC 22201	3 Q= Vr p = bar p = bar Plugg D Supply Supply Strument List Strument List	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al □ PS = µm °C i = µm °C Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxdiary connections Anchor bolts Speed regulation Coupling Baseplate INSTRUMENT Manufacturer Power Speed For the sealing Manufacturer Speed MottoR Manufacturer Power Speed (r.p.m.)	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from exter  Fluid from exter  Plugg  Plugg  Hydraulic sg  Frecuency u Spacer  d	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Make: Flowserve Flushing Nº : API Plan 1  Pumped fluid  External fluid  Quantity  Hydraulic variator  Hydraulic variator  Rafer to Pump In	3 Q= Vr p = bas p = bas Plugg Q Supply Supply Soleplate strument List	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling Baseplate INSTRUMENT MontoR Manufacturer Power Speed (r.p.m.) Cooling fluid	Pull out Non pull out Non pull out Denomination Vent Information Variable speed Constant speed Forwhole ZPligid Conver pedestal/Head	Fluid from external Fluid	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Nake: Flowserve Flushing Nº : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator Refer to Pump In TEC 22201 372	3 Q= Vr p = bas p = bas Plugg Q Supply Supply Soleplate strument List	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al □ PS = µm °C i = µm °C Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling Baseplate INSTRUMENT MontoR Manufacturer Power Speed (r.p.m.) Cooling fluid	Pull out Pull out Non pull out Denomination Vent Information Variable speed Constant speed Fiexble ZRigid Dorver bedstal/Heac SAND ACCESSORIES O	Fluid from external Fluid	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Nake: Flowserve Flushing Nº : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator Refer to Pump In Refer to Pump In TEC 22201 372	3 Q= Vr p = bas p = bas Plugg Q Supply Supply Soleplate strument List	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m
Impeller Shaft sealing Bearings Arrangement Auxilary connections Anchor bolts Speed regulation Coupling Baseplate INSTRUMENT MOTOR Manufacturer Power Speed (r.p.m.) Cooling fluid	Pull out Pull out Non pull out Denomination Vent Information Variable speed Constant speed Fiexble ZRigid Dorver bedstal/Heac SAND ACCESSORIES O	Fluid from external Fluid	Type       		Dmax= 1306 mm       Packing       Line shaft       Oline shaft	Grease Grease	Nake: Flowserve Flushing Nº : API Plan 1 Pumped fluid External fluid Quantity Quantity Hydraulic variator Frecuency variator Refer to Pump In Refer to Pump In TEC 22201 372	3 Q= Un p = bar p = bar T] Plugg □ Supply Supply Sleplate strument List Srument List	d fluid Externa hin g. T= ℃ Q = Umin PS p = barg. T= Q = Umin PS p = barg. T= inner colum connectio Connectio Connectio	al PS = μm °C ·c Yes No Size m

Doupell



	GNFS	ŝ∧			畬				TC	v					REV	5
	legenierie y Tacanico		ASHU	GANJ 450 MV	V COMBINED CYCLI	E POWER PLA	ANT								DATE: BY:	10.09.2014 SC
	MPRESARIES AGRI	PADOS			(SOUTH)			<u> </u>		тя	KINE	ECTRA			CHECK: APROBED:	ED MD
lterr			1			CIRCU		WATER P				201104		•		
	PUMP MATER	IALS								TA SHEET				·		· · · · · · · · · · · · · · · · · · ·
	nlet beli Bowl				A285 Gr. C A285 Gr. C		Inlet be Bowl	ell							ASTM A36	
	mpeller Diffuser				ASTM A 743 CA 6 N	NM	Impelle							A	ASTM A36 STM A743 CA6NM	
	Shaft				A285 Gr. C ASTM A 276 Ty 410	0	Diffuse Shaft							ASTA	A A276 Ty. 410 Con	d.T
	Column pipe nner colum				A285 Gr. C N/A		Colum Inner c	n pipe							ASTM A36	
	Discharge elbo				A285 Gr. C		Discha	irge elbow/h	ead						N/A ASTM A36	
	Casing wear rin mpeller wear ri	ings			Stainless steel Stainless steel			wear rings er wear rings							CA15 Hardened CA15	
	Shaft sleeves Radial bearings				ASTM A 276 Ty 410	0		leeves bearings						A	STM A276 Ty. 410	
	Bolting						Pressu	re Bolting							ber - Bronze Backe ASTM A193 Gr. 88	d
	Vet bolting Auxiliary piping							l minor boltin ry piping	g						AISI 410	
	Soleplate Pump base plat	te			Carbon steel Carbon steel		Solepla	ate							ASTM A36	
							-						-	·		
	ECHANICAL															
	Noment of inert	ia WR <sup>2</sup> Nominal pump	torque		(Kg. m <sup>2</sup> ) (N. m)							38				
		Maximum requ Maximum requ	ired torque o	luring starting	(N. m)		-					509				
	orque	conditions			(N. m)							-				
		Maximum torqu withstand			(N. m)											
		Maximum appli account safety		ent taking into	(N. m)											
	orces and mor	ments at pump d	lischarge noz	zle			1				Fx= 273	74 N. Fy=246	83 N, Fz=	80457 N		
	Veights (aprox.	)									IX=30519	Nm, My=383: Pump: 28	000 Kg	26475 Nm		
		Downward	Maximum	·	(N)							Motor: 25	500 Kg			
	'hrust (at the oupling)		Continous Maximum		(N) (N)		1				т	hrust bearing	 >n the pum	ρ.	· •	
	THER REQUI	Upward 0	Continous.		(N)		-									
1 "		REALENTO														
<u> </u>												7				
	EMARKS	coupling side														
(	1) Viewed from 2) Plamt elevat	ion 100000 corre	esponds to g	round elevation	+9.65 MSL (PWD) e conditions 0 5m. Wat	ter level elevation	1 +0 68m	(PW(D)				2				
	1) Viewed from 2) Plamt elevat	ion 100000 corre n inlet channel a	ind cleaning	system for wors	e conditions 0.5m. Wat											
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	esponds to g ind cleaning A 2194	round elevation system for wors B 2500	+9.65 MSL (PWD) e conditions 0.5m. Wat C 6300	ter level elevation	1 +0.66m E 732	F&G	H 2×3209	1 400+3200	J 1524	ĸ	L 3705	M	Not	185
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n inlet channel a DRAWING	A A	system for wors B	e conditions 0.5m. Wat C 6300	D	E	F&G			J 1524			M	Not	ias
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	A A	system for wors B	e conditions 0.5m. Wat	D	E	F&G				ĸ		M	No	las
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	A A	system for wors B	e conditions 0.5m. Wat C 6300	D	E	F&G				ĸ		M	Not	185
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	A A	system for wors B	e conditions 0.5m. Wat C 6300	D	E	F&G				ĸ		M	Not	185
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	A A	system for wors B	e conditions 0.5m. Wat C 6300	D	E	F&G				ĸ		M	Not	185
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	A A	system for wors B	e conditions 0.5m. Wat C 6300	D	E	F&G				ĸ		M	Not	138
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	A A	system for wors B	e conditions 0.5m. Wat C 6300	D	E	F&G			1524	K 3426 (aprox)		M	Nel	tas
	1) Viewed from 2) Plamt elevat 3) Head loses I	ion 100000 corre n infet channel a DRAWING SPECIFIC.	A A	system for wors B	e conditions 0.5m. Wat C 6300	D	E 732	F & G 4368	2×3200		1524	K 3426 (aprox 3410N DATA 9,2 m (PWD)	<u>3705</u> (EI +9	9550mm)	Nol	ias
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A A	B 2500	e conditions 0.5m, Wat	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	K 3426 (aprox)	3705 (EI +9 ) (EI +9		Not	
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m, Wat	D	E 732 REFERE MAXIML NORMA	F&G 4368	2×3200		1524	<u>к</u> 3426 (аргох) 4110N DATA 9,2 m (PWD) 7.8 m (PWD)	(EI +9 ) (EI +9 ) (EI +9	9550mm) 8130mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m, Wat	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)	Not	
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m. Wat C 0300 L L 4 K 4 - - - - - - - - - - - - -	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m. Wat C 0300 L L k t J t J t J t L L L L L L L L L L L L L	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m. Wat C 0300 L L 4 K 4 - - - - - - - - - - - - -	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m. Wat C 6300 L k k k k k k k k k k k k k	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m. Wat C 6300 L L K E D F P P F P F F	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	A 2194	B 2500	e conditions 0.5m. Wat C 6300 L k k k k k k k k k k k k k	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	Ide 110000 correl initel channel a DRAWING BPECIFIC SUPPLIER REFE	RENCE ELEVATIC	B 2500	e conditions 0.5m. Wat C 6300 L L K E D F P P F P F F	D	E 732 REFERE MAXIML NORMA	F&G 4368 368 368 368 4368 4368 368 368 368 368 368 368 368 368 368	2×3200		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	ian 10000 corre I niet channel ai DRAWING BPECIFIC SUPPLIER	RENCE ELEVATIC	B 2500	e conditions 0.5m. Wat C 6300 L L K E D F P P F P F F	D	E 732 REFERE MAXIML NORMA	ENCE INCE INCUID LE IN LIQUID LE M LIQUID LE	EVEL VEL VEL		1524	K 3426 (aprox) 3426 (aprox) 3426 (aprox) 7,8 m (PWD 6,6 m (PWD 1,16 m (PWD	(EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)		
	1) Viewed from 2) Plamt elevat 3) Head loses I	Ide 110000 correl initel channel a DRAWING BPECIFIC SUPPLIER REFE	RENCE ELEVATIC	B 2500	e conditions 0.5m. Wat C 6300 L L K E D F P P F P F F	D	E 732 REFERE MAXIML NORMA	F&G 4368 4368 M LIQUID LE LI LIQUID LE LI LIQUID LE M LIQUID LE M LIQUID LE	rVEL VEL VEL sr Rev		1524	К 3426 (аргох) 3426 (аргох) 34	(EI +9 ) (EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)	See note 2	] ]
	1) Viewed from 2) Plamt elevat 3) Head loses I	Ide 110000 correl initel channel a DRAWING BPECIFIC SUPPLIER REFE	RENCE ELEVATIC	B 2500	e conditions 0.5m. Wat C 6300 L L K E D F P P F P F F	D	E 732 REFERE MAXIML NORMA	ENCE MUQUID LE LUQUID LE LUQUID LE Suppli	rvel Vel Vel ar Rev		1524	K 3426 (aprox) 3426 (aprox) 3426 (aprox) 5.6 m (PWD 6.6 m (PWD 1.16 m (PWD) 1.16 m (PWD 1.16 m (PWD) 1.16 m (PW	(EI +9 ) (EI +9 ) (EI +9 ) (EI +9 ) (EI +9	9650mm) 8130mm) 4026mm)	See note 2	
	1) Viewed from 2) Plamt elevat 3) Head loses I	Ide 110000 correl initel channel a DRAWING BPECIFIC SUPPLIER REFE	RENCE ELEVATIC	B 2500	e conditions 0.5m. Wat C 6300 L L K E D F P P F P F F	D	E 732 REFERE MAXIML NORMA	ENCE INCE IM LIQUID LE LIQUID LE M LIQUID LE Suppli	rvEL /EL /EL /EL /EL /EL		1524	К 3426 (аргох) 3426 (аргох) 3426 (аргох) 3426 (аргох) 7.8 m (РУС 6.6 m (РУС 6.6 m (РУС 1,16 m (РУС 1,16 m (РУС 1,16 m (РУС 1,16 m (РУС	(EI +9 ) (EI +9 ) (EI +9 ) (EI +9 ) (EI +9 ) (EI +9 2013 2014 2014	9650mm) 8130mm) 4026mm)	See note 2	

Deepell

C